

From: [Hewitson, Annette](#)
To: [North Killingholme Power Project](#)
Subject: EN010038 North Killingholme Power Project - Non Material Amendment
Date: 23 September 2020 11:53:47
Attachments: [200923 EN010038 EA representation to SoS re non-material amend North Killingholme Power Project.pdf](#)

Dear Sir/Madam

Please find the attached comments in respect of the above.

Kind regards,

Annette Hewitson | Principal Planning Adviser
Lincolnshire & Northamptonshire Area
Environment Agency | Ceres House, Searby Road, Lincoln LN2 4DW

 annette.hewitson@environment-agency.gov.uk

: 02030 254924



We have recently published new webpages for [LPAs](#), [developers](#) and [Neighbourhood Planning Groups](#) giving clarification on our planning consultation role. Please refer to this to check if we can provide you with advice on your development proposals. For developments in areas at risk of flooding, please refer to our new [Flood Risk Assessment checklist](#).

We're committed to providing excellent customer service and would appreciate your feedback.

Were you happy with the service you received today?



This message has been sent using TLS 1.2 Information in this message may be confidential and may be legally privileged. If you have received this message by mistake, please notify the sender immediately, delete it and do not copy it to anyone else. We have checked this email and its attachments for viruses. But you should still check any attachment before opening it. We may have to make this message and any reply to it public if asked to under the Freedom of Information Act, Data Protection Act or for litigation. Email messages and attachments sent to or from any Environment Agency address may also be accessed by someone other than the sender or recipient, for business purposes.

The Secretary of State
c/o The Planning Inspectorate
National Infrastructure
Temple Quay House
2 The Square
Bristol
BS1 6PN

Our ref: AN/2013/117045/02-L01
Your ref: EN010038
Date: 23 September 2020

Dear Sir/Madam

**470MWe capacity thermal generating power station - non material amendment application
North Killingholme Power Project, North Killingholme**

We have received notice from the applicant, C.Gen Killingholme Limited, that an application for a non-material amended to the North Killingholme Power Project scheme has been submitted to the Secretary of State.

We have reviewed the supporting documents to this application and are of the opinion that there are no likely significant effects on the environment (for matters that fall within our remit) arising from the proposed amendments. Accordingly, we have no objection to the application.

Information for the applicant

Given that the site is located in an area of 'high probability' of flooding, we recommend that prior to construction the applicant reviews the flood risk data we hold, to ensure decisions factor in the latest available information. The Humber water levels are currently being reviewed/updated and are due for release towards the end of 2020. Whilst we do not envisage any significant change in predicted flood levels, we recommend that this data is used to check critical infrastructure construction levels when it is available.

Should you require any additional information, or wish to discuss these matters further, please do not hesitate to contact me on the number below.

Yours faithfully

**Annette Hewitson
Principal Planning Adviser**

Direct dial 02030 254924
Direct e-mail annette.hewitson@environment-agency.gov.uk