

Hornsea 2 Project
The Planning Inspectorate
Temple Quay House
2 The Square
Bristol
BS1 6PN

Stuart Curry
Senior Development Manager Offshore Wind
Tel: 0207 851 5077

Your Ref.:
Our Ref.:

8 March 2018

Dear Sirs

The Hornsea Two Offshore Wind Farm Order 2016 – Application for a Non-Material Change

We have received a letter and notice from Orsted on behalf of Optimus Wind Limited and Breesea Limited (“the Project Two Companies”), the named undertakers in the Hornsea Two Offshore Wind Order 2016 as subsequently amended (“the DCO”), regarding an application for a non-material change to the DCO.

The Crown Estate was previously consulted on the DCO and we have therefore been informed of the proposed reduction in the number of the offshore high voltage alternating current (HVAC) collector substations permitted from six to three, the increase in the offshore HVAC topside dimensions and the proposed increase in the maximum platform area. We note that the proposed increase in the topside area does not require an increase in the footprint of the HVAC, nor any increase in the number of jacket legs, or piles. We therefore concur that the proposed amendments will reduce the assessed impact on the seabed.

The Crown Estate does not have any objections to the proposed amendments to the Hornsea Two Offshore Wind Farm DCO.

Yours faithfully



Stuart Curry
Senior Development Manager Offshore Wind