

Appendix 5.2: Methodology Supporting Tables

Table 5.15 Discrete Receptor Details

| Ref | Name | OS Location | |
|-----|--|-------------|--------|
| | | X | Y |
| 1 | Talbot Court Nursing Home, Talbot Road | 276923 | 189479 |
| 2 | 25 Lower West End Road | 277067 | 189006 |
| 3 | 21 Duke Street | 277614 | 188396 |
| 5 | 40 Byass Street | 278238 | 187110 |
| 6 | 1 Ten Acre Wood | 279563 | 186315 |
| 8 | 26 Curt Ucha Terrace (Talbot Road) | 277098 | 189213 |
| 11 | Port Talbot Fire Station | 277388 | 188733 |
| 14 | Theodore Road | 277328 | 189385 |
| 15 | Talbot Road | 276833 | 189567 |
| 17 | Port Talbot Docks | 276346 | 189446 |
| 18 | Prince St. | 277689 | 188235 |
| 23 | 12 Lower West End Road | 277139 | 188901 |
| 24 | Woodfield Street | 277461 | 188673 |
| 27 | 91 Talbot Road | 277020 | 189291 |
| 28 | 74 Talbot Road | 277035 | 189297 |
| 29 | 44 Abbey Road | 277179 | 189345 |
| 30 | 9 Abbey Road | 277275 | 189444 |
| 31 | 1 Abbey Road | 277329 | 189527 |
| 32 | Glen Afan Comprehensive School | 276715 | 189941 |
| 33 | Dyffryn Comprehensive School | 277079 | 189508 |
| 34 | Residential, 1 Castle Street | 276241 | 190110 |

Table 5.16 Traffic Data Used in the Assessment of Local Air Quality

| Link Ref | 2013 Base Year | | 2018 Base Flows | | 2018 With Option 1 & Option 2 Phase 1 | | Change (2018 With – 2018 Base) | | 2028 WO* | | 2028 With Option 2 Phase 2 | | Change (2028 With – 2028 Base) | | Speed (km/h) |
|----------|----------------|------|-----------------|------|---------------------------------------|------|--------------------------------|-----|----------|------|----------------------------|------|--------------------------------|-----|--------------|
| | AADT | HDV | AADT | HDV | AADT | HDV | AADT | HDV | AADT | HDV | AADT | HDV | AADT | HDV | |
| Link 1 | 11018 | 496 | 11412 | 514 | 11466 | 514 | 54 | 0 | 12199 | 549 | 12253 | 549 | 54 | 0 | 48 |
| Link 2 | 11912 | 476 | 12338 | 494 | 12392 | 494 | 54 | 0 | 13189 | 528 | 13243 | 528 | 54 | 0 | 48 |
| Link 3 | 16154 | 646 | 16731 | 669 | 16785 | 669 | 54 | 0 | 17885 | 715 | 17939 | 715 | 54 | 0 | 48 |
| Link 4 | 12184 | 548 | 12619 | 568 | 12943 | 568 | 324 | 0 | 13489 | 607 | 13813 | 607 | 324 | 0 | 64 |
| Link 5 | 9968 | 797 | 10324 | 826 | 10590 | 855 | 265 | 29 | 11036 | 883 | 11302 | 912 | 265 | 29 | 64 |
| Link 6 | 9968 | 1196 | 10324 | 1239 | 10590 | 1268 | 265 | 29 | 11036 | 1324 | 11302 | 1354 | 265 | 29 | 80 |
| Link 7 | 12922 | 1034 | 13384 | 1071 | 13649 | 1100 | 265 | 29 | 14307 | 1145 | 14572 | 1174 | 265 | 29 | 80 |
| Link 8 | 11684 | 701 | 12101 | 726 | 12128 | 726 | 27 | 0 | 12936 | 776 | 12963 | 776 | 27 | 0 | 48 |
| Link 9 | 21306 | 852 | 22067 | 883 | 22175 | 883 | 108 | 0 | 23589 | 944 | 23697 | 944 | 108 | 0 | 48 |
| Link 10 | 7384 | 332 | 7648 | 344 | 7810 | 344 | 162 | 0 | 8175 | 368 | 8337 | 368 | 162 | 0 | 48 |
| Link 11 | 7384 | 332 | 7648 | 344 | 7810 | 344 | 162 | 0 | 8175 | 368 | 8337 | 368 | 162 | 0 | 48 |
| Link 12 | 12922 | 581 | 13384 | 602 | 13708 | 602 | 324 | 0 | 14307 | 644 | 14631 | 644 | 324 | 0 | 64 |

* Option 2 Phase 1 will not alter baseline traffic once the construction is completed as there are no additional vehicle movements associated with the operation of the boiler.



Table 5.19 Blast Furnace Gas Consumption

| Unit | With existing boiler plant | | With Option 1 or Option 2 second installation | | With Option 2 first installation | |
|---------------------------|----------------------------|------------|---|------------|----------------------------------|------------|
| | tonnes/hr | MWth | tonnes/hr | MWth | tonnes/hr | MWth |
| Margam C, boiler 6 | 130 | 101 | 130 | 101 | 130 | 101 |
| Margam C, boiler 7 | 130 | 101 | 130 | 101 | 130 | 101 |
| No. 3 boiler | 100 | 78 | 100 | 78 | 100 | 78 |
| Margam A, boiler 5 | 40 | 31 | - | - | 40 | 31 |
| Margam B, Mitchell boiler | 90 | 70 | - | - | 90 | 70 |
| Service boiler 4 | 50 | 39 | - | - | 30 | 23 |
| Service boiler 5 | 50 | 39 | - | - | 30 | 23 |
| New boiler 8 ^b | - | - | 189 | 148 | 189 | 148 |
| New boiler 9 ^b | - | - | 189 | 148 | -- | - |
| Average BFG flare | 166 | 129 | 17 | 13 | 17 | 13 |
| <i>Total</i> | <i>756</i> | <i>589</i> | <i>756</i> | <i>589</i> | <i>756</i> | <i>589</i> |

Notes: ^a Based on gross calorific value of 3.75 MJ/Nm³. ^b The new boilers are rated at 164 MWth, but will not always be fully fired with only BFG. The most common situation is that the boilers will be fired with blast furnace gas that may be enhanced by mixing small proportions of coke oven gas, BOS gas or natural gas to increase the calorific value as required, though over 85% of the thermal input will come from the blast furnace gas alone. The final split of gas will be determined on


an operational basis related to the gas availability a. It is anticipated that any gas sent to the new power station would otherwise have been sent to flare and as such the relative effects will be the same. In case of reduced availability of blast furnace gas, and in order to ensure the necessary supply of steam, natural gas can be used to supplement the BFG and the boilers will have the capacity to fire with only natural gas in case of a complete loss of BFG, however, the use of natural gas is uneconomic, and would only be used as a temporary measure if other gases were not available in sufficient quantity

Table 5.20 Emission Limit Values

| Scenario | Unit | Waste gas flow (Nm ³ /h @ 3% O ₂ , dry) | ELV (mg/Nm ³ @ 3% O ₂ , dry) | | | Pollutant emission rates (g/s) | | |
|---|--|---|--|-----|------------------|--------------------------------|------|-----------------|
| | | | NO _x | PM | SO ₂ | NO _x | PM | SO ₂ |
| With Existing Boilers | Margam C, boiler 6 | 166,807 | 300 | 50 | 800 | 13.9 | 2.32 | 37.1 |
| | Margam C, boiler 7 | 166,807 | 300 | 50 | 800 | 13.9 | 2.32 | 37.1 |
| | No. 3 boiler | 128,313 | 200 | 30 | 400 | 7.13 | 1.07 | 14.3 |
| | Margam A, boiler 5 | 51,325 | 300 | 50 | 800 | 4.28 | 0.71 | 11.4 |
| | Margam B, Mitchell boiler | 115,482 | 300 | 50 | 800 | 9.62 | 1.60 | 25.7 |
| | Service boilers 4&5 | 128,313 | 300 | 50 | 800 | 10.7 | 1.78 | 28.5 |
| | Flare | N/A | N/A | N/A | N/A | 3.79 | 0.32 | 1.62 |
| | Total with existing boiler plant | | | | | | 63.3 | 10.1 |
| With Option 1 or Option 2 second installation | Margam C, boiler 6 | 166,807 | 300 | 50 | 800 | 13.9 | 2.32 | 37.1 |
| | Margam C, boiler 7 | 166,807 | 300 | 50 | 800 | 13.9 | 2.32 | 37.1 |
| | No. 3 boiler | 128,313 | 200 | 30 | 400 | 7.13 | 1.07 | 14.3 |
| | New boiler 8 | 243,016 | 100 | 10 | 200 ^a | 6.75 | 0.68 | 13.5 |
| | New boiler 9 | 243,016 | 100 | 10 | 200 ^a | 6.75 | 0.68 | 13.5 |
| | Flare | N/A | N/A | N/A | N/A | 0.39 | 0.03 | 0.17 |
| | Total with Option 1 | | | | | | 48.8 | 7.09 |
| With Option 2 first installation | Margam C, boiler 6 | 166,807 | 300 | 50 | 800 | 13.9 | 2.32 | 37.1 |
| | Margam C, boiler 7 | 166,807 | 300 | 50 | 800 | 13.9 | 2.32 | 37.1 |
| | No. 3 boiler | 128,313 | 200 | 30 | 400 | 7.13 | 1.07 | 14.3 |
| | Margam A, boiler 5 | 51,325 | 300 | 50 | 800 | 4.28 | 0.71 | 11.4 |
| | Margam B, Mitchell boiler | 115,482 | 300 | 50 | 800 | 9.62 | 1.60 | 25.7 |
| | Service boilers 4&5 | 76,209 | 300 | 50 | 800 | 6.35 | 1.06 | 16.9 |
| | New boiler 8 | 243,016 | 100 | 10 | 200 ^a | 6.75 | 0.68 | 13.5 |
| | Flare | N/A | N/A | N/A | N/A | 0.39 | 0.03 | 0.17 |
| | Total with Option 2 first installation | | | | | | 62.3 | 9.79 |

Notes ELV = Emission Limit Value. ^a Values have been based on the ELV for firing blast furnace gas as set out in the IED.

Graph 5.1: Graph of Total Pollutant Emission Rates from the Tata Site Based on Emission Limit Values for each Assessment Scenario



Note: Mass emissions of SO₂ appear to increase with Option 2 Phase 1 relative to the Existing Case. This is due to the way that SO₂ emission from the flare, which does not have an Emission Limit Value, has been calculated in the existing scenario. In reality SO₂ emission can not increase above their existing levels as SO₂ is determined by the amount of sulphur in the fuel being burned which will not be altered by the proposed development. In reality SO₂ emission are likely to decrease in Option 2 Phase 2 due to acid gas control systems which are inherent to the boilers along with controlled combustion in the boilers which will reduce SO₂ formation.

Table 5.21 Measured Emissions from Existing Boilers

| Unit | Waste gas flow (Nm ³ /h @ 3% O ₂ , dry) | Pollutant concentrations (mg/Nm ³ at 3% O ₂ , dry) | | | | | | Actual oxygen (% , dry) | |
|---------------------------|---|--|----------|---------|-----------|---------|------------|-------------------------|-------------|
| | | NO _x | | CO | | PM | | Average | Range |
| | | Average | Range | Average | Range | Average | Range | | |
| Margam C, boiler 6 | 166,807 | 104 | 52 – 167 | 2 | 1 – 3 | 6.9 | 4.1 – 10.9 | 4.3 | 3.2 - 6.4 |
| Margam C, boiler 7 | 166,807 | 81 | 51 – 103 | 7 | 0 – 17 | 4.9 | 1.0 – 10.0 | 4.6 | 4.0 – 5.5 |
| No. 3 boiler | 128,313 | 23 | 11 – 51 | 38 | 18 – 68 | 2.6 | 1.6 – 3.4 | 11.1 | 10.0 – 12.2 |
| Margam A, boiler 5 | 51,325 | 38 | 19 – 54 | 723 | 9 – 9,418 | 2.1 | 0.6 – 2.7 | 9.5 | 7.8 – 11.7 |
| Margam B, Mitchell boiler | 115,482 | 28 | 12 – 56 | 389 | 2 – 4,319 | 4.6 | 0.5 – 8.0 | 11.5 | 9.7 – 13.6 |
| Service boilers 4&5 | 128,313 | 159 | 32 - 266 | 1,565 | 0 – 6,347 | 8.7 | 5.4 – 12.7 | 11.4 | 8.6 – 15.5 |



Table 5.22 Estimated Pollutant Emissions from Boilers Without New Power Plant

| Unit | Waste gas flow (Nm ³ /h @ 3% O ₂ , dry) | Pollutant emission Waste gas flow rates (g/s) | | | | | | | |
|---------------------------|---|---|------|------|-----------------|-----------------|------|------|-----------------|
| | | Long-term | | | | Max Short-term | | | |
| | | NO _x | CO | PM | SO ₂ | NO _x | CO | PM | SO ₂ |
| Margam C, boiler 6 | 166,807 | 4.81 | 0.08 | 0.32 | 1.27 | 7.72 | 0.15 | 0.51 | 1.27 |
| Margam C, boiler 7 | 166,807 | 3.73 | 0.32 | 0.23 | 1.27 | 4.77 | 0.77 | 0.46 | 1.27 |
| No. 3 boiler | 128,313 | 0.82 | 1.34 | 0.09 | 0.98 | 1.81 | 2.43 | 0.12 | 0.98 |
| Margam A, boiler 5 | 51,325 | 0.55 | 10.3 | 0.03 | 0.39 | 0.77 | 134 | 0.04 | 0.39 |
| Margam B, Mitchell boiler | 115,482 | 0.89 | 12.5 | 0.15 | 0.88 | 1.8 | 139 | 0.26 | 0.88 |
| Service boilers 4&5 | 128,313 | 5.67 | 55.8 | 0.31 | 0.98 | 9.48 | 226 | 0.45 | 0.98 |
| Flare | - | 3.79 | 20.6 | 0.32 | 1.62 | - | - | - | - |
| Total | - | 20.2 | 101 | 1.44 | 7.38 | - | - | - | - |

Table 5.24 Estimated Pollutant Emissions from Boilers With Option 1

| Unit | Waste gas flow (Nm ³ /h @ 3% O ₂ , dry) | Pollutant emission Waste gas flow rates (g/s) | | | | | | | |
|--------------------|---|---|------|------|-----------------|-----------------|------|------|-----------------|
| | | Long-term | | | | Max Short-term | | | |
| | | NO _x | CO | PM | SO ₂ | NO _x | CO | PM | SO ₂ |
| Margam C, boiler 6 | 166,807 | 4.81 | 0.08 | 0.32 | 1.27 | 7.72 | 0.15 | 0.51 | 1.27 |
| Margam C, boiler 7 | 166,807 | 3.73 | 0.32 | 0.23 | 1.27 | 4.77 | 0.77 | 0.46 | 1.27 |
| No. 3 boiler | 128,313 | 0.82 | 1.34 | 0.09 | 0.98 | 1.81 | 2.43 | 0.12 | 0.98 |
| New boiler 8 | 243,016 | 6.22 | 0.29 | 0.4 | 1.85 | 11.25 | 1.12 | 0.74 | 1.85 |
| New boiler 9 | 243,016 | 6.22 | 0.29 | 0.4 | 1.85 | 11.25 | 1.12 | 0.74 | 1.85 |
| Flare | - | 0.39 | 2.15 | 0.03 | 0.17 | - | - | - | - |
| Total | - | 22.2 | 4.47 | 1.47 | 7.38 | - | - | - | - |

Table 5.23 Estimated Pollutant Emissions from Boilers With Option 2 Phase 1

| Unit | Waste gas flow (Nm ³ /h @ 3% O ₂ , dry) | Pollutant emission Waste gas flow rates (g/s) | | | | | | | |
|---------------------------------|---|---|------|------|-----------------|-----------------|------|------|-----------------|
| | | Long-term | | | | Max Short-term | | | |
| | | NO _x | CO | PM | SO ₂ | NO _x | CO | PM | SO ₂ |
| Margam C, boiler 6 | 166,807 | 4.81 | 0.08 | 0.32 | 1.27 | 7.72 | 0.15 | 0.51 | 1.27 |
| Margam C, boiler 7 | 166,807 | 3.73 | 0.32 | 0.23 | 1.27 | 4.77 | 0.77 | 0.46 | 1.27 |
| No. 3 boiler | 128,313 | 0.82 | 1.34 | 0.09 | 0.98 | 1.81 | 2.43 | 0.12 | 0.98 |
| Margam A, boiler 5 | 51,325 | 0.55 | 10.3 | 0.03 | 0.39 | 0.77 | 134 | 0.04 | 0.39 |
| Margam B, Mitchell boiler | 115,482 | 0.89 | 12.5 | 0.15 | 0.88 | 1.8 | 139 | 0.26 | 0.88 |
| Service boilers 4&5 | 76,209 | 3.37 | 33.1 | 0.18 | 0.58 | 5.63 | 134 | 0.27 | 0.58 |
| Additional boiler 8 | 243,016 | 6.22 | 0.29 | 0.4 | 1.85 | 11.25 | 1.12 | 0.74 | 1.85 |
| Flare | - | 0.39 | 2.15 | 0.03 | 0.17 | - | - | - | - |
| Total | - | 20.8 | 60.1 | 1.43 | 7.38 | - | - | - | - |

Table 5.25 Stack/Emission Characteristics

| Unit/ Stack | OS Location | Height (m) | Diameter (m) | Actual O ₂ (% dry) | Waste gas flow ^a (Nm ³ /h, actual O ₂ , wet) | Mean molecular mass (kg/kmol) | Specific heat capacity (J/°C/kg) | Temperature (°C) |
|---------------------------|-------------------|-----------------------|-------------------|----------------------------------|---|----------------------------------|-------------------------------------|------------------|
| Margam C, boilers 6 & 7 | 277149, 188448 | 135 | 3.89 ^b | 4.5 | 380,303 | 31.7 | 984 | 215 |
| No. 3 boiler | 276980, 188470 | 33 | 2.8 | 11.1 | 240,845 | 30.6 | 990 | 150 |
| Margam A, boiler 5 | 277052, 188526 | 32 | 2.4 | 9.5 | 83,456 | 30.9 | 989 | 180 |
| Margam B, Mitchell boiler | 277164, 188185 | 37 | 2.7 | 11.5 | 225,461 | 30.6 | 991 | 200 |
| Service boilers 4 & 5 | 277851, 186608 | 68 | 2.5 | 11.4 | 247,682 | 30.6 | 991 | 200 |
| New boiler 8 | 277198, 188433 | 40 - 120 ^c | 2.5 | 3.0 | 255,283 | 31.9 | 982 | 125 |
| New boiler 9 | 277202, 188463 | 40 - 120 ^c | 2.5 | 3.0 | 255,283 | 31.9 | 982 | 125 |
| Average for BFG flare | | | | | Momentum flux (m ⁴ /s ²) | | Buoyancy flux ^d (MW) | |
| Without new boilers | 277142, | 54 | 1.2 | - | 1,208 | 116 | | |
| With new boiler(s) | 187509 | | | - | 13.1 | 12.1 | | |

Notes:

^a Calculated from BFG firing rate and actual waste gas oxygen content.^b Two flues, each with a diameter of 2.75 metres^c Range of potential stack heights - see text^d Assuming 90% of the heat input becomes sensible heat of the flare

- 1.1.1 It should be noted that the pollutant concentrations (both measured and ELVs) Table 5.20 and Table 5.24 are expressed at reference conditions of 3% oxygen and dry gas, however, the numbers presented in Table 5.25 are based on actual conditions for the purposes of calculating efflux momentum, buoyancy and hence plume rise. These values are expressed at actual oxygen and for wet gas and as such differ to those presented in the previous tables.
- 1.1.2 The following calculation sets out the methodology used to calculate emission for No. 3 boiler and has been included as an example. The BFG flow to the boiler is 100 tonnes per hour (Table 5.19) and density is 1.3386 kg/Nm³ (see paragraph 5.4.49), this equates to 74,705 Nm³/hour. Combustion with sufficient air to leave 3% waste gas oxygen yields 1.7176 Nm³ dry waste gas per Nm³ BFG (see paragraph 5.4.50), so the waste gas flow expressed at 3% oxygen, dry gas is $74,705 \times 1.7176 = 128,313$ Nm³/hour, as stated in Table 5.20, Table 5.22, Table 5.23 and Table 5.24. The mass emission rates then use this flow rate - so a NO_x ELV of 200 mg/Nm³ (expressed at 3% oxygen, dry gas) equates to a NO_x emission rate of $128,313/3,600 \times 200/1,000 = 7.13$ g/s and an average measured NO_x concentration of 23 mg/Nm³ (expressed at 3% oxygen, dry gas) equates to a NO_x emission rate of $128,313/3,600 \times 23/1,000 = 0.82$ g/s. Since the mean waste gas oxygen for this boiler is 11.1% (Table 5.21), the flow rate would be $128,313 \times (20.9-3)/(20.9-11.1) = 234,368$ Nm³/hour expressed at actual oxygen and for dry gas. The moisture content is the difference between the wet and dry waste gas volumes from paragraph 5.4.50 ($1.8043-1.7176 = 0.0867$ Nm³ H₂O per Nm³ BFG), so for a BFG rate of 74,705 Nm³/hour, there is 6,477 Nm³/hour water vapour. Adding this to the dry waste gas flow gives $234,368 + 6,477 = 240,845$ Nm³/hour expressed at actual oxygen and for wet gas as stated in Table 5.25.

Table 5.26 Building characteristics

| Unit/Stack | Stack Height (m) | Relevant Building | Building Characteristics | | |
|---------------------------|------------------|-----------------------|--------------------------|------------|-----------|
| | | | Height (m) | Length (m) | Width (m) |
| Margam C, boilers 6 & 7 | 121 | Margam C boiler house | 25 | 45 | 32 |
| No. 3 boiler | 33 | Margam A boiler house | 25 | 91 | 20 |
| Margam A, boiler 5 | 32 | Margam A boiler house | 25 | 91 | 20 |
| Margam B, Mitchell boiler | 37 | Margam B boiler house | 25 | 43 | 17 |
| Service boilers 4 & 5 | 68 | Hot Mill | 20 | 980 | 110 |
| New boiler 8 | 40 - 120 | New boiler house | 32 | 45 | 23.3 |
| New boiler 9 | 40 - 120 | New boiler house | 32 | 45 | 23.3 |
| BFG flare stack | 54 | No relevant building | - | - | - |

Table 5.27 Example of Where Air Quality Objectives Apply

| Averaging Period | Objectives should apply at: | Objectives should generally not apply at: |
|------------------|---|--|
| Annual mean | <p>All locations where members of the public might be regularly exposed. Building façades of residential properties, schools, hospitals, care homes etc.</p> | <p>Building façades or offices or other places of work where members of the public do not have regular access.</p> <p>Hotels, unless people live there as their permanent residence.</p> <p>Gardens of residential properties.</p> <p>Kerbside sites (as opposed to locations at the buildings façades), or any other location where public exposure is expected to be short-term.</p> |
| 24 hour mean | <p>All locations where the annual-mean objective would apply, together with hotels.</p> <p>Gardens of residential properties.</p> | <p>Kerbside sites (as opposed to locations at the buildings façade), or any other location where public exposure is expect to be short-term.</p> |
| 1 hour mean | <p>All locations where the annual and 24-hour mean would apply. Kerbside sites (e.g. pavements of busy shopping streets).</p> <p>Those parts of car parks, bus stations and railway stations etc which are not fully enclosed, where members of the public might reasonably be expected to spend one hour or more.</p> <p>Any outdoor locations to which the public might reasonably be expected to spend 1-hour or longer.</p> | <p>Kerbside sites where the public would not be expected to have regular access</p> |

Table 5.28 Discrete Receptor Details - Human

| Ref | Name | OS Location | |
|-----|---|-------------|--------|
| | | X | Y |
| 1 | Talbot Court Nursing Home, Talbot Road | 276923 | 189479 |
| 2 | 25 Lower West End Road | 277067 | 189006 |
| 3 | 21 Duke Street | 277614 | 188396 |
| 4 | Groeswen Park | 277938 | 188212 |
| 5 | 40 Byass Street | 278238 | 187110 |
| 6 | 1 Ten Acre Wood | 279563 | 186315 |
| 7 | 1 Conduit Place | 277541 | 189321 |
| 8 | 26 Curt Ucha Terrace (Talbot Road) | 277098 | 189213 |
| 9 | 20 Kings Street | 277092 | 190174 |
| 10 | 130a Water Street | 276063 | 189898 |
| 11 | Port Talbot Fire Station | 277388 | 188733 |
| 12 | Dyffryn School | 278700 | 187387 |
| 13 | Twll-yn-y Wal Park | 278196 | 187891 |
| 14 | Theodore Road | 277328 | 189385 |
| 15 | Talbot Road | 276833 | 189567 |
| 16 | Port Talbot Little Warren | 275313 | 188879 |
| 17 | Port Talbot Docks | 276346 | 189446 |
| 18 | Prince St. | 277689 | 188235 |
| 19 | Victoria Gardens | 275471 | 197183 |
| 20 | Pontardawe Post Office | 272031 | 203950 |
| 21 | Old Fire Station, Water Street, Port Talbot | 276131 | 189926 |
| 22 | 11 College Green Margam | 278794 | 187237 |
| 23 | 12 Lower West End Road | 277139 | 188901 |
| 24 | Woodfield Street | 277461 | 188673 |
| 25 | Eastern Primary School | 277606 | 188848 |
| 26 | Groes Primary School | 278590 | 187407 |
| 27 | 91 Talbot Road | 277020 | 189291 |

Table 5.28 Discrete Receptor Details - Human

| Ref | Name | OS Location | |
|-----|--------------------------------|-------------|--------|
| | | X | Y |
| 28 | 74 Talbot Road | 277035 | 189297 |
| 29 | 44 Abbey Road | 277179 | 189345 |
| 30 | 9 Abbey Road | 277275 | 189444 |
| 31 | 1 Abbey Road | 277329 | 189527 |
| 32 | Glen Afan Comprehensive School | 276715 | 189941 |
| 33 | Dyffryn Comprehensive School | 277079 | 189508 |

Table 5.29 Discrete Receptor Details – Ecological

| Ref | Name | Designation | OS Location | |
|-----|--|-------------|-------------|--------|
| | | | X | Y |
| 1 | Bishops Wood | SSSI | 259258 | 188025 |
| 2 | Blackmill Woodlands | SAC, SSSI | 292964 | 185912 |
| 3 | Blackpill, Swansea | SSSI | 262700 | 189841 |
| 4 | Bracelet Bay | SSSI | 262927 | 187120 |
| 5 | Bryn-Bach, Cefn Cribwr | SSSI | 287053 | 183095 |
| 6 | Caeau Cefn Cribwr | SSSI | 285769 | 183080 |
| 7 | Caswell Bay | SSSI | 258177 | 187248 |
| 8 | Cefn Cribwr Grasslands (Glaswelltiroedd) | SAC | 287096 | 183083 |
| 9 | Cefn Cribwr Grasslands (Glaswelltiroedd) | SAC | 285573 | 183308 |
| 10 | Cefn Cribwr Grasslands Glaswelltiroedd) | SAC | 285541 | 181873 |
| 11 | Cefn Cribwr Grasslands (Glaswelltiroedd) | SAC | 284278 | 181903 |
| 12 | Clemenstone Meadows, Wick | SSSI | 291985 | 173900 |
| 13 | Cors Crymlyn / Crymlyn Bog | SSSI | 270782 | 193803 |
| 14 | Craig Y Parciau Woodland | LNR | 289683 | 179112 |
| 15 | Crymlyn Bog / Cors Crymlyn | SAC | 271598 | 194216 |
| 16 | Crymlyn Bog And Pant Y Sais | NNR | 271598 | 194216 |
| 17 | Crymlyn Bog And Pant Y Sais | NNR | 269686 | 194539 |
| 18 | Crymlyn Bog | RAMSAR | 271598 | 194216 |
| 19 | Crymlyn Bog | RAMSAR | 269360 | 194712 |
| 20 | Crymlyn Bog | SAC, SSSI | 269426 | 194750 |
| 21 | Crymlyn Burrows | SSSI | 271446 | 192471 |
| 22 | Cwm Cyffog | SSSI | 292134 | 190365 |
| 23 | Cwm Du Woodlands | SSSI | 287589 | 190090 |
| 24 | Cwm Risca Meadow | SSSI | 287431 | 184476 |
| 25 | Cynffig/Kenfig | SSSI | 277910 | 183346 |
| 26 | Dunraven Bay | SAC | 288636 | 172752 |

Table 5.29 Discrete Receptor Details – Ecological

| Ref | Name | Designation | OS Location | |
|-----|----------------------------|-------------|-------------|--------|
| | | | X | Y |
| 27 | Eaglesbush Valley | LNR | 275526 | 195844 |
| 28 | Eaglesbush Valley | LNR | 275125 | 196161 |
| 29 | Eglwys Nunydd Reservoir | SSSI | 279205 | 185527 |
| 30 | Eglwys Nunydd Reservoir | SSSI | 279463 | 184876 |
| 31 | Ewenny And Pant Quarries | SSSI | 290474 | 176683 |
| 32 | Fforest Goch Bog | SSSI | 273840 | 202025 |
| 33 | Frog Pond Wood | LNR | 284057 | 181946 |
| 34 | Glais Moraine | SSSI | 269472 | 200466 |
| 35 | Kenfig | SAC | 279053 | 181378 |
| 36 | Kenfig / Cynffig | SAC | 284477 | 177438 |
| 37 | Kenfig / Cynffig | SAC | 285694 | 176828 |
| 38 | Kenfig / Cynffig | SAC | 277910 | 183346 |
| 39 | Kenfig Pool And Dunes | LNR | 277910 | 183346 |
| 40 | Kenfig Pool And Dunes | LNR | 279052 | 181635 |
| 41 | Kenfig Pool And Dunes | NNR | 277910 | 183346 |
| 42 | Kenfig Pool And Dunes | NNR | 279300 | 181797 |
| 43 | Kenfig | SSSI | 279053 | 181378 |
| 44 | Langland Bay (Rotherslade) | SSSI | 261289 | 187070 |
| 45 | Locks Common | LNR | 280558 | 177637 |
| 46 | Locks Common | LNR | 280363 | 178265 |
| 47 | Margam Moors | SSSI | 278076 | 185023 |
| 48 | Margam Moors | SSSI | 278284 | 184606 |
| 49 | Merthyr Mawr | SSSI | 284477 | 177438 |
| 50 | Merthyr Mawr | SSSI | 285694 | 176828 |
| 51 | Merthyr Mawr Warren | NNR | 284457 | 177228 |
| 52 | Merthyr Mawr Warren | NNR | 286004 | 176900 |
| 53 | Mumbles Hill | LNR | 262656 | 187375 |

Table 5.29 Discrete Receptor Details – Ecological

| Ref | Name | Designation | OS Location | |
|-----|--------------------------|-------------|-------------|--------|
| | | | X | Y |
| 54 | Old Castle Down | SSSI | 290300 | 175738 |
| 55 | Pant Y Sais | SSSI, LNR | 271598 | 194216 |
| 56 | Penplas Grasslands | SSSI | 263455 | 197938 |
| 57 | Penycastell, Cefn Cribwr | SSSI | 284253 | 181958 |
| 58 | Southerndown Coast | SSSI | 288425 | 172927 |
| 59 | Tremains Wood | LNR | 292114 | 180155 |
| 60 | Waun Cimla | SSSI | 284698 | 183119 |
| 61 | Waun Fawr, Cefn Cribwr | SSSI | 285669 | 181774 |