



Ministry
of Defence

Defence Infrastructure Organisation

Safeguarding Department
Statutory & Offshore

The Planning Inspectorate
3D Eagle Wing
Temple Quay House
2 The Square
Bristol
BS1 6PN

Defence Infrastructure Organisation
Kingston Road
Sutton Coldfield
West Midlands
B75 7RL

Tel: +44 (0)121 311 3847 Tel (MOD): 94421 3847

Fax: +44 (0)121 311 2218

E-mail: DIO-safeguarding-statutory@mod.gov.uk

www.mod.uk/DIO

12 March 2018

Your reference: **EN010068**

Our reference: 10042743

Dear Sir / Madam

MOD Safeguarding – SITE OUTSIDE SAFEGUARDING AREA (SOSA)

Proposal: Application by Millbrook Power Limited for an Order Granting Development Consent for a Millbrook Power Project

Location: The Rookery Pit near Stewartby, Bedfordshire

Grid Ref: 501415, 238608

Thank you for consulting Defence Infrastructure Organisation (DIO) on the above proposed development. This application relates to a site outside of Ministry of Defence (MOD) statutory safeguarding areas. We can therefore confirm that the MOD has no safeguarding objections to this proposal.

In the interests of air safety, the MOD requests that any proposed structures which are 50m or greater in height are fitted with aviation warning lighting. Any such structures should be fitted with a minimum intensity 25 candela omni-directional flashing red light or equivalent infra-red light fitted at the highest practicable point of the structure.

Whilst we have no safeguarding objections to this application, the height of the development will necessitate that aeronautical charts and mapping records are amended. Defence Infrastructure Organisation (DIO) Safeguarding therefore requests that, as a condition of any planning

permission granted, the developer must notify UK DVOF & Powerlines at the Defence Geographic Centre with the following information prior to development commencing:

- a. Precise location of the development.
- b. Date of commencement of construction.
- c. Date of completion of construction.
- d. The height above ground level of the tallest structure.
- e. The maximum extension height of any construction equipment.
- f. Details of any aviation warning lighting fitted to the structure(s)

This information can be sent by e-mail to UK DVOF & Powerlines at DVOF@mod.gov.uk or post it to:

**D-UKDVOF & Power Lines
Geospatial Air Information Team
Defence Geographic Centre
DGIA
Elmwood Avenue
Feltham
Middlesex
TW13 7AH**

I trust this adequately explains our position on this matter, however should you have any questions regarding please do not hesitate to contact me.

Yours sincerely



Debbie Baker