

THE ABERGELLI POWER PROJECT

EXPLANATION OF CHANGES MADE TO THE DRAFT DEVELOPMENT CONSENT ORDER ('DCO') SUBMITTED AT DEADLINE 4

Minor typographical amendments for clarity and consistency are not set out below. The numbering referred to below is to that in the updated draft DCO.

Article / Requirement number	Explanation of Change
Article 2 (Interpretation)	<p>The definition of “commence” has been amended to clarify that the temporary means of enclosure can only be used for activities that are excluded from commencement.</p> <p>This change has been requested by CCS and the definition of commence has now been agreed by CCS and the Applicant.</p>
Schedule 2, Requirement 2(2)	<p>An additional table has been inserted, securing the parameters of the structure crossing the DCC water main.</p> <p>The principle of this change (the inclusion of parameters) was requested by CCS – the drafting has not previously been issued to CCS.</p>
Schedule 2, Requirement 2(6)	<p>This new sub-paragraph has been inserted requiring specific approval of the design of the structure used for crossing the Water Main.</p> <p>This change has been approved by DCC and CCS, and is agreed by the Applicant.</p>
Schedule 2, Requirement 3(5)	<p>This has been amended to clarify that the review must be submitted, approved in writing by CCS and then implemented by the undertaker.</p> <p>This change has been requested by CCS and is agreed by the Applicant.</p>
Schedule 2, Requirement 5(4)	<p>This has been inserted to require permanent fencing to allow movement of the specified species, except in Work Nos. 1 and 5.</p> <p>This change has been requested by CCS and is agreed by the Applicant.</p>
Schedule 2, Requirement 6(1)	<p>This has been amended to include details of any water course crossings, which must therefore be submitted, approved and implemented as approved.</p>

Article / Requirement number	Explanation of Change
	This has been requested by CCS and is agreed by the Applicant.
Schedule 2, Requirement 8(1)	This has been amended to take into account instances where species are present.
Schedule 2, Requirement 8(5)	<p>This has been requested by CCS and is agreed by the Applicant.</p> <p>This has been inserted to clarify that no numbered works can commence if the approved surveys are more than 2 years old.</p>
Schedule 2, Requirement 8(6)	<p>This has been requested by CCS and is agreed by the Applicant.</p> <p>This has been amended to clarify that surveys that are more than 2 years old must be repeated and any repeated survey must be submitted and approved.</p>
Schedule 2, Requirement 10(2)	<p>This has been requested by CCS and is agreed by the Applicant.</p> <p>This has been amended to reflect that the survey work will contain the relevant qualifications and experience of the persons carrying out the survey, rather than it being conducted by a suitably certified and experienced ecological contractor.</p>
Schedule 2, Requirement 12(1)	<p>This has been requested by CCS and is agreed by the Applicant.</p> <p>This has been amended to permit separate discharge in relation to each numbered work.</p>
Schedule 2, Requirement 12(3)	<p>This has been requested by CCS and is agreed by the Applicant.</p> <p>This has been inserted to require a reptile method statement to be conducted by a suitably qualified and experience person.</p>
Schedule 2, Requirement 14(3)	<p>This has been requested by CCS and is agreed by the Applicant.</p> <p>This has been amended to require the report to contain the relevant qualifications and experience of the person carrying it out.</p>
Schedule 2, Requirement 17(1)(j)	<p>This has been requested by CCS and is agreed by the Applicant.</p> <p>This has been inserted to require the CEMP to include details of plant and machinery that may be operated outside the working hours.</p>

Article / Requirement number	Explanation of Change
	This has been requested by CCS and agreed by the Applicant.
Schedule 2, Requirement 27	<p>This has been inserted to secure in the DCO that the authorised development will not operate for greater than 2,250 hours per annum, nor more than 1,500 hour as a rolling 5 year average. This mirrors the Environmental Permit.</p> <p>This was committed to by the Applicant in the hearings.</p>
Schedule 2, Requirement 28(3)	<p>This has been amended to clarify that the demolition and removal of work number 1 must be in accordance with the approved implementation timetable.</p> <p>This has been requested by CCS and is agreed by the Applicant.</p>
Schedule 2, Requirement 28(4)	<p>This has been inserted to require the Applicant to apply for additional consents in accordance with the programme submitted and approved by CCS.</p> <p>This is proposed by the Applicant.</p>