



East Anglia TWO Offshore Windfarm

Appendix 6.4

Project Description East Anglia TWO and East Anglia ONE North Cumulative Project Descriptions

Environmental Statement Volume 3

Applicant: East Anglia TWO Limited
Document Reference: 6.3.6.4
SPR Reference: EA2-DWF-ENV-REP-IBR-000898_004 Rev 02
Pursuant to APFP Regulation: 5(2)(a)

Author: Royal HaskoningDHV
Date: 15th December 2020
Revision: Version 2

Applicable to
East Anglia TWO



Revision Summary				
Rev	Date	Prepared by	Checked by	Approved by
01	08/10/2019	Paolo Pizzolla	Julia Bolton	Helen Walker
02	15/12/2020	Paolo Pizzolla	Lesley Jamieson	Richard Morris

Description of Revisions			
Rev	Page	Section	Description
01	n/a	n/a	Final for Submission
02	n/a	n/a	Submitted to Examination at Deadline 3



Table of Contents

1	East Anglia TWO and East Anglia ONE North Cumulative Project Descriptions	1
1.1	Changes to Previously Submitted Document	1
1.2	Cumulative Project Descriptions	1



Appendix 6.4 is supported by the table listed below.

Table Number	Title
Table A6.1	Comparison between Scenarios for the proposed East Anglia ONE North and East Anglia TWO projects cumulative assessment



Glossary of Acronyms

CCS	Construction Consolidation Sites
CIA	Cumulative Impact Assessment
DCO	Development Consent Order
ES	Environmental Statement
HDD	Horizontal Directional Drilling
HE	Health England
LVIA	Landscape and Visual Impact Assessment
MW	Megawatt
NGET	National Grid Electricity Transmission
PEIR	Preliminary Environmental Information Report
ZTV	Zone of Theoretical Visibility



Glossary of Terminology

Applicant	East Anglia TWO Limited.
Cable sealing end compound	A compound which allows the safe transition of cables between the overhead lines and underground cables which connect to the National Grid substation.
Cable sealing end (with circuit breaker) compound	A compound (which includes a circuit breaker) which allows the safe transition of cables between the overhead lines and underground cables which connect to the National Grid substation.
Construction consolidation sites	Compounds associated with the onshore works which may include elements such as hard standings, lay down and storage areas for construction materials and equipment, areas for vehicular parking, welfare facilities, wheel washing facilities, workshop facilities and temporary fencing or other means of enclosure.
Construction, operation and maintenance platform	A fixed offshore structure required for construction, operation, and maintenance personnel and activities.
Development area	The area comprising the Onshore Development Area and the Offshore Development Area (described as the 'order limits' within the Development Consent Order).
East Anglia TWO project	The proposed project consisting of up to 75 wind turbines, up to four offshore electrical platforms, up to one construction, operation and maintenance platform, inter-array cables, platform link cables, up to one operational meteorological mast, up to two offshore export cables, fibre optic cables, landfall infrastructure, onshore cables and ducts, onshore substation, and National Grid infrastructure.
East Anglia TWO windfarm site	The offshore area within which wind turbines and offshore platforms will be located.
European site	Sites designated for nature conservation under the Habitats Directive and Birds Directive, as defined in regulation 8 of the Conservation of Habitats and Species Regulations 2017 and regulation 18 of the Conservation of Offshore Marine Habitats and Species Regulations 2017. These include candidate Special Areas of Conservation, Sites of Community Importance, Special Areas of Conservation and Special Protection Areas.
Horizontal directional drilling (HDD)	A method of cable installation where the cable is drilled beneath a feature without the need for trenching.
HDD temporary working area	Temporary compounds which will contain laydown, storage and work areas for HDD drilling works.
Inter-array cables	Offshore cables which link the wind turbines to each other and the offshore electrical platforms. These cables will include fibre optic cables.
Jointing bay	Underground structures constructed at intervals along the onshore cable route to join sections of cable and facilitate installation of the cables into the buried ducts.
Landfall	The area (from Mean Low Water Springs) where the offshore export cables would make contact with land and connect to the onshore cables.
Link boxes	Underground chambers within the onshore cable route housing electrical earthing links.

Appendix 6.4 Cumulative Project Description

15th December 2020



Meteorological mast	An offshore structure which contains metrological instruments used for wind data acquisition.
Mitigation areas	Areas captured within the onshore development area specifically for mitigating expected or anticipated impacts.
Marking buoys	Buoys to delineate spatial features / restrictions within the offshore development area.
Monitoring buoys	Buoys to monitor <i>in situ</i> condition within the windfarm, for example wave and metocean conditions.
National electricity grid	The high voltage electricity transmission network in England and Wales owned and maintained by National Grid Electricity Transmission.
National Grid infrastructure	A National Grid substation, cable sealing end compounds, cable sealing end (with circuit breaker) compound, underground cabling and National Grid overhead line realignment works to facilitate connection to the national electricity grid, all of which will be consented as part of the proposed East Anglia TWO project Development Consent Order but will be National Grid owned assets.
National Grid overhead line realignment works	Works required to upgrade the existing electricity pylons and overhead lines (including cable sealing end compounds and cable sealing end (with circuit breaker) compound) to transport electricity from the National Grid substation to the national electricity grid.
National Grid overhead line realignment works area	The proposed area for National Grid overhead line realignment works.
National Grid substation	The substation (including all of the electrical equipment within it) necessary to connect the electricity generated by the proposed East Anglia TWO project to the national electricity grid which will be owned by National Grid but is being consented as part of the proposed East Anglia TWO project Development Consent Order.
National Grid substation location	The proposed location of the National Grid substation.
Natura 2000 site	A site forming part of the network of sites made up of Special Areas of Conservation and Special Protection Areas designated respectively under the Habitats Directive and Birds Directive.
Offshore cable corridor	This is the area which will contain the offshore export cables between offshore electrical platforms and landfall.
Offshore development area	The East Anglia TWO windfarm site and offshore cable corridor (up to Mean High Water Springs).
Offshore electrical infrastructure	The transmission assets required to export generated electricity to shore. This includes inter-array cables from the wind turbines to the offshore electrical platforms, offshore electrical platforms, platform link cables and export cables from the offshore electrical platforms to the landfall.
Offshore electrical platform	A fixed structure located within the windfarm area, containing electrical equipment to aggregate the power from the wind turbines and convert it into a more suitable form for export to shore.
Offshore export cables	The cables which would bring electricity from the offshore electrical platforms to the landfall, these cables will include fibre optic cables.
Offshore infrastructure	All of the offshore infrastructure including wind turbines, platforms, and cables.
Offshore platform	A collective term for the construction, operation and maintenance platform and the offshore electrical platforms.

Appendix 6.4 Cumulative Project Description

15th December 2020



Onshore cable corridor	The corridor within which the onshore cable route will be located.
Onshore cable route	This is the construction swathe within the onshore cable corridor which would contain onshore cables as well as temporary ground required for construction which includes cable trenches, haul road and spoil storage areas.
Onshore cables	The cables which would bring electricity from landfall to the onshore substation. The onshore cable is comprised of up to six power cables (which may be laid directly within a trench, or laid in cable ducts or protective covers), up to two fibre optic cables and up to two distributed temperature sensing cables.
Onshore development area	The area in which the landfall, onshore cable corridor, onshore substation, landscaping and ecological mitigation areas, temporary construction facilities (such as access roads and construction consolidation sites), and the National Grid Infrastructure will be located.
Onshore infrastructure	The combined name for all of the onshore infrastructure associated with the proposed East Anglia TWO project from landfall to the connection to the national electricity grid.
Onshore preparation works	Activities to be undertaken prior to formal commencement of onshore construction such as pre-planting of landscaping works, archaeological investigations, environmental and engineering surveys, diversion and laying of services, and highway alterations.
Onshore substation	The East Anglia TWO substation and all of the electrical equipment within the onshore substation and connecting to the National Grid infrastructure.
Onshore substation location	The proposed location of the onshore substation for the proposed East Anglia TWO project.
Platform link cable	Electrical cable which links one or more offshore platforms. These cables will include fibre optic cables.
Safety zones	A marine area declared for the purposes of safety around a renewable energy installation or works / construction area under the Energy Act 2004.
Scour protection	Protective materials to avoid sediment being eroded away from the base of the foundations as a result of the flow of water.
Transition bay	Underground structures at the landfall that house the joints between the offshore export cables and the onshore cables.



1 East Anglia TWO and East Anglia ONE North Cumulative Project Descriptions

1.1 Changes to Previously Submitted Document

1. This Cumulative Project Description updates the previous version (APP-453) submitted with the Development Consent Order (DCO) application for the East Anglia TWO project (the Project). The updates within this document take account of comments made by the Examining Authority in their first set of written questions and a commitment made by the Applicant at Deadline 2 (see **Project Update Note** (REP2-007) which confirms that should both the East Anglia ONE North project and the East Anglia TWO project be consented and then built sequentially, when the first project goes into construction, the ducting for the second project will be installed along the whole of the onshore cable route in parallel with the installation of the onshore cables for the first project. This will also include installing ducting using Horizontal Directional Drilling (HDD) at the landfall in parallel.
2. This updated document should be read in conjunction with the **Onshore Cable Route Works Programme Clarification Note** (document reference ExA.AS-10.D3.V1) submitted at Deadline 3 which provides supplementary information on the onshore cable route construction durations.

1.2 Cumulative Project Descriptions

3. The proposed East Anglia ONE North project has submitted a separate DCO application. The two projects will share the same landfall location, onshore cable route, National Grid infrastructure; and the two onshore substations will be co-located.
4. The proposed East Anglia TWO project CIA will therefore initially consider the cumulative impact with the proposed East Anglia ONE North project against two different construction scenarios (i.e. construction of the two projects simultaneously and sequentially). The realistic worst case scenario of each impact is then carried through to the main body of the CIA assessment which considers other developments which are in close proximity to the proposed East Anglia TWO project and proposed East Anglia ONE North project.
5. The two construction scenarios assessed are:



- Scenario 1 - the proposed East Anglia TWO project and proposed East Anglia ONE North project are built simultaneously; and
 - Scenario 2 - the proposed East Anglia TWO project and the proposed East Anglia ONE North project are built sequentially (noting paragraph 1 above, that in this scenario the onshore cable ducting for the second project will be installed in parallel with the installation of the onshore cables for the first project).
6. Under scenario 2, either the proposed East Anglia TWO project or the proposed East Anglia ONE North project could be constructed first. However, there will be no difference in impact regardless of which project is constructed first. The CIA presented in this ES is presented using the intended development strategy of the proposed East Anglia TWO project being constructed first. However, in the eventuality that the proposed East Anglia ONE North project is constructed first, the impacts presented would be the same.
7. As described in **Chapter 5 EIA Methodology**, there are two co-located onshore substation locations for either the proposed East Anglia TWO project or the proposed East Anglia ONE North project. The draft DCOs for both the proposed East Anglia TWO and East Anglia ONE North projects have the flexibility for either project to use either onshore substation location. The intended development strategy is for the proposed East Anglia TWO project to use the eastern location and the proposed East Anglia ONE North project to use the western location. Therefore, this is how the 'project alone' assessments in the onshore technical chapters (Chapters 18-30) are presented. There is no difference in the details provided below regardless of which onshore substation location is used by the proposed East Anglia TWO project.
8. **Table A6.1** compares the proposed East Anglia TWO project in isolation with construction scenario 1 and construction scenario 2.



Appendix 6.4 Cumulative Project Descriptions

15th December 2020

Table A1.1 Comparison between Scenarios for the proposed East Anglia TWO and East Anglia ONE North projects Cumulative Assessment

Parameter	East Anglia TWO only	Scenario 1: East Anglia TWO and East Anglia ONE North constructed concurrently	Scenario 2: East Anglia TWO and East Anglia ONE North constructed sequentially
Landfall			
Number of cables	Up to 6 onshore cables, up to 2 fibre optic cables and up to 2 distributed temperature sensing (DTS) cables	Up to 12 onshore cables, up to 4 fibre optic cables and up to 4 DTS cables	
Number of transition bays	2	4	
Site description	Same site description (see Chapter 6 Project Description section 6.6.1)		
Temporary roads assessment (methodology)	Same methodology (see Chapter 6 Project Description section 6.6.2)		
Horizontal Directional Drilling (methodology)	Same methodology (see Chapter 6 Project Description section 6.6.3.1)		
Transition bays (methodology)	Same methodology (see Chapter 6 Project Description section 6.6.3.2)		
Construction traffic and plant (not movements) (methodology)	Same methodology (see Chapter 6 Project Description section 6.6.3.3)		
Lighting (methodology)	Same methodology (see Chapter 6 Project Description section 6.6.3.4)		
Workforce (methodology)	Same methodology (see Chapter 6 Project Description section 6.6.3.5)		
Construction Programme	Up to 12 months	Up to 20 months	Up to 16 months for the first project Up to 4 months for the second project
Commissioning and Reinstatement Programme	Up to 6 months	Up to 6 months	Up to 6 months for the first project.



Appendix 6.4 Cumulative Project Descriptions

15th December 2020

Parameter	East Anglia TWO only	Scenario 1: East Anglia TWO and East Anglia ONE North constructed concurrently	Scenario 2: East Anglia TWO and East Anglia ONE North constructed sequentially
			Up to 4 months for the second project
Operation and maintenance (methodology)	Same methodology (see <i>Chapter 6 Project Description section 6.6.4</i>)		
Decommissioning (methodology)	Same methodology (see <i>Chapter 6 Project Description section 6.6.5</i>)		
Onshore Cable Route			
Site description	Same description (see <i>Chapter 6 Project Description section 6.7.1</i>)		
Cables and ducts	Same description (see <i>Chapter 6 Project Description section 6.7.2.1</i>)		
Cable jointing and jointing pits	Two jointing bays per location, approximately 19 jointing bays locations.	Four jointing bays per location, approximately 19 jointing bays locations.	
Preparation of the onshore cable route width	<p>Construction activities would be undertaken within a temporarily fenced strip of land, known as the onshore cable route width, which would generally be no wider than 32m.</p> <p>Construction activities include the establishment of temporary infrastructure such as haul roads along the length of the onshore cable route, surface water management infrastructure; fencing and</p>	<p>Construction activities would be undertaken within a temporarily fenced strip of land, known as the onshore cable route, which would generally be no wider than 64m (total for both projects).</p> <p>Construction activities include the establishment of temporary infrastructure such as haul roads along the length of the onshore cable route, surface water management infrastructure; fencing and</p>	<p>Assuming that the proposed East Anglia TWO project is constructed first:</p> <ul style="list-style-type: none"> • Construction of East Anglia ONE North onshore cables and East Anglia TWO onshore cable ducts would include those activities listed in Scenario 1 within the working widths specified for that scenario • Completion of the East Anglia ONE North onshore cables will require temporary infrastructure



Appendix 6.4 Cumulative Project Descriptions

15th December 2020

Parameter	East Anglia TWO only	Scenario 1: East Anglia TWO and East Anglia ONE North constructed concurrently	Scenario 2: East Anglia TWO and East Anglia ONE North constructed sequentially
	<p>establishment of Construction Consolidation Sites (CCS).</p>	<p>establishment of Construction Consolidation Sites (CCS).</p> <p>Opportunities will be explored to share infrastructure between both projects (i.e. use of a common temporary haul road) to reduce the combined onshore cable route width.</p>	<p>such as haul roads to be installed (where required) to access the key work areas such as jointing bays and CCSs; and surface water management infrastructure would be established.</p> <p>Given the reduced infrastructure required for the East Anglia ONE North project in this scenario, the Applicant would seek to reduce the onshore cable route width to 16.1m where practicable (i.e. in areas where only a haul road and associated surface water management is required).</p>
<p>Installation of onshore cables</p>	<p>The onshore cables for East Anglia TWO would be installed in two parallel trenches (either laid directly within each trench or ducts would be laid for subsequent cable installation) with sand and originally excavated backfill, where suitable. In all there would be six power cables, two fibre-optic cables and two DTS cables.</p> <p>New joint bays will be constructed along the onshore cable route to allow for jointing of the onshore</p>	<p>The onshore cables for the proposed East Anglia TWO project would be installed in two parallel trenches (either laid directly within each trench or ducts would be laid for subsequent cable installation) with sand and originally excavated backfill, where suitable. In all there would be six power cables, two fibre-optic cables and two DTS cables.</p> <p>In addition, two parallel trenches would be excavated for the proposed East Anglia ONE North project in the</p>	<p>Assuming that the proposed East Anglia TWO project is constructed first:</p> <ul style="list-style-type: none"> The onshore cables for East Anglia TWO would be installed in two parallel trenches (either laid directly within each trench or ducts would be laid for subsequent cable installation) with sand and originally excavated backfill, where suitable. In all there would be six



Appendix 6.4 Cumulative Project Descriptions

15th December 2020

Parameter	East Anglia TWO only	Scenario 1: East Anglia TWO and East Anglia ONE North constructed concurrently	Scenario 2: East Anglia TWO and East Anglia ONE North constructed sequentially
	<p>cables. Joint bays will subsequently be backfilled.</p>	<p>same manner as for East Anglia TWO, to accommodate six power cables, two fibre-optic cables and two DTS cables to serve the East Anglia ONE North project.</p> <p>New joint bays will be constructed along the onshore cable route to allow for jointing of the onshore cables. Joint bays will subsequently be backfilled.</p>	<p>power cables, two fibre-optic cables and two DTS cables.</p> <ul style="list-style-type: none"> • New joint bays will be constructed along the onshore cable route to allow for jointing of the onshore cables. Joint bays will subsequently be backfilled. • In addition, two parallel trenches would be excavated for the proposed East Anglia ONE North project in the same manner as for East Anglia TWO to accommodate the onshore cable ducts for the future installation of six power cables, two fibre-optic cables and two DTS cables to serve the East Anglia ONE North project. • Completion of the East Anglia ONE North onshore cables at a later date will require duct integrity testing, repair and dewatering/cleaning (where required); new joint bays and the pulling of onshore cables through the pre-installed cable ducts. Joint bays will subsequently be backfilled.



Appendix 6.4 Cumulative Project Descriptions

15th December 2020

Parameter	East Anglia TWO only	Scenario 1: East Anglia TWO and East Anglia ONE North constructed concurrently	Scenario 2: East Anglia TWO and East Anglia ONE North constructed sequentially
Reduced working width	<p>A reduced onshore cable route width of 16.1m is proposed at woodland and important hedgerows identified within the draft DCO (classified as important due to ecological, cultural heritage or landscape criteria).</p> <p>This includes where the onshore cable route interacts with the woodland to the west of Aldeburgh Road and within the woodland to the east of Aldeburgh Road to within 40m of the Hundred River's western bank.</p>	<p>Where the East Anglia TWO project is constructed in parallel with the East Anglia ONE North project, the onshore cable route working width will be 27.1m within the woodland to the west of Aldeburgh Road and within the woodland to the east of Aldeburgh Road to within 40m of the Hundred River's western bank.</p> <p>A reduced combined onshore cable route width of 32.2m (as opposed to 64m) is proposed at important hedgerows identified within the draft DCO (classified as important due to ecological, cultural heritage or landscape criteria).</p>	<p>Assuming that the proposed East Anglia TWO project is constructed first:</p> <ul style="list-style-type: none"> • Construction of the East Anglia TWO onshore cable and the East Anglia ONE North onshore cable ducts would be undertaken in line with the reduced working width described for scenario 1. • During completion of the East Anglia ONE North onshore cables, the onshore cable route would reduce to 16.1m at woodland and important hedgerows identified within the draft DCO (classified as important due to ecological, cultural heritage or landscape criteria). This includes where the onshore cable route interacts with the woodland to the west of Aldeburgh Road and within the woodland to the east of Aldeburgh Road to within 40m of the Hundred River's western bank.



Appendix 6.4 Cumulative Project Descriptions

15th December 2020

Parameter	East Anglia TWO only	Scenario 1: East Anglia TWO and East Anglia ONE North constructed concurrently	Scenario 2: East Anglia TWO and East Anglia ONE North constructed sequentially
Leiston Aldeburgh SSSI / Sandlings SPA crossing	<p>Where the Leiston Aldeburgh SSSI / Sandlings SPA crossing is undertaken using an open-cut trenching methodology, the maximum width of the onshore cable corridor will be restricted to 16.1m within the SSSI / SPA boundary.</p> <p>For the medium scale trenchless technique crossing at the Leiston Aldeburgh SSSI / Sandlings SPA crossing point, a typical working area of approximately 70m x 90m, or variations of these dimensions, would be required at the rig site to accommodate the drilling rig itself, as well as ancillary equipment, offices, working facilities and storage of bentonite (drilling fluid), water and drill pipes. At the exit side of each crossing an area of approximately 30m x 90m would be required to encompass the exit pit and the mud storage tanks.</p>	<p>Where the Leiston Aldeburgh SSSI / Sandlings SPA crossing for both the East Anglia TWO and East Anglia ONE North projects are undertaken simultaneously using an open-cut trenching methodology, the maximum width of the combined onshore cable corridor will be restricted to 32.2m (i.e. 16.1m per project) within the SSSI / SPA boundary.</p> <p>For the medium scale trenchless technique crossing at the Leiston Aldeburgh SSSI / Sandlings SPA crossing, a typical working area of approximately 70m x 175m, or variations of these dimensions, would be required at the rig site to accommodate the drilling rig itself, as well as ancillary equipment, offices, working facilities and storage of bentonite (drilling fluid), water and drill pipes. At the exit side of each crossing an area of approximately 30m x 175m would be required to encompass the exit pit and the mud storage tanks.</p>	<p>Assuming that the proposed East Anglia TWO project is constructed first:</p> <ul style="list-style-type: none"> Construction of East Anglia TWO onshore cable and East Anglia ONE North onshore cable ducts would be undertaken as described for scenario 1. During completion of the East Anglia ONE North onshore cable route at a later date, the East Anglia ONE North cables would be pulled through ducts, between either the footprint of the original trenchless technique entry/exit pits (located outside the SPA/SSSI), or between the project's jointing bays.
Pre-construction works (methodology)	Same methodology (see Chapter 6 Project Description section 6.7.3.2)		



Appendix 6.4 Cumulative Project Descriptions

15th December 2020

Parameter	East Anglia TWO only	Scenario 1: East Anglia TWO and East Anglia ONE North constructed concurrently	Scenario 2: East Anglia TWO and East Anglia ONE North constructed sequentially
Topsoil stripping (methodology)	Same methodology (see Chapter 6 Project Description section 6.7.3.5)		
Temporary roads (methodology)	Same methodology (see Chapter 6 Project Description section 6.7.3.6)		
Cable delivery (methodology)	Same methodology (see Chapter 6 Project Description section 6.7.3.8)		
Cable pulling and installation (methodology)	Same methodology (see Chapter 6 Project Description section 6.7.3.9)		
Temporary works (methodology)	Same methodology (see Chapter 6 Project Description section 6.7.3.11)		
Construction traffic and plant	An initial assessment of the number of vehicle movements required (for the delivery of equipment, and personnel) associated with the construction of the cable route per separate construction sections has been estimated at approximately an average of 65 two-way movements per day for Section 1, 69 two-way movements per day for Section 2, 53 two-way movements per day for Section 3, and 105 two-way movements per day for Section 4.	For construction traffic and plant, an initial assessment of the number of vehicle movements required (for the delivery of equipment, and personnel) associated with the construction of the cable route per separate construction sections has been estimated at approximately an average of 78 two-way movements per day for Section 1, 80 two-way movements per day for Section 2, 64 two-way movements per day for Section 3, and 119 two-way movements per day for Section 4.	Assuming East Anglia TWO is constructed first: <ul style="list-style-type: none"> East Anglia TWO construction together with the installation of the East Anglia ONE North onshore cable ducts would require fewer movements than scenario 1 (as jointing bays and cables for East Anglia ONE North will not be installed at that time) East Anglia ONE North would require fewer movements than for the East Anglia TWO only scenario, however until the location of jointing bays is known the extent of any reduction in haul road required cannot be ascertained and therefore the reduction of materials required (and associated reduction in



Appendix 6.4 Cumulative Project Descriptions

15th December 2020

Parameter	East Anglia TWO only	Scenario 1: East Anglia TWO and East Anglia ONE North constructed concurrently	Scenario 2: East Anglia TWO and East Anglia ONE North constructed sequentially
			<p>movements) are not yet known. Notwithstanding, it is anticipated there will be a reduction in haul road length with an associated reduction in HGV movements (relative to East Anglia TWO only). Note that for East Anglia THREE the length of haul road required for cable installation (i.e. pulling cables through ducts installed by East Anglia ONE) will be approximately half of the total length of the offshore cable corridor</p> <ul style="list-style-type: none"> The cumulative assessment remains valid as the cumulative case was determined by the daily worst case peak construction traffic movements, derived from Scenario 1 Projects' parameters. This worst case traffic scenario is not changed by the introduction of a parallel duct installation scenario.
Lighting (methodology)	Same methodology (see Chapter 6 Project Description section 6.7.3.13)		
Workforce	The total number of construction employees required has been estimated at approximately an average of 22 construction personnel	Construction workforce would match that as described in section 6.9.3.13 with the exception that the total number of construction employees	Assuming East Anglia TWO is constructed first:



Appendix 6.4 Cumulative Project Descriptions

15th December 2020

Parameter	East Anglia TWO only	Scenario 1: East Anglia TWO and East Anglia ONE North constructed concurrently	Scenario 2: East Anglia TWO and East Anglia ONE North constructed sequentially
	associated with Section 1 of the onshore cable route, 24 personnel per day for Section 2, 19 personnel per day for Section 3, and 40 personnel per day for Section 4.	required has been estimated at approximately an average of 26 construction personnel associated with Section 1 of the onshore cable route, 27 personnel per day for Section 2, 23 personnel per day for Section 3, and 43 personnel per day for Section 4. The estimated programme would remain as outlined in section 6.9.3.13	<ul style="list-style-type: none"> The total number of construction employees required for East Anglia TWO construction with installation of East Anglia ONE North cable ducts would not exceed those required under scenario 1. The total number of construction employees required for East Anglia ONE North cable installation would not exceed those required for East Anglia TWO only scenario.
Construction Programme	Up to 24 months	Up to 24 months	Up to 24 months for the first project. Up to 12 months for the second project
Commissioning and Reinstatement Programme	Up to 6 months	Up to 6 months	Up to 6 months for the first project. Up to 6 months for the second project
Operation and maintenance (methodology)	Same methodology (see Chapter 6 Project Description section 6.6.4)		
Decommissioning (methodology)	Same methodology (see Chapter 6 Project Description section 6.6.5)		
Substation(s)			



Appendix 6.4 Cumulative Project Descriptions

15th December 2020

Parameter	East Anglia TWO only	Scenario 1: East Anglia TWO and East Anglia ONE North constructed concurrently	Scenario 2: East Anglia TWO and East Anglia ONE North constructed sequentially
Onshore substation infrastructure	The proposed East Anglia TWO project onshore substation would be located within a single compound, with up to maximum dimensions of 170m (width) x 190m (length) x up to 14m (height) for external electrical equipment, or up to 14m (height) for the tallest building.	The proposed East Anglia ONE North onshore substation is a duplication of the proposed East Anglia TWO onshore substation that would be located immediately adjacent to the East Anglia TWO onshore substation.	
National Grid substation infrastructure	The National Grid substation would be located within a single compound, with up to maximum dimensions of 145m (width) x 310m (length) x up to 6m (height) for the tallest Air Insulates Switchgear (AIS) building.	Only one National Grid substation is required for the proposed East Anglia TWO and East Anglia ONE North projects. The two SPR onshore substations would share the National Grid infrastructure and connection to the overhead lines (as per Chapter 6 Project Description section 6.7.9).	
Site establishment and laydown	East Anglia TWO: up to 17,100m ² in area plus the 190m x 170m footprint of the onshore substation.	East Anglia TWO and East Anglia ONE North: up to maximum of 2 CCS of 17,100m ² in area plus the 190m x 170m footprint of the onshore substations.	
Pre-construction activities (methodology)	Same methodology (see Chapter 6 Project Description section 6.7.8.2)		
Temporary fencing (methodology)	Same methodology (see Chapter 6 Project Description section 6.7.8.4)		
Grading and earthworks (methodology)	Same methodology (see Chapter 6 Project Description section 6.7.8.6)		



Appendix 6.4 Cumulative Project Descriptions

15th December 2020

Parameter	East Anglia TWO only	Scenario 1: East Anglia TWO and East Anglia ONE North constructed concurrently	Scenario 2: East Anglia TWO and East Anglia ONE North constructed sequentially
Surface water drainage (methodology)	Same methodology (see Chapter 6 Project Description section 6.7.8.7)		
Foul drainage (methodology)	Same methodology (see Chapter 6 Project Description section 6.7.8.8)		
Foundations (methodology)	Same methodology (see Chapter 6 Project Description section 6.7.8.10)		
Buildings (methodology)	Same methodology (see Chapter 6 Project Description section 6.7.8.9)		
Installation works (methodology)	Same methodology (see Chapter 6 Project Description section 6.7.8.12)		
Lighting (methodology)	Same methodology (see Chapter 6 Project Description section 6.7.8.14)		
Workforce (methodology)	Same methodology (see Chapter 6 Project Description section 6.7.8.15)		
Construction Programme	<p>For an outline programme for the construction of the onshore substation see Chapter 6 Project Description section 6.7.9.3.</p> <p>For National Grid substation and overhead line see Chapter 6 Project Description section 6.9.4 and section 6.9.5.</p>	<p>For an outline programme for the construction of the onshore substation see Chapter 6 Project Description section 6.9.3.</p> <p>For National Grid substation and overhead line see Chapter 6 Project Description section 6.9.4 and section 6.9.5.</p>	<p>The outline programme for the construction of the proposed East Anglia TWO project onshore substation matches that as described in Chapter 6 Project Description section 6.9.3.</p> <p>The outline programme for the construction of the proposed East Anglia ONE North project onshore substation would be duplicated at a different date. The ES assessment assumes full reinstatement of the first project before construction of the second project begins.</p> <p>For National Grid substation and overhead line see Chapter 6 Project</p>



Appendix 6.4 Cumulative Project Descriptions

15th December 2020

Parameter	East Anglia TWO only	Scenario 1: East Anglia TWO and East Anglia ONE North constructed concurrently	Scenario 2: East Anglia TWO and East Anglia ONE North constructed sequentially
			Description section 6.9.4 and section 6.9.5.
Operation	Same methodology (see Chapter 6 Project Description section 6.7.11)		
Decommissioning	Same methodology (see Chapter 6 Project Description section 6.7.12)		