



The Planning Act 2008

East Anglia One North (EA1N) and East Anglia Two (EA2) Offshore Wind Farms

Planning Inspectorate Reference: EA1N – EN010077, EA2 – EN010078

Deadline 12 – 28 June 2021

**Comments of Suffolk County Council as Local Highways Authority**

**1. Comments on responses to ExQ3**

1.1 Not applicable.

**2. Comments on the amendments to the previously issued RIES (if required)**

2.1 Not applicable.

**3. Comments on any additional information/submissions received at D11**

**Outline Code of Construction Practice (REP11-016)**

3.1 No comments on revisions.

**Outline Construction Traffic Management Plan (REP11-018)**

3.2 No comments on revisions.

**Outline Access Management Plan (REP11-019)**

3.3 No comments on revisions.

**Outline Travel Plan (REP11-021)**

3.4 No comments on revisions.

**Outline Port Construction Traffic Management and Travel Plan (REP11-023)**

3.5 No comments on revisions.

**Outline Operational Drainage Management Plan (AS-126)**

3.6 The LHA has requested that the nominal depth of cover between the pipes discharging water from the sub station site to the Friston Watercourse and the surface of Church Road are shown on drawing ED11892-GE-3016 and described in paragraph 5.3.3 of the Outline Operational Drainage Management Plan. During discussions with the applicant the LHA has been advised that the pipes are approximately 300mm below existing road surface which would be acceptable to the LHA subject to agreement of suitable detail design. We understand this position is also stated in LA-10.44 in the Statement of Common Ground Version 5 to be submitted at deadline 12.

**4. Responses to any further information requested by the ExAs for this deadline**

4.1 Not applicable.