



Deadline 7: Applicant's Response to the Examining Authority's Further Written Questions (ExQ4)

Appendix B – FM1 R1 Accreditation 2018 and FM1 R1 Revalidation 2019

Wheelabrator Kemsley (K3 Generating Station) and Wheelabrator Kemsley North (WKN) Waste to Energy Facility Development Consent Order

PINS Ref: EN010083

Document 15.2

August 2020 – Deadline 7



Mr. Matt Hardy
Ferrybridge MFE Limited
Ferrybridge Multifuel 1
Kirkshaw Lane
Knottingley
West Yorkshire
WF11 8DX

Our ref: EPR/SP3239FU/R1

Date: 16 February 2018

Dear Mr. Hardy

Confirmation of R1 Status – Ferrybridge Multifuel 1, Ferrybridge MFE Limited, Ferrybridge, Wakefield.

Thank you for your submission of your 'R1' assessment in relation to operation of the above site.

I am satisfied that the data provided confirms that the plant is capable of operation with an R1 energy efficiency factor greater than or equal to 0.65.

Accordingly, this letter certifies that the plant qualifies as an R1 Recovery Operation within the meaning of Annex II to Directive 2008/98/EC on Waste.

I would like to remind you:

- To contact us in the event of any changes in the operation of the plant that might result in a reduction of plant efficiency below 0.65
- That operational plants need to submit an updated version of the assessment spreadsheet by end January each year, covering plant performance over the preceding calendar year, in order that we can revalidate the R1 certification.

Yours faithfully,



Jessica Brown
Regulatory Officer – EPR Installations

Direct dial: 02030253942
Email: jessica.brown@environment-agency.gov.uk

Mr. Matt Hardy
Ferrybridge MFE Limited
Ferrybridge Multifuel 1
Kirkshaw Lane
Knottingley
West Yorkshire
WF11 8DX

Our ref: EPR/SP3239FU/R1

Date: 28 January 2019

Dear Mr. Hardy

REVALIDATION OF R1 CERTIFICATION

Permit reference: EPR/SP3239FU
Operator: Ferrybridge MFE Limited
Facility: Ferrybridge Multifuel 1

Thank you for submitting for revalidation, an updated version of the R1 application spreadsheet, covering performance for 2018. Based on the information provided and presented in the spreadsheet, we have concluded that Ferrybridge Multifuel 1 is achieving an R1 energy efficiency factor above 0.65.

We can therefore confirm that this facility continues to be classified as a recovery operation under Annex II of Directive 2008/98/EC on Waste based on operational data.

We remind you that you will need to submit an updated version of the spreadsheet by the end of January each year, covering performance over the last calendar year, so we can revalidate the R1 certification.

Yours sincerely,



Jessica Rollitt
Regulatory Officer – EPR Installations

Direct dial: 02030253942
Email: jessica.rollitt@environment-agency.gov.uk