



SECTION A-A

SUBSTATION MINIMUM ELECTRICAL CLEARANCES IN ACCORDANCE WITH TS 2.1

NOMINAL SYSTEM VOLTAGE (rms)	400kV
PHASE TO EARTH CLEARANCE (PE)	2.8m
PHASE TO PHASE CLEARANCE (PP)	3.6m
HORIZONTAL DESIGN CLEARANCE FOR SAFETY (HSC)	4.6m
VERTICAL DESIGN CLEARANCE FOR SAFETY (VSC)	5.5m
INSULATION HEIGHT CLEARANCE (IHC)	2.4m
SAFETY DISTANCE (SD)	3.1m

NOTE:
Document Reference: EN010106/APP/6.3
APFP Regulation: 5(2)(a)

Purpose of Issue
FOR DCO SUBMISSION

Client
SUNNICA LTD



Drawing Title
FIGURE 3-28A
SUNNICA WEST SITE A
SUBSTATION ELEVATION -
400KV SOLUTION (ILLUSTRATIVE)

Drawn LL	Checked DW	Approved NC	Date 04/07/2022
-------------	---------------	----------------	--------------------

AECOM Internal Project No. 60589004 Scale @ A3 NOT TO SCALE

THIS DOCUMENT HAS BEEN PREPARED PURSUANT TO AND SUBJECT TO THE TERMS OF AECOM'S APPOINTMENT BY ITS CLIENT. AECOM ACCEPTS NO LIABILITY FOR ANY USE OF THIS DOCUMENT OTHER THAN BY ITS ORIGINAL CLIENT OR FOLLOWING AECOM'S EXPRESS AGREEMENT TO SUCH USE AND ONLY FOR THE PURPOSES FOR WHICH IT WAS PREPARED AND PROVIDED.

AECOM
Unit 1 Welbrook Court
Gilton
Cambridge CB3 0NA
United Kingdom
Telephone (01223) 488000



Drawing Number 60589004_ES_SD_028A	Rev 0
---------------------------------------	----------