

Suffolk County Council (20031377)

SCC Responses to Deadline 4 Submissions in relation to Flood Risk

Sunnica Energy Farm (EN010106)

Deadline 5

13 January 2023

This document sets out the comments on the Applicant's Deadline 4 (D4) submissions relating to Flood Risk by Suffolk County Council (**SCC**). The tables below set out the document in question that the Council is commenting on, together with the relevant paragraph or reference number.

8.14 Statement of Common Ground with the Environment Agency - Rev: 01 [REP4-016]

Topic	Paragraph Number	Council's Comment
Flood Risk & Drainage	N/A	SCC LLFA note that all matters are listed as "agreed" and there are no matters currently "under discussion" or "not agreed".

8.66 Appendix 9C: Flood Risk Assessment Addendum - Parts 1 and 2 [REP4-040 and REP4-041]

Topic	Paragraph Number	Council's Comment
Flood Risk	3.1.7	SCC LLFA agrees with updated definition of flood risk as per national updates to guidance.
Drainage Design – Greenfield Runoff Calculations	5.1.10	SCC LLFA supports the change in relation to the of use EH data over FEH rainfall rata as it has been proven to be more conservative for modelling larger scale catchments.
Conclusion	10.1	SCC LLFA recommends this section includes reference to pluvial/surface water flooding as the summary only details the risk presented by fluvial/river flooding to the scheme.
Flood risk maps	Annex B – Parameter Plans	SCC LLFA requests that maps are included to demonstrate the extent of pluvial flood risk areas in relation to the layout of the site as has been provided for fluvial flood risk mapping.