

Submissions Received After the Close of the Examination

EN010107

South Humber Bank Energy Centre

Last updated: 10 August 2021

Date Examination Closed: 10 May 2021

Date of Recommendation Report: 10 August 2021

Date of Decision: 10 November 2021

Submissions made after the Examination closed			
Number	Date submission received by PINS	Description of submission	Date submission forwarded to SoS
1.	13 May 2021	Ministry of Defence response to Rule 17 of 23 April 2021	10 August 2021
2.	6 August 2021	Northern Powergrid Plc update on negotiations	10 August 2021

**1. Ministry of Defence response to Rule 17 of 23 April
2021**



Ministry
of Defence

Defence
Infrastructure
Organisation

South Humber Bank Planning Team
The Planning Inspectorate
National Infrastructure Planning
Temple Quay House
2 The Square
Bristol, BS1 6PN

Safeguarding Department
Statutory & Offshore
Defence Infrastructure Organisation
Kingston Road
Sutton Coldfield
West Midlands
B75 7RL

[REDACTED]
[REDACTED]
[REDACTED]

www.mod.uk/DIO

13 May 2021

Your reference: EN010107
Our reference: DIO/SUT/10047103_Rev3/2021

Dear Sir/Madam

MOD Safeguarding – SOSA (Site Outside of statutory Safeguarding Areas)

Proposal: The construction and operation of an energy from waste plant of up to 95 megawatts gross capacity and associated development including an electrical connection, landscaping and access. Variations to the Examination Timetable resulting from the Examining Authority's (ExA) requests for further information from the Applicant, National Grid and North East Lincolnshire Council (NELC) under Rule 17 of the Infrastructure Planning (Examination Procedures) Rules. The Examination Timetable has been amended as a consequence of the submissions made at Deadline (D) 6 (23 April 2021) and the need of the Examining Authority (ExA) to seek further information from the Applicant, National Grid and NELC.

Location: South Marsh Road Stallingborough

Grid Ref's: E 522768 N 413415

Thank you for consulting Defence Infrastructure Organisation (DIO) on the above proposed development. This application relates to a site outside of Ministry of Defence (MOD) statutory safeguarding areas (SOSA). We can therefore confirm that the MOD has no safeguarding objections to this proposal. In line with our previous recommendations regarding this consultation, we remind that the following is our position with regard to this development.

In the interests of air safety, the MOD requests that the structure is fitted with aviation warning lighting. The mast should be fitted with a minimum intensity 25 candela omni directional flashing red light or equivalent infra-red light fitted at the highest practicable point of the structure.

Whilst we have no safeguarding objections to this application, the height of the development will necessitate that aeronautical charts and mapping records are amended. Defence Infrastructure Organisation (DIO) Safeguarding therefore requests that, as a condition of any planning permission granted, the developer must notify UK DVOF & Powerlines at the Defence Geographic Centre with the following information prior to development commencing:

Precise location of development.

Date of commencement of construction.

Date of completion of construction.

The height above ground level of the tallest structure.

The maximum extension height of any construction equipment.

Details of aviation warning lighting fitted to the structure(s)

This information can be sent by e-mail to the Defence Geographic Centre at: [REDACTED] or post it to:



I trust this is clear however should you have any questions please do not hesitate to contact me.

Yours sincerely



Mr Chris Waldron
Safeguarding Officer

2. Northern Powergrid Plc update on negotiations

The Examining Authority
The National Infrastructure Planning Unit

Contact: Elaine Field

[REDACTED]
[REDACTED]
Our ref: W22559-2171
Your ref:

By email:
southhumberbank@planninginspectorate.gov.uk

6 August 2021

Dear Sirs

Application by EP Waste Management Limited for an Order Granting Development Consent for the South Humber Bank Energy Centre

We write in relation to the above mentioned DCO Application to which our client Northern Powergrid Plc ("NPG"), have been in consultation with EP Waste Management Limited ("EPW") regarding the protective provisions relating to NPG's apparatus located within the proposed development site. Our client wrote to EPW on 24 March 2020 to reserve their right to object to the DCO and have been engaging with EPW in relation to the required protected provisions.

We are instructed to write to the Examining Authority to provide an update on those negotiations. NPG and EPW are still in the process of agreeing appropriate protective provisions, albeit it is anticipated that these should be completed soon. However, for the avoidance of doubt, NPG would like to advise the Examining Authority that these discussions are still ongoing. NPG have been engaging on the protective provisions with EPW and will continue to work with them in a collaborative manner in order to seek to resolve the outstanding issues as soon as possible. Should agreement be reached then we will notify the Examining Authority and the Secretary of State.

To this affect, we would request that NPG be granted additional time to continue to seek to engage with EPW and to reach agreement on these outstanding points. We are conscious that the examination has closed and subsequently request that these representations are taken into account prior to the DCO being determined.

Yours faithfully

Weightmans LLP