


Medworth Energy from Waste Combined Heat and Power Facility

PINS ref. EN010110
Document Reference: 9.24
March 2023



Technical Note:

R1 Calculation

**We inspire
with energy.**



Contents

1.	R1 Calculation	3
	Overview	3
	Guidance	3
	R1 Calculation	4

Appendix A: Environment Agency Guidance R1 Calculation



1. R1 Calculation

Overview

1.1.1 To comply with the revised Waste Framework Directive (rWFD) in the UK, an applicant is required to demonstrate their proposed development is capable of achieving an R1 value in excess of 0.65. Therefore, rather than being classified as an inefficient “disposal” operation it is an efficient energy “recovery” operation. To qualify as an R1 recovery operation, the plant must:

- Have or will have an environmental permit;
- Be capable of treating mixed municipal solid waste, including refuse derived fuel or solid recovered fuel if the fuel’s been made from mixed municipal solid waste; and
- Not be a co-incinerator

1.1.2 The Environment Agency is the certification body for R1 status in England. An application for certification of R1 status has been made at the same time as the application made for an Environmental Permit and details of the Proposed Development’s initial R1 calculation accompany the Applicant’s application for an Environmental Permit. The R1 design calculation for the EfW CHP Facility is 0.81.

1.1.3 During commissioning of the EfW CHP Facility, the Applicant will undertake a re-assessment of the R1 calculation to ensure the EfW CHP Facility does/will continue to achieve R1 status. The R1 status will also be required to be re-validated on an annual basis using actual energy inputs and outputs.

1.1.4 The R1 status of the EfW CHP facility will be validated by the Environment Agency as part of annual reporting under the EfW CHP Facility’s Environmental Permit.

Guidance

1.1.5 To calculate the R1 value, the Applicant used the Environment Agency’s guidance:

- *Waste incinerator plant: apply for R1 status (Aug 2021).*

1.1.6 As part of this guidance, the Environment Agency has developed a spreadsheet pro-forma that provides a calculation of the R1 value using the method in the European Commission’s “*Guidelines on the interpretation of the R1 energy efficiency formula for incineration facilities dedicated to the processing of municipal solid waste according to Annex II of Directive 2008/98/EC on waste*”. The Environment Agency’s pro-forma was used to calculate the R1 value for the EfW CHP Facility.

1.1.7 Commission Directive (EU) 2015/1127 establishes that, to achieve a level playing field, it is reasonable to apply a climate correction factor (CCF) to the R1 formula based on local climatic conditions. For new installations, the CCF ranges between a value of 1 and 1.12 dependent on the local heating degree days with a formula for the calculation of the CCF provided in the Annex of Commission Directive (EU) 2015/1127.



4 Technical Note: R1 Calculation

R1 Calculation


- 1.1.8 The EfW CHP Facility has a design R1 value of 0.81 (0.90 with application of climate change correction factor based on regional heating degree day analysis) at design load conditions (DLC) without the export of heat, ensuring that the installation can be classed as an energy recovery operation irrespective of the level of heat export. **Appendix A** provides a CHP-R assessment and details of the R1 calculation. Operational data will be collected during commissioning and each subsequent year, with a re-assessment of the R1 calculation made to ensure the EfW CHP Facility does/can continue to achieve R1 status.

1.2 Conclusion

- 1.2.1 The Proposed development will be designed to achieve an R1 value of 0.81, therefore be classified as a waste “recovery” operation.



Appendix A Environment Agency Guidance R1 Calculation

	A	B	C	D	E	F	G	H	I
1	PROFORMA FOR DETERMINING ENERGY EFFICIENCY USING R1								
2	Site name, address and grid reference	Medworth Energy from waste Combined Heat and Power Facility, Alorges Way, Wisbech, Cambridgeshire, PE13 2TQ	EPR Permit reference (if known)	EPR/VP3705BL/A001					
3	Operator name	Medworth CHP Ltd	Application fee (£)	Included with permit application fee					
4	Details of who to contact if we have any queries regarding this form	Per the contact details provided on form Part A							
5	What data has been used in the application? →		Design data						
6	Indicative R1 factor (subject to confirmation)	0.81	Quantity in reporting year	Units	U _c	Properties (Average over reporting year)	Units	Note which parameters that have been estimated	Reference to Supporting information
7	Climate change correction factor (optional)	1.12							
8	R1 after CCF adjustment	0.90							
9	1. Gross electricity meter (Electricity produced at turbine)		480000	MWh					
10	2. Electricity exported - Net input/output meter		440000	MWh					
11	3. Electricity imported - Net input/output meter		352.72	MWh					
12	4. Other fuel inputs								
13		4.1 Light fuel oil	1622850	litres		0.85	kg/l		
14						42600	kJ/kg		Digest of UK Energy St
15		4.2 Natural gas		Nm ³		34200	kJ/Nm ³		
16									
17		4.3 LPG		Nm ³			kg/Nm ³		
18							kJ/kg		
19		4.4 Other fuels similar to light fuel oil		litres			kg/l		
20							kJ/kg		
21	5. Primary combustion air (as supplied to furnace)		2169002123	m ³		0.942	kg/Nm ³		
22						99.97	°C		
23						75.7197	kJ/kg		
24	6. Secondary combustion air (as supplied to furnace)		971588133	m ³		1.146	kg/Nm ³		
25						33.72	°C		
26						8.8072	kJ/kg		
27	7. Recycled flue gas (as supplied to furnace)			m ³			kg/Nm ³		
28							°C		
29							0	kJ/kg	
30	8. Heat exported outside R1 boundary								
31		8.1 steam exported		tonnes			°C		
32							kPa		
33							kJ/kg		
34		condensate returned		tonnes			°C		
35							kPa		
36							kJ/kg		
37		8.2 hot water exported		tonnes			°C		
38							kPa		
39							kJ/kg		
40		hot water returned		tonnes			°C		
41							kPa		
42							kJ/kg		
43									
44	9. Internal steam use								
45		9.1 for soot blowing (no backflow)		tonnes			°C		
46							kPa		
47							kJ/kg		
48		9.2 for steam driven devices		tonnes			°C		
49							kPa		
50							kJ/kg		
51		backflow as steam		tonnes			°C		
52							kPa		
53							kJ/kg		
54		9.3 for trace heating		tonnes			°C		
55							kPa		
56							kJ/kg		
57		backflow as condensate		tonnes			°C		
58							kPa		
59							kJ/kg		
60		9.4 for re-heating flue gas		tonnes			°C		
61							kPa		
62							kJ/kg		
63		backflow as condensate		tonnes			°C		
64							kPa		
65							kJ/kg		
66		9.5 for concentration processes		tonnes			°C		
67							kPa		
68							kJ/kg		
69		backflow as condensate		tonnes			°C		

