

**CONDITIONS FOR DEVELOPMENT NEAR WATER MAINS**

Location: **Awel y Môr Offshore Wind Farm project, Denbighshire**

Date: **18/10/2022**

The development of the site with our water main located as shown on the attached plan will involve certain conditions which must be strictly adhered to. These are:-

1. No structure is to be sited within a minimum distance from the centre line of the pipe. The pipeline must therefore be located and marked up accurately at an early stage so that the Developer or others understand clearly the limits to which they are confined with respect to the Company's apparatus. Arrangements can be made for Company staff to trace and peg out such water mains on request of the Developer.  
No part of any building will be permitted within **3 metres** either side of the centreline of the 4" public watermain (grid reference: 303547.61, 382435.29) - water plan 1  
No part of any building will be permitted within **4 metres** either side of the centreline of the 300mm public watermain (grid reference: 302558.11, 379205.47) water plan 2  
No part of any building will be permitted within **4.5 metres** either side of the centreline of the 300mm public watermain (grid reference: 302208.79, 378853.53) - water plan 3  
No part of any building will be permitted within **4.5 metres** either side of the centreline of the 450mm public watermain (grid reference: 302169.68, 378846.37) - water plan 3  
No part of any building will be permitted within **4.5 metres** either side of the centreline of the 15" public abandoned watermain (grid reference: 302169.68, 378846.37) - water plan 3  
No part of any building will be permitted within **3 metres** either side of the centreline of the 110mm public watermain (grid reference: 301350.15, 377733.45) - water plan 4
2. Adequate precautions are to be taken to ensure the protection of the water main during the course of site development.
3. If heavy earthmoving machinery is to be employed, then the routes to be used in moving plant around the site should be clearly indicated. Suitable ramps or other protection will need to be provided to protect the water main from heavy plant.

4. The water main is to be kept free from all temporary buildings, building material and spoil heaps etc.
5. The existing ground cover on the water main should not be increased or decreased.
7. All chambers, covers, marker posts etc. are to be preserved in their present position.
8. Access to the Company's apparatus must be maintained at all times for inspection and maintenance purposes and must not be restricted in any way as a result of the development.
9. No work is to be carried out before this Company has approved the final plans and sections.

These are general conditions only and where appropriate, will be applied in conjunction with specific terms and conditions provided with our quotation and other associated documentation relating to this development.