

Operational Data

Plant Size	725,000	tonnes pa	80	MWth	73	MWe
No. of combustion lines	2	No. of Turbines:		1		

Waste types received	Unit	Q1	Q2	Q3	Q4	Year Total	%	
Household / Local Authority	tonnes					-	-	
Commercial & Industrial						-	-	
Hazardous						-	-	
Clinical						-	-	
Waste wood (biomass)						-	-	
Refuse derived fuel		168,606	150,765	149,463	130,534	599,367	100.0%	
Solid recovered fuel						-	-	
Other [Please specify]						-	-	
Other [Please specify]						-	-	
Other [Please specify]						-	-	
Total waste received			168,606	150,765	149,463	130,534	599,367	100.0%
Rejected Waste							-	-
Waste transferred out						-	-	
Total waste combusted		168,606	150,765	149,463	130,534	599,367	100.0%	

Energy Usage / Export	Unit	Q1	Q2	Q3	Q4	Year Total	KWh/te
Power Generated	MWh	170,953	143,573	135,251	1,993	451,769	754
Power Exported		154,668	129,923	122,117	1,790	408,497	682
Power Used on site		16,285	13,650	13,135	203	43,273	72
Power Imported		-			12,619	12,619	21
Parasitic Load	%	9.5%	9.5%	9.7%	87.8%	12.0%	
Thermal Energy Produced	GWh					-	-
Thermal Energy Exported						-	-
R1 value					0.89	Design / Operational / n/a	

Waste Disposal & Recovery	Unit	Q1	Q2	Q3	Q4	Year Total	% inputs	
APC Residues - produced	tonnes	7,410	5,966	6,313	5,307	24,996	4.2%	
IBA - produced		32,500	30,616	31,324	19,066	113,506	18.9%	
Metals recycling		1,261	915	812	789	3,777	0.6%	
Waste wood		2	0	1	2	4	0.0%	
Building rubble		-	4	-	-	4	0.0%	
Dry mixed recyclables		1	1	1	1	4	0.0%	
General waste		2	6	13	23	44	0.0%	
APCr contaminated materials		2		4		5	0.0%	
Glycol waste		3				3	0.0%	
Oil contaminated solid waste		3		2		5	0.0%	
WEEE		0				0	0.0%	
Spent aerosols		0				0	0.0%	
Waste hydraulic oil				2	1		3	0.0%
Spent ion exchange resin					1		1	0.0%
Fluorescent tubes					0		0	0.0%
Waste process water					537	1,213	1,749	0.3%
Sewage					29	13	42	0.0%
Septic tank sludge					20		20	0.0%
Other			-	-	-	-	-	-

Raw Material Usage	Unit	Q1	Q2	Q3	Q4	Year Total	kg or Ltr /te
--------------------	------	----	----	----	----	------------	---------------

Mains Water	m ³	21,593	18,092	26,175	30,043	95,903	160.01
Other Water	m ³	31,500	23,382	22,072	16,427	93,381	155.80
Ammonia / Urea	kgs	10,288	8,408	5,609	3,577	27,882	46.52
Activated Carbon	kgs	65,006	59,400	60,700	55,700	240,806	401.77
Lime / hydrated lime	kgs	2,869,000	2,647,000	2,674,000	2,286,000	10,476,000	17,478.43
Fuel oil	ltrs	56,099	192,281	263,082	659,168	1,170,630	1,953.11
Gas	cf	-	-	-	-	-	-
Other		-	-	-	-	-	-

Summary of Hours		Line/Unit	Q1	Q2	Q3	Q4	Year Total	
Hours of waste combustion, total		2	2,180	2,177	1,767	2,160	8,284	94.6%
Hours of waste combustion, total		2	2,176	2,180	1,970	2,040	8,366	95.5%
Hours of turbine operations, total		1	2,160	2,143	1,781	29	6,113	69.8%
Hours of heat / steam export			-	-	-	-	-	n/a
Abnormal Events	qty.		2	-	6	4	12	yes
Abnormal operation	hours		2	-	15	3	19	0.21%
Permit Breaches	qty.		-	-	-	-	-	no

2020 Annual Reporting Performance Form 1

Permit EPR/SP3239FU

Operator: 0

Facility: Ferrybridge Multifuel 1

Form: Performance 1

Reporting Period from:

01 January 2020

to:

31 December 2020

2020 Annual Reporting of Waste Disposal and Recovery

Waste Description	Disposal Route(s)	Disposal Tonnes	Recovery Tonnes	% / tonne of waste incinerated
1) Hazardous Wastes				
APC Residues	D9/R5	7,441.4	17,599.6	4.2%
APCr contaminated materials	D14	5.0	0.0	0.0%
Waste Oil	R13	0.0	3.0	0.0%
Oil contaminated materials	D14	5.0	0.0	0.0%
WEEE	R4	0.0	0.2	0.0%
Aerosols	R13	0.0	0.2	0.0%
Glycol waste	D15	3.0	0.0	0.0%
Spent ion exchange resin	D14	1.0	0.0	0.0%
Fluorescent tubes	R13	0.0	0.2	0.0%
Total Hazardous Waste		7,455.4	17,603.2	4.2%
2) Non-Hazardous Wastes				
IBA	R5	0.0	113,506.0	18.9%
Ferrous Metal	R4	0.0	3,777.0	0.6%
Process Water	D8	1,749.0	0.0	0.3%
Dry mixed recyclables	R13	0.0	4.0	0.0%
Rubble	R13	0.0	4.0	0.0%
General waste	R13	0.0	44.0	0.0%
Wood	R3	0.0	4.0	0.0%
Sewage	D8	42.0	0.0	0.0%
Septic tank sludge	R13	0.0	20.0	0.0%
Total Non-Hazardous Waste		1,791.0	117,359.0	19.9%
TOTAL WASTE		9,246.4	134,962.2	24.1%

Operator's comments :

--

2020 Annual Reporting of Water and Other Raw Material Usage

Raw Material	Usage	Unit	Specific Usage	Unit
Mains Water	95903	m ³	0.16	m ³ /te
Total Water	189283.59	m ³	0.32	m ³ /te
Urea / Ammonia	27882	kg	0.05	kg/te
Activated Carbon	240806	kg	0.40	kg/te
Lime / hydrated lime / Sodium Bicarb.	10476000	kg	17.48	kg/te

Operator's comments :

--

2020 Annual Reporting of other performance indicators

Parameter	Results by Line

	A1	A2	A3	A4	A5		Turbine 1	Turbine 2
Operating hours for the year, hours	8284	8366					6113	
Number of periods of abnormal operation, qty.	12	25						
Cumulative hours of abnormal operation for this year, hours	6	12.5						

Operator's comments :

Signed: _____

Date: _____

Operational Data

Plant Size	725,000 tonnes pa	80 MWth	73 MWe
No. of combustion lines	2	No. of Turbines:	1

Waste types received	Unit	Q1	Q2	Q3	Q4	Year Total	%
Household / Local Authority	tonnes					-	-
Commercial & Industrial						-	-
Hazardous						-	-
Clinical						-	-
Waste wood (biomass)						-	-
Refuse derived fuel		170,067	152,091	154,104	180,152	656,414	100.0%
Solid recovered fuel						-	-
Other [Please specify]						-	-
Other [Please specify]						-	-
Other [Please specify]						-	-
Total waste received			170,067	152,091	154,104	180,152	656,414
Rejected Waste						-	-
Waste transferred out						-	-
Total waste combusted		170,067	152,091	154,104	180,152	656,414	100.0%

Energy Usage / Export	Unit	Q1	Q2	Q3	Q4	Year Total	KWh/te
Power Generated		165,038	163,220	161,460	174,610	664,328	1,012
Power Exported	MWh	148,773	147,391	145,796	157,969	599,929	914
Power Used on site		16,265	15,829	15,664	16,641	64,399	98
Power Imported		-	-	97	21	119	0
Parasitic Load	%	9.9%	9.7%	9.8%	9.5%	9.7%	
Thermal Energy Produced	GWh					-	-
Thermal Energy Exported						-	-
R1 value					0.80		Design / Operational / n/a

Waste Disposal & Recovery	Unit	Q1	Q2	Q3	Q4	Year Total	% inputs
APC Residues - produced	tonnes	6,441	6,522	6,329	7,406	26,699	4.1%
IBA - produced		31,835	32,944	31,024	31,673	127,477	19.4%
Metals recycling		1,164	1,188	1,130	1,246	4,728	0.7%
Waste wood		5	3	2	1	11	0.0%
Building rubble		25	-	-	-	25	0.0%
Dry mixed recyclables		0	0	1	1	2	0.0%
General waste		9	12	5	8	33	0.0%
APCr contaminated materials		7	-	10	4	21	0.0%
Oil contaminated solid waste		1	-	1	-	2	0.0%
WEEE		0	-	0	-	1	0.0%
Spent aerosols		0	-	0	-	0	0.0%
Waste hydraulic oil		-	3	-	3	6	0.0%
Spent ion exchange resin		0	-	0	-	0	0.0%
Fluorescent tubes		-	-	0	-	0	0.0%
Sewage		-	17	-	4	21	0.0%
Mixed batteries		0	-	-	-	0	0.0%
Carbon/vermiculite		40	-	-	-	40	0.0%
Waste lime		-	0	-	-	0	0.0%
Waste activated carbon		-	-	2	-	2	0.0%
Carbon filters		-	-	-	0	0	0.0%
Waste alumina dessicant		-	-	-	2	2	0.0%

Raw Material Usage	Unit	Q1	Q2	Q3	Q4	Year Total	kg or Ltr /te
Mains Water	m ³	28,432	21,374	13,884	19,398	83,088	126.58
Other Water	m ³	18,167	25,334	27,159	23,377	94,036	143.26
Ammonia / Urea	kgs	1,812	779	1,617	4,585	8,793	13.39
Activated Carbon	kgs	69,750	66,240	66,300	66,500	268,790	409.48
Lime / hydrated lime	kgs	2,353,000	2,640,000	2,816,000	2,829,000	10,638,000	16,206.24
Fuel oil	ltrs	250,420	148,672	263,799	93,347	756,238	1,152.07
Gas	cf	-	-	-	-	-	-
Other		-	-	-	-	-	-

Summary of Hours	Line/Unit	Q1	Q2	Q3	Q4	Year Total	
Hours of waste combustion, total	2	2,121	2,039	2,126	2,151	8,437	96.3%
Hours of waste combustion, total	2	2,073	2,088	2,112	2,089	8,362	95.5%
Hours of turbine operations, total	1	2,160	2,184	2,186	2,204	8,734	99.7%
Hours of heat / steam export		-	-	-	-	-	n/a
Abnormal Events	qty.	11	2	11	1	25	yes
Abnormal operation	hours	6	1	6	1	13	0.14%
Permit Breaches	qty.	-	-	1	-	1	yes

2021 Annual Reporting Performance Form 1

Permit EPR/SP3239FU

Operator: 0

Facility: enfinium Ferrybridge 1 Ltd

Form: Performance 1

Reporting Period from:

01 January 2021

to:

31 December 2021

2021 Annual Reporting of Waste Disposal and Recovery

Waste Description	Disposal Route(s)	Disposal Tonnes	Recovery Tonnes	% / tonne of waste incinerated
1) Hazardous Wastes				
APC Residues	D9/R5	6,432.5	20,266.0	4.1%
APCr contaminated materials	D14/D15/R13	16.7	4.3	0.0%
Waste Oil	R13	0.0	5.6	0.0%
Oil contaminated materials	R13	0.0	1.8	0.0%
WEEE	R13	0.0	0.4	0.0%
Aerosols	R13	0.0	0.0	0.0%
Spent ion exchange resin	R13	0.0	0.1	0.0%
Mixed batteries	R13	0.0	0.1	0.0%
Carbon filters	R13	0.0	0.3	0.0%
Fluorescent tubes	R13	0.0	0.4	0.0%
Total Hazardous Waste		6,449.2	20,278.8	4.1%
2) Non-Hazardous Wastes				
IBA	R5	0.0	127,477.0	19.4%
Ferrous Metal	R4	0.0	4,728.0	0.7%
Dry mixed recyclables	R13	0.0	2.0	0.0%
Rubble	R13	0.0	25.0	0.0%
General waste	R13	0.0	33.0	0.0%
Wood	R3	0.0	11.0	0.0%
Sewage	D8	21.1	0.0	0.0%
Carbon/vermiculite	R13	0.0	40.0	0.0%
Activated carbon	D15	1.5	0.0	0.0%
WEEE	R13	0.0	0.3	0.0%
Waste alumina dessicant	D14	2.1	0.0	0.0%
Total Non-Hazardous Waste		24.7	132,316.3	20.2%
TOTAL WASTE		6,473.9	152,595.1	24.2%

Operator's comments :

2021 Annual Reporting of Water and Other Raw Material Usage

Raw Material	Usage	Unit	Specific Usage	Unit
Mains Water	83088	m ³	0.13	m ³ /te
Total Water	177124.01	m ³	0.27	m ³ /te
Ammonia	8792.58	kg	0.01	kg/te
Activated Carbon	268790	kg	0.41	kg/te
Lime / hydrated lime / Sodium Bicarb.	10638000	kg	16.21	kg/te

Operator's comments :

2021 Annual Reporting of other performance indicators

Parameter	Results by Line						Turbine 1	Turbine 2
	A1	A2	A3	A4	A5			
Operating hours for the year, hours	8437	8362					8734	
Number of periods of abnormal operation, qty.	7	18						
Cumulative hours of abnormal operation for this year, hours	3.5	9						

Operator's comments :

Signed: _____

Date: _____

Operational Data

Plant Size	725,000 tonnes pa	80 MWth	73 MWe
No. of combustion lines	2	No. of Turbines:	1

Waste types received	Unit	Q1	Q2	Q3	Q4	Year Total	%
Household / Local Authority	tonnes					-	-
Commercial & Industrial						-	-
Hazardous						-	-
Clinical						-	-
Waste wood (biomass)						-	-
Refuse derived fuel		153,355	158,168	162,701	140,354	614,578	100.0%
Solid recovered fuel						-	-
Other [Please specify]						-	-
Other [Please specify]						-	-
Other [Please specify]						-	-
Total waste received			153,355	158,168	162,701	140,354	614,578
Rejected Waste						-	-
Waste transferred out						-	-
Total waste combusted		153,355	158,168	162,701	140,354	614,578	100.0%

Energy Usage / Export	Unit	Q1	Q2	Q3	Q4	Year Total	KWh/te
Power Generated	MWh	162,200	158,011	157,825	118,425	596,461	971
Power Exported		148,460	143,248	142,977	107,626	542,311	882
Power Used on site		13,740	14,763	14,848	10,257	53,608	87
Power Imported		153	11	61	2,286	2,511	4
Parasitic Load	%	8.6%	9.3%	9.4%	10.8%	9.5%	
Thermal Energy Produced	GWh					-	-
Thermal Energy Exported						-	-
R1 value							Design / Operational / n/a

Waste Disposal & Recovery	Unit	Q1	Q2	Q3	Q4	Year Total	% inputs	
APC Residues - produced	tonnes	6,226	6,230	6,168	5,691	24,315	4.0%	
IBA - produced		28,030	32,527	30,796	20,335	111,687	18.2%	
Metals recycling		150	198	733	858	1,938	0.3%	
Dry mixed recycling		1	1	1	0	3	0.0%	
General waste		5	8	3	10	26	0.0%	
Waste process water		249	167	129	566	1,110	0.2%	
Waste paint		1				1	0.0%	
Waste lime			0	2	1	4	0.0%	
Ash contaminated water			14	3		17	0.0%	
Waste wood			1	1	2	4	0.0%	
Glycol liquid waste					1	1	0.0%	
Oil contaminated solid waste					2	2	0.0%	
Spent ion exchange resin					1	1	0.0%	
Waste hydraulic oil				0		0	0.0%	
Sewage						10	0.0%	
Other			-	-	-	-	-	-

Raw Material Usage	Unit	Q1	Q2	Q3	Q4	Year Total	kg or Ltr /te
Mains Water	m ³	30,905	21,118	16,521	13,044	81,588	132.75
Other Water	m ³		28,305	21,732	22,058	72,095	117.31
Ammonia / Urea	kgs	91,535	26,169	33,690	36,410	187,804	305.58

Activated Carbon	kgs	56,870	58,987	57,106	47,401	220,364	358.56
Lime / hydrated lime	kgs	2,756,000	2,803,000	2,722,000	2,316,800	10,597,800	17,244.03
Fuel oil	ltrs	203,551	88,771	394,087	297,829	984,238	1,601.49
Gas	cf	-	-	-	-	-	-
Other		-	-	-	-	-	-

Summary of Hours	Line/Unit	Q1	Q2	Q3	Q4	Year Total	
Hours of waste combustion, total	2	2,165	2,184	2,010	1,825	8,184	x %
Hours of waste combustion, total	2	2,129	2,150	2,076	1,821	8,176	x %
Hours of turbine operations, total	1	2,885	2,180	2,162	1,598	8,825	x %
Hours of heat / steam export		-	-	-	-	-	n/a
Abnormal Events	qty.	-	1	-	3	4	yes
Abnormal operation	hours	-	7	-	3	10	0.11%
Permit Breaches	qty.	1	1	-	-	2	yes

2020 Annual Reporting Performance Form 1

Permit EPR/XP3833DK

Operator: 0

Facility: Ferrybridge Multifuel 2

Form: Performance 1

Reporting Period from:

01 January 2020

to:

31 December 2020

2020 Annual Reporting of Waste Disposal and Recovery

Waste Description	Disposal Route(s)	Disposal Tonnes	Recovery Tonnes	% / tonne of waste incinerated
1) Hazardous Wastes				
APC Residues	R5/D9	602.3	23,744.8	4.0%
Waste paint	R13		0.5	0.0%
Waste lime	D9	3.8		0.0%
Ash contaminated water	D9	17.0		0.0%
Glycol waste	D15	0.5		0.0%
Oil contaminated solid waste	D15	1.5		0.0%
Spent ion exchange resin	D14	0.6		0.0%
Waste hydraulic oil	R13		0.2	0.0%
				-
Total Hazardous Waste		625.7	23,745.5	4.0%
2) Non-Hazardous Wastes				
IBA	R5		111,641.2	18.2%
Ferrous Metal	R4	117.0	1,818.6	0.3%
Process Water	D8	1,110.3		0.2%
Dry Mixed Recyclables	R13		2.8	0.0%
General Waste	R13		26.0	0.0%
Waste wood	R3		3.6	0.0%
Sewage	D8	10.1		0.0%
				-
Total Non-Hazardous Waste		1,237.4	113,492.2	18.7%
TOTAL WASTE		1,863.1	137,237.7	22.6%

Operator's comments :

--

2020 Annual Reporting of Water and Other Raw Material Usage

Raw Material	Usage	Unit	Specific Usage	Unit
Mains Water	81588	m ³	0.13	m ³ /te
Total Water	153682.82	m ³	0.25	m ³ /te
Urea / Ammonia	187804	kg	0.31	kg/te
Activated Carbon	220364	kg	0.36	kg/te
Lime / hydrated lime / Sodium Bicarb.	10597800	kg	17.24	kg/te

Operator's comments :

--

2020 Annual Reporting of other performance indicators

Parameter	Results by Line					Turbine 1	Turbine 2
	A1	A2	A3	A4	A5		
Operating hours for the year, hours	8184	8176				8825	

Number of periods of abnormal operation, qty.	7	22						
Cumulative hours of abnormal operation for this year, hours	1.17	8.67						

Operator's comments :

Signed: _____

Date: _____

Operational Data

Plant Size	725,000 tonnes pa	80 MWth	73 MWe
No. of combustion lines	2	No. of Turbines:	1

Waste types received	Unit	Q1	Q2	Q3	Q4	Year Total	%	
Household / Local Authority	tonnes					-	-	
Commercial & Industrial						-	-	
Hazardous						-	-	
Clinical						-	-	
Waste wood (biomass)						-	-	
Refuse derived fuel		169,270	147,840	176,918	174,912	668,941	100.0%	
Solid recovered fuel						-	-	
Other [Please specify]						-	-	
Other [Please specify]						-	-	
Other [Please specify]						-	-	
Total waste received			169,270	147,840	176,918	174,912	668,941	100.0%
Rejected Waste							-	-
Waste transferred out						-	-	
Total waste combusted		169,270	147,840	176,918	174,912	668,941	100.0%	

Energy Usage / Export	Unit	Q1	Q2	Q3	Q4	Year Total	KWh/te
Power Generated	MWh	169,392	151,470	178,428	178,239	677,529	1,013
Power Exported		154,377	139,845	162,617	162,570	619,408	926
Power Used on site		15,015	11,626	15,812	15,670	58,121	87
Power Imported		-	320	23	-	343	1
Parasitic Load	%	8.9%	7.9%	8.9%	8.8%	8.6%	
Thermal Energy Produced	GWh					-	-
Thermal Energy Exported						-	-
R1 value						0.85	Design / Operational / n/a

Waste Disposal & Recovery	Unit	Q1	Q2	Q3	Q4	Year Total	% inputs
APC Residues - produced	tonnes	6,960	5,906	6,811	7,560	27,237	4.1%
IBA - produced		31,195	29,063	33,910	30,627	124,795	18.7%
Metals recycling		1,168	991	1,427	1,476	5,063	0.8%
Dry mixed recycling		1	1	0	1	2	0.0%
General waste		5	15	6	4	29	0.0%
APCr contaminated waste		3	1	29	7	39	0.0%
Waste lime		2	1	-	1	3	0.0%
Activated carbon waste		0	-	-	-	0	0.0%
Ash contaminated water		4	-	-	-	4	0.0%
Waste wood		1	2	1	1	4	0.0%
Glycol liquid waste		-	0	-	-	0	0.0%
Oil contaminated solid waste		1	2	1	2	5	0.0%
Spent ion exchange resin		1	0	0	-	1	0.0%
Waste Electronic and Electrical Equipment		-	-	0	-	0	0.0%
Waste hydraulic oil		-	3	-	-	3	0.0%
Oversized unburned material		247	147	88	28	510	0.1%
Sewage		-	47	-	-	47	0.0%
Cement		-	-	-	22	22	0.0%
Other		-	-	-	-	-	-

Raw Material Usage	Unit	Q1	Q2	Q3	Q4	Year Total	kg or Ltr /te
Mains Water	m ³	23,924	21,821	13,312	13,334	72,391	108.22
Other Water	m ³	22,943	16,619	25,758	18,657	83,977	125.54
Ammonia / Urea	kgs	31,467	75,290	58,772	77,079	242,608	362.67
Activated Carbon	kgs	62,575	59,023	66,582	68,961	257,141	384.40
Lime / hydrated lime	kgs	3,070,900	2,679,700	3,248,120	3,460,610	12,459,330	18,625.46
Fuel oil	ltrs	146,953	163,860	64,232	55,811	430,856	644.09
Gas	cf	-	-	-	-	-	-
Other		-	-	-	-	-	-

Summary of Hours	Line/Unit	Q1	Q2	Q3	Q4	Year Total	
Hours of waste combustion, total	2	2,113	1,972	2,204	2,095	8,384	95.7%
Hours of waste combustion, total	2	2,156	1,956	2,201	2,208	8,521	97.3%
Hours of turbine operations, total	1	2,155	1,955	2,201	2,208	8,519	97.2%
Hours of heat / steam export		-	-	-	-	-	n/a
Abnormal Events	qty.	-	-	-	1	1	yes
Abnormal operation	hours	-	-	-	1	1	0.01%
Permit Breaches	qty.	-	-	-	-	-	no

2021 Annual Reporting Performance Form 1

Permit EPR/XP3833DK

Operator: 0

Facility: enfinium Ferrybridge 2 Ltd

Form: Performance 1

Reporting Period from:

01 January 2021

to:

31 December 2021

2021 Annual Reporting of Waste Disposal and Recovery

Waste Description	Disposal Route(s)	Disposal Tonnes	Recovery Tonnes	% / tonne of waste incinerated
1) Hazardous Wastes				
APC Residues	R5/D9	1,052.5	26,184.9	4.1%
APCr contaminated waste	D14/D15/R13	38.3	1.0	0.0%
Waste lime	D9/D14/R13	2.2	1.2	0.0%
Ash contaminated water	D9	3.6	0.0	0.0%
Glycol waste	R13	0.0	0.0	0.0%
Oil contaminated solid waste	R13	0.0	4.9	0.0%
Spent ion exchange resin	D14/R13	0.0	0.5	0.0%
Waste Electronic and Electrical Equipment	R13	0.0	0.1	0.0%
Waste hydraulic oil	R13	0.0	2.8	0.0%
Activated carbon waste	D14	0.3	0.0	0.0%
Total Hazardous Waste		1,096.9	26,195.5	4.1%
2) Non-Hazardous Wastes				
IBA	R5	0.0	124,795.0	18.7%
Ferrous Metal	R4	0.0	5,062.7	0.8%
Dry Mixed Recyclables	R13	0.0	2.1	0.0%
General Waste	R13	0.0	28.9	0.0%
Waste wood	R3	0.0	4.1	0.0%
Sewage	D8	47.3	0.0	0.0%
Cement	D14	22.0	0.0	0.0%
Oversized unburned material	R13	0.0	509.7	0.1%
Total Non-Hazardous Waste		69.3	130,402.5	19.5%
TOTAL WASTE		1,166.2	156,598.0	23.6%

Operator's comments :

--

2021 Annual Reporting of Water and Other Raw Material Usage

Raw Material	Usage	Unit	Specific Usage	Unit
Mains Water	72391	m ³	0.11	m ³ /te
Total Water	156367.71	m ³	0.23	m ³ /te
Urea / Ammonia	242608	kg	0.36	kg/te
Activated Carbon	257141	kg	0.38	kg/te
Lime / hydrated lime / Sodium Bicarb.	12459330	kg	18.63	kg/te

Operator's comments :

--

2021 Annual Reporting of other performance indicators

Parameter	Results by Line							
	A1	A2	A3	A4	A5	Turbine 1	Turbine 2	
Operating hours for the year, hours	8384	8521					8519	
Number of periods of abnormal operation, qty.	0	1						
Cumulative hours of abnormal operation for this year, hours	0	0.5						

Operator's comments :

Signed: _____

Date: _____