



NORTH FALLS

Offshore Wind Farm

ENVIRONMENTAL STATEMENT

Appendix 26.4 Operational Noise Calculations

| | |
|---------------------|-----------|
| Document Reference: | 3.3.63 |
| Volume: | 3.3 |
| APFP Regulation: | 5(2)(a) |
| Date: | July 2024 |
| Revision: | 0 |

| | |
|-----------------------------|--|
| Project | North Falls Offshore Wind Farm |
| Document Title | Environmental Statement Appendix 26.4 Operational Noise Calculations |
| Document Reference | 3.3.63 |
| APFP Regulation | 5(2)(a) |
| Supplier | Royal HaskoningDHV |
| Supplier Document ID | PB9244-RHD-ES-ON-RP-ON-0243 |

This document and any information therein are confidential property of North Falls Offshore Wind Farm Limited and without infringement neither the whole nor any extract may be disclosed, loaned, copied or used for manufacturing, provision of services or other purposes whatsoever without prior written consent of North Falls Offshore Wind Farm Limited, and no liability is accepted for loss or damage from any cause whatsoever from the use of the document. North Falls Offshore Wind Farm Limited retains the right to alter the document at any time unless a written statement to the contrary has been appended.

| Revision | Date | Status/Reason for Issue | Originator | Checked | Approved |
|-----------------|-------------|--------------------------------|-------------------|----------------|-----------------|
| 0 | July 2024 | Submission | RHDHV | NFOW | NFOW |
| | | | | | |
| | | | | | |
| | | | | | |

Contents

1 Introduction 5

2 Operational noise calculations 5

2.1 Operational noise sources 5

2.2 Modelling input data..... 5

2.3 Acoustic model settings 6

3 Predicted operational noise levels 6

4 References..... 8

Tables

Table 1 Operational noise plant list 5

Table 2 Noise model input data 6

Table 3 Calculated onshore substation operational noise levels 6

Glossary of Acronyms

| | |
|-------|--|
| BNL | Basic Noise Level |
| dB | Decibel |
| DCO | Development Consent Order |
| DEFRA | Department for Environment, Food and Rural Affairs |
| ES | Environmental Statement |
| HDD | Horizontal Directional Drilling |
| HGV | Heavy Goods Vehicle |
| LIDAR | Light detection and ranging |
| NVSR | Noise and vibration sensitive receptor |
| OS | Ordnance Survey |

Glossary of Terminology

| | |
|--|--|
| The Project Or 'North Falls' | North Falls Offshore Wind Farm, including all onshore and offshore infrastructure. |
| Landfall | The location where the offshore export cables come ashore at Kirby Brook. |
| Landfall compound | Compound at landfall within which horizontal directional drill (HDD) or other trenchless technique would take place. |
| Onshore cable route | Onshore route within which the onshore export cables and associated infrastructure would be located. |
| Onshore substation | A compound containing electrical equipment required to transform and stabilise electricity generated by the Project so that it can be connected to the national grid. |
| Onshore substation works area | Area within which all temporary and permanent works associated within the onshore substation are located, including onshore substation, construction compound, access, landscaping, drainage and earthworks. |
| <i>For further explanation of acoustics specific terms, refer to Appendix 26.1 (Document Reference: 3.3.60).</i> | |

1 Introduction

1. This Appendix to the Environmental Statement (ES) for the proposed North Falls Offshore Wind Farm (herein 'the Project' or 'North Falls') details the operational noise modelling reported in ES Chapter 26 Noise and Vibration (Document Reference: 3.1.28), including plant data, calculation procedures and results.

2 Operational noise calculations

2. Operational noise emissions from proposed onshore substation were predicted at the noise and vibration sensitive receptors (NVSRs) in the vicinity of the substation, as identified in ES Chapter 26 Noise and Vibration (Document Reference: 3.1.28). The modelling was undertaken using SoundPLAN 9.0 3D modelling software. The software implements accepted national and international acoustic calculation standards.
3. The predictions were undertaken in accordance with the methodology provided in ISO 9613-2 Acoustics — Attenuation of sound during propagation outdoors — Part 2: General method of calculation.

2.1 Operational noise sources

4. Operational noise sources that were included in the model are presented in Table 1. This also identifies the number of items of plant / equipment at the onshore substation. All data presented in this appendix are presented as broadband noise levels, however all calculations have included spectral data which can be provided on request.

Table 1 Operational noise plant list

| Item of plant | No. of plant | Sound power level (dB L_{WA}) |
|-------------------------------|--------------|-------------------------------------|
| Power transformer | 2 | 95 |
| Power transformer cooler | 2 | 93 |
| Shunt Reactor (export) | 6 | 95 |
| Shunt Reactor (export) cooler | 6 | 93 |
| Shunt Reactor (400kV) | 1 | 95 |
| Shunt Reactor (400kV) cooler | 1 | 93 |
| Harmonic Filters | 3 | 85 |
| Statcom - Reactors | 6 | 85 |
| Statcom – Capacitors | 12 | 80 |
| Statcom Coolers | 2 | 85 |

2.2 Modelling input data

5. Inputs into the noise models include ground topography, ground type, and buildings to form a 3D representation of the study area. Modelling input data for these calculations are detailed in Table 2.

Table 2 Noise model input data

| Data | Usage | Source file | Origin |
|---------------------------------------|--------------------------------------|--|---|
| OS mapping | Locations of buildings in study area | OS_MasterMap_669253_880737 | Emapsite |
| | | OS_MasterMap_717065_930746 | North Falls Offshore Wind Limited |
| LiDAR composite Digital Terrain Model | Ground topography in study area | LIDAR-DTM-1m-2020-TM02ne LIDAR-DTM-1m-2020-TM21nw | Environment Agency (2020) LIDAR Composite DSM 2020 – 1m. Defra Data Services Platform. Available at https://environment.data.gov.uk/DefraDataDownload/?Mode=survey |

2.3 Acoustic model settings

6. Acoustic modelling has been undertaken using the following model settings:
- Maximum search radius of 3000m;
 - Maximum number of reflections: 3;
 - Daytime and evening / weekend noise predictions carried out at ground floor level i.e. 1.5m above ground. Night-time predictions carried out at first floor level i.e. 4m above ground;
 - Side diffraction enabled;
 - Building heights set to 6m; and
 - Areas of hard ground were identified from the OS mapping and the remainder of the study area was set to soft ground.

3 Predicted operational noise levels

7. The complete results of the onshore substation operational noise level modelling are presented in Table 3. An acoustic feature correction of +2dB has been applied to all predicted noise levels at receptors to obtain the rating level, as defined in BS 4142:2014+A1:2019 ‘Methods for rating and assessing industrial and commercial sound’ and discussed in ES Chapter 26 Noise and Vibration (Document Reference: 3.1.28).
8. The predicted noise levels vary with the height of the receiver above the ground, in accordance with the method in ISO 9613-2. Typically, predicted noise levels are greater at higher floors, due to reduced screening and reduced attenuation from absorptive ground (e.g. vegetation). It is also possible for predicted noise levels to be higher at ground floor, e.g. where reflections off a hard ground surface near to the receiver are a significant contributor to the overall predicted noise level.

Table 3 Calculated onshore substation operational noise levels

| NVSR | Floor | Predicted noise levels (dB $L_{Aeq, T}$) | Rating level (dB $L_{Ar, T}$) |
|------|--------|--|-----------------------------------|
| SSR3 | Ground | 34 | 36 |
| | 1st | 33 | 35 |
| SSR4 | Ground | 32 | 34 |
| | 1st | 34 | 36 |

| NVSR | Floor | Predicted noise levels (dB $L_{Aeq, T}$) | Rating level (dB $L_{Ar, T}$) |
|-------|--------|--|-----------------------------------|
| SSR5 | Ground | 35 | 37 |
| | 1st | 33 | 35 |
| SSR6 | Ground | 35 | 37 |
| | 1st | 34 | 36 |
| SSR7 | Ground | 44 | 46 |
| | 1st | 42 | 44 |
| SSR8 | Ground | 41 | 43 |
| | 1st | 42 | 44 |
| SSR9 | Ground | 35 | 37 |
| | 1st | 36 | 38 |
| SSR10 | Ground | 33 | 35 |
| | 1st | 33 | 35 |

4 References

BSI. (2019). *BS 4142:2014+A1:2019 Methods for Rating and Assessing Industrial and Commercial Sound*. London: BSI.

International Organization for Standardization. (1996). *ISO9613-2:1996 Acoustics - Attenuation of sound during propagation outdoors - Part 2: general method for calculation*. Switzerland: ISO.



NORTH FALLS

Offshore Wind Farm



HARNESSING THE POWER OF NORTH SEA WIND

North Falls Offshore Wind Farm Limited

A joint venture company owned equally by SSE Renewables and RWE.

To contact please email contact@northfallsoffshore.com

© 2024 All Rights Reserved

North Falls Offshore Wind Farm Limited Registered Address: Windmill Hill Business Park, Whitehill Way, Swindon, Wiltshire, SN5 6PB, United Kingdom
Registered in England and Wales Company Number: 12435947