

# ENVIRONMENTAL STATEMENT – VOLUME 3 – APPENDIX 7.1

## Construction Noise and Vibration

Assumptions

Drax Bioenergy with Carbon Capture and Storage

The Infrastructure Planning (Applications: Prescribed Forms and Procedure) Regulations, 2009 – Regulation (5(2)(a)) Document Reference Number: 6.3.7.1 Applicant: Drax Power Limited PINS Reference: EN010120



REVISION: 01 DATE: May 2022 DOCUMENT OWNER: WSP UK Ltd AUTHOR: E. Olmos APPROVER: S. Whydle PUBLIC

## TABLE OF CONTENTS

CONS	STRUCTION ASSUMPTIONS	.1
1.1.	Plant Assumptions	.1
1.2.	Vibration Assumptions	.1
1.3.	Noise Assumptions	.2
1.4.	Model Configuration Assumptions	.4
	1.1. 1.2. 1.3.	CONSTRUCTION ASSUMPTIONS         1.1.       Plant Assumptions         1.2.       Vibration Assumptions         1.3.       Noise Assumptions         1.4.       Model Configuration Assumptions

## PLATES

Plate 1.1 - Construction Area Layout4
---------------------------------------

### TABLES

Table 1.1 -TRL 429 Vibratory Roller and Compactor Data	.2
Table 1.2 - On site Earthworks Noise Level Summary	.2
Table 1.3 - On site Piling Noise Level Summary	.2
Table 1.4 - General Construction Noise Level Summary	.3

## 1. CONSTRUCTION ASSUMPTIONS

#### 1.1. PLANT ASSUMPTIONS

- 1.1.1. The following assumptions are with regards to plant:
  - a. All plant on site operates 100% on-time;
  - **b.** There are three key construction activities assumed: earthwork, piling (civil works), and general construction (installation of carbon capture technology); and
  - c. Locations were assumed for activities, shown in **Plate 1.1**.

#### **1.2. VIBRATION ASSUMPTIONS**

- 1.2.1. The following assumptions are with regards to construction vibration:
  - a. Distance from closest sensitive receptor to construction area limits where vibration is generated 900 m;
  - b. Nominal hammer energy in joules for hammer in use in piling 85000 W;
  - c. Scaling factor depending on ground conditions for percussive piling set to 3;
  - **d.** Scaling factor depending on probability of predicted value being exceeded for vibratory piling set to 126; and
  - e. Vibratory roller and compactor data from TRL 429, shown in Table 1.1.

#### Table 1.1 -TRL 429 Vibratory Roller and Compactor Data

Plant Model	Туре	Number of Drums	Drum Width (m)	Mass per m width (kg/m)		High Setting		
				Front	Rear	Amplitude of drum vibration (mm)	Frequency (Hz)	Centrifugal Force (kN)
Boomag BW161AD	Twin smooth drum roller – JCB size	2	1.68	2680	2740	0.91	30	58

#### 1.3. NOISE ASSUMPTIONS

1.3.1 The following tables show on site plant generated noise levels associated with plant activity stages with reference to BS 5228:2009+A1:2014.

#### Table 1.2 - On site Earthworks Noise Level Summary

Plant Description	BS 5228 Reference	L <sub>Aeq,12h</sub> @ 10m dB from plant	Number of Items	Number of Items Correction dB	Resultant L <sub>Aeq,12h</sub> @ 10m dB from plant items
20 t excavator	C.02 #21	71	5	7	78
35 t road-based wagon	C.02 #30	79	1	0	79
14 t general excavator	C.02 #25	69	6	8	77
D4 and D6 bull dozers	C.02 #12	81	2	3	84
10 & 20 t compaction vibrating rollers	C.05 #20	75	2	3	78

#### Table 1.3 - On site Piling Noise Level Summary

Plant Description	BS 5228 Reference	L <sub>Aeq,12h</sub> @ 10m dB from plant	Number of Items	Number of Items Correction dB	Resultant L <sub>Aeq,12h</sub> @ 10m dB from plant items
Hydraulic hammer piling	C.03 #2	90	4	6	96
Sheet piling	C.03 #9	63	2	3	66

#### Table 1.4 - General Construction Noise Level Summary

Plant Description	BS 5228 Reference	L <sub>Aeq,12h</sub> @ 10m dB from plant	Number of Items	Number of Items Correction dB	Resultant L <sub>Aeq,12h</sub> @ 10m dB from plant items
600 t crawler crane	C.04 #50	71	1	0	71
General craneage	C.03 #29	70	1	0	70
Concrete delivery wagon	C.04 #21	77	1	0	77
Welding and cutting piles	C.03 #32	73	1	0	73

1.3.1. **Plate 1.1** shows the construction areas, with the bore piling area indicated in green, sheet piling area indicated in blue, and the earthworks and general construction area indicated in yellow.

#### Plate 1.1 - Construction Area Layout



#### 1.4. MODEL CONFIGURATION ASSUMPTIONS

- 1.4.1. The following CadnaA configuration settings were assumed:
  - a. Calculations were set to industrial noise, in accordance with ISO BS5228-1:2009+A1:2014 – Code of Practice of noise and vibration control on construction and open sites;
  - **b.** Default ground absorption setting was set to 50%; and
  - c. The maximum order of reflections was set to a value of two.