

From: [REDACTED]
To: [DraxBECCS](#)
Subject: DXBX-SP081 EN010120 – Drax Bioenergy with Carbon Capture and Storage project
Date: 08 March 2023 13:40:22
Attachments: [REDACTED]

Good afternoon
My name is Ben Surtees

I am the clean water network engineer for Yorkshire water and have recently received an email outlining a new development for a Drax carbon capture project.

I have looked through the proposed designs and there are 4 areas of concern from a clean water and strategic mains point of view, I have attached a powerpoint with the sections you have outlined and the areas where we have clean water assets that are of concern for your perusal.

I would like to attend one of the meetings for the infrastructure session if possible please as we need to look at the exact extent of any proposed works and construction depths etc during the works as this may impact our mains.

If you could let me know of the date please as there are 3 dates on the examination procedure document.

Any questions or queries you may have please don't hesitate to get in touch with myself on the email or telephone number at the bottom of this email.

Thank you in advance

[REDACTED]

Want to know a bit more about Yorkshire Water? Our website is full of useful info, from how to apply for a water meter to planning your next walk at one of our beautiful reservoirs - it's all at yorkshirewater.com

Need to talk to us? For the best way to get in touch with us, go to [REDACTED]

Now the legal stuff! The information and any files sent as part of this email are confidential, possibly legally privileged and for the addressee's attention only. If you've wrongly received this email, please reply to it to let the sender know and delete it from your computer. Just to confirm, this email isn't a binding offer, acceptance, amendment, waiver or any agreement or obligation – unless this is clearly stated in the email.

We need to let you know that the content is subject to the legal notice at [REDACTED] Any disclosure, copying, distribution or action taken based on its contents, is prohibited and may be unlawful.

Yorkshire Water Services Limited
Registered Office Western House, Halifax Road, Bradford, BD6 2SZ
Registered in England and Wales No 2366682

Key:



Order Limits



Order Land - New rights to be compulsorily acquired and restrictive covenants imposed, in relation to which it is proposed to extinguish easements, servitudes and other private rights



Order land - Temporary use of land and in relation to which it is proposed to suspend easements, servitudes and other private rights




Order Land- Land in relation to which it is proposed to permanently extinguish easements, servitudes and other private rights





Order land - No rights required

Plans showing YW clean water mains in proposed development area

- Slide 2 shows a 1000mm ductile Iron Critical trunk main within the proposed development boundary of section 1
- Slide 4 shows a 3" uPVC main that is within the proposed development boundary this seems to be laid in the this appears to be laid in the carriageway but if any construction works are to take place in the road this will need to be located and marked out and either diverted or dependant on construction/reinstatement protected
- Slide 7 shows several mains (6" and 4") within the proposed dev boundary of section 2. Again these could be located in the carriageway
and would need to be verified as to their exact location if the development is to go ahead and again dependant on construction
could be diverted or protected during construction
- Slide 9 shows a small length of 300mm Ductile Iron main that may be impacted in Section 3 of your plans
- Slide 11 shows the same main 300mm DI on a different section of your plans section 4 same applies to this main as previous










3" uPVC main



3

