



## ENVIRONMENTAL STATEMENT: 6.3 APPENDIX 6-5: OPERATIONAL NOISE MODELLING ASSUMPTIONS

**Cory Decarbonisation Project** 

**PINS Reference: EN010128** 

March 2024

Revision A



## APPENDIX 6-5: OPERATIONAL NOISE MODELLING ASSUMPTIONS

**Table 1** identifies the assumptions made for sound power levels and heights of each noise source that has been modelled for the operation phase of the Proposed Scheme, based on the evolving design.

**Table 1: Operation Noise Source Assumptions** 

| Noise Source                              | Sound Power<br>Level L <sub>WA</sub> dB (A) | Height (m) | Information Source   |
|---|---|------------|--|
| Stack(s)                                  | 103   | 60         | Sound power level equivalent to the stack for Riverside 2, excludes the Absorber Column(s). Height of the Absorber Column(s) and Stack(s) is 113m as described in Section 2.2 of Chapter 2: Site and Proposed Scheme Description (Volume 1). |
| Flue Gas Fan                              | 85  | 9.8        | Based on similar development (professional judgement).   |
| Pumps                                     | 104   | 1          | WKC Group Pump Noise Calculator,<br>450kW rich solution pump, assumed<br>worst-case speed range.   |
| Pumps associated with solvent/waste tanks | 96  | 1          | WKC Group Pump Noise Calculator,<br>100kW pump, assumed 1500rpm speed<br>range.  |
| Back Pressure turbines                    | 85  | 6          | Based on similar development (professional judgement).   |
| 33/11kV Transformers                      | 78  | 6          | Based on NEMA TR1 and IEEE standards for specifying sound pressure and converting to sound power.  |
| 132/33kV<br>Transformers                  | 86  | 6          | Based on NEMA TR1 and IEEE standards for specifying sound pressure and converting to sound power.  |
| CO₂ Vents                                 | 110   | 11.6       | Based on similar development (professional judgement).   |
| CO <sub>2</sub> Compressors               | 90  | 11         | The CO <sub>2</sub> compressors are a part of the Compression Plant. The height of the plant is detailed in <b>Section 2.2</b> of  |



| Noise Source                          | Sound Power<br>Level L <sub>WA</sub> dB (A) | Height (m) | Information Source   |
|---------------------------------------|---|------------|--|
|                                       |   |            | Chapter 2: Site and Proposed Scheme Description (Volume 1).  |
| Refrigeration Package                 | 98  | 1          | Based on similar development (professional judgement).   |
| Cooling Solution                      | 93  | 15         | Assumed as part of design based on similar developments.   |
| Heat Transfer Station<br>Cooling Fans | 98  | 7.75       | Assumed as part of design based on similar developments, height assumed to be 2.5m above the roof of building as a worst case. |



10 Dominion Street

CORY

Floor 5

Moorgate, London

EC2M 2EF

Contact Tel: 020 7417 5200

Email: enquiries@corygroup.co.uk

corygroup.co.uk