

Steffan,

Further to our call earlier, I thought it better to email you so that I could better set out the relevant references.

The best description of when it is appropriate to use a H Pole is provided within the project description chapter of the ES. APP-057 paragraphs 2.5.11 to 2.5.15 provide an explanation.

Ultimately the standards which drive the choice of single or H poles are, I understand set out within the WPD document WPD Standard Technique OH4B/1 , which is based on EN 43 – 50 (132Kv Single Circuit Overhead Lines on Wood Poles). This document is referred to within the submitted Climate Change resilience report (APP085), paragraph 6.28 when discussing the matter of resilience to high winds.

I should point out that the document ‘Applicant’s response to open floor hearings’ is essentially a transcript of what was said at the hearings. Our subsequent response to a range of questions posed by Mrs Reader is set out within the document ‘responses to Exa questions asked at hearings’ Vol 9.15. See Appendix 1.

Regards

David.

David Kenyon MRTPI IHBC

Technical Director, Planning, Transport and Design, Amec Foster Wheeler Environment & Infrastructure UK Ltd
Canon Court, Abbey Lawn, Abbey Foregate, Shrewsbury SY2 5DE
T +44 1743 342000 D +44 1743 342061 Mob 07803 078430
david.kenyon@amecfw.com



This message is the property of Amec Foster Wheeler plc and/or its subsidiaries and/or affiliates and is intended only for the named recipient(s). Its contents (including any attachments) may be confidential, legally privileged or otherwise protected from disclosure by law. Unauthorised use, copying, distribution or disclosure of any of it may be unlawful and is strictly prohibited. We assume no responsibility to persons other than the intended named recipient(s) and do not accept liability for any errors or omissions which are a result of email transmission. If you have received this message in error, please notify us immediately by reply email to the sender and confirm that the original message and any attachments and copies have been destroyed and deleted from your system. This disclaimer applies to any and all messages originating from us and set out above. If you do not wish to receive future unsolicited commercial electronic messages from us, **please forward this email to: unsubscribe@amecfw.com and include “Unsubscribe” in the subject line.** If applicable, you will continue to receive invoices, project communications and similar factual, non-commercial electronic communications.

Please click <http://amecfw.com/email-disclaimer> for notices and company information in relation to emails originating in the UK, Italy or France.