



R17
 Predicted noise level: 17.7 dB
 Daytime Criterion: 43 dB
 Night-time Criterion: 35 dB

R16
 Predicted noise level: 28.9 dB
 Daytime Criterion: 43 dB
 Night-time Criterion: 35 dB

Key

Order Limits

dB, LAeq,T (all plant operating continuously)

- Less than 25
- 25 to 30
- 30 to 35
- 35 to 40
- 40 to 45
- 45 to 50
- 50 to 55
- 55 to 60
- 60 to 65
- 65 to 70
- 70 to 75
- More than 75

Receptor Name:
 R16 - Southsea Leisure Park (Caravans)
 R17 - 41-51 Fort Cumberland Road

The Infrastructure Planning (Applications: Prescribed Forms and Procedure) Regulations 2009 – Regulation 5(2)(a)

01	23/10/2019	YH	FIRST ISSUE	TF	LB
REV	DATE	BY	DESCRIPTION	CHK	APP

DRAWING STATUS: FINAL



WSP House, 70 Chancery Lane, London, WC2A 1AF
 T+ 44 (0) 20 7314 5000
 wsp.com

CLIENT:



PROJECT:
 AQUIND Interconnector

TITLE:
 Figure 24.5
 Section 10 - predicted broadband noise levels from operational telecommunication ORS infrastructure at landfall
 Sheet 1 of 1

SCALE AT A4 1:800	CHECKED: TF	APPROVED: LB
PROJECT NO: EN020022	DESIGNED: TF	DRAWN: YH
DRAWING NO: EN020022-ES-24.5-Sheet1		REVNO: 01

© WSP UK Ltd

Reproduced from Ordnance Survey digital map data © Crown copyright [date]. All rights reserved. Licence number [add number].
 © Crown copyright material is reproduced with the permission of Land Registry under delegated authority from the Controller of HMSO. This material was last updated in [date] and may not be copied, distributed, sold or published without the formal permission of Land Registry. Only an official copy of a title plan or register obtained from the Land Registry may be used for legal or other official purposes. May contain public sector information licensed under the Open Government Licence v 3.0.