

### **AQUIND Limited**

## **AQUIND INTERCONNECTOR**

Environmental Statement – Volume 3 – Appendix 4.1 Screening for Major Accidents and Disasters

The Planning Act 2008

The Infrastructure Planning (Applications: Prescribed Forms and Procedure) Regulations 2009 – Regulation 5(2)(a)

The Infrastructure Planning (Environmental Impact Assessment) Regulations 2017

Document Ref: 6.3.4.1

PINS Ref.: EN020022



## **AQUIND Limited**

# **AQUIND INTERCONNECTOR**

Environmental Statement – Volume 3 – Appendix 4.1 Screening for Major Accidents and Disasters

**PINS REF.: EN020022** 

**DOCUMENT: 6.3.4.1** 

DATE: 14 NOVEMBER 2019

**WSP** 

**WSP House** 

70 Chancery Lane

London

WC2A 1AF

+44 20 7314 5000

www.wsp.com



#### **DOCUMENT**

Document	6.3.4.1 Environmental Statement – Volume 3 – Appendix 4.1 Screening for Major Accidents and Disasters
Revision	001
Document Owner	WSP UK Limited
Prepared By	J. Scholes
Date	17 October 2019
Approved By	U. Stevenson
Date	17 October 2019

PINS Ref.: EN020022

Document Ref.: Environmental Statement Appendix 4.1 Screening for Major Accidents and Disasters

November 2019



#### **CONTENTS**

APPENDIX 4.1 SCREENING FOR MAJOR ACCIDENTS AND DISASTERS 1

**REFERENCES** 

#### **TABLES**

Table 1 - Screening Exercise to determine the types of major accidents and/or disasters relevant to the Proposed Development

3

AQUIND INTERCONNECTOR

PINS Ref.: EN020022

Document Ref.: Environmental Statement Appendix 4.1 Screening for Major Accidents and Disasters

November 2019



# APPENDIX 4.1 SCREENING FOR MAJOR ACCIDENTS AND DISASTERS

- 1.1.1.1. This Appendix addresses the potential vulnerability of the Proposed Development to major accidents and/or disasters as required by the Infrastructure Planning (Environmental Impact Assessment) Regulations 2017 (HM Government, 2017).
- 1.1.1.2. Schedule 4, Paragraph 8 of the ('Environmental Impact Assessment') EIA Regulations requires an Environmental Statement ('ES') to include the following:

"A description of the expected significant adverse effects of the development on the environment deriving from the vulnerability of the development to risks of major accidents and/or disasters which are relevant to the project concerned. Relevant information available and obtained through risk assessments pursuant to EU legislation such as Directive 2012/18/EU of the European Parliament and of the Council"..."or Council Directive 2009/71/Euratom"..."or UK environmental assessments may be used for this purpose provided that the requirements of this Directive are met. Where appropriate, this description should include measures envisaged to prevent or mitigate the significant adverse effects of such events on the environment and details of the preparedness for and proposed response to such emergencies."

- 1.1.1.3. A screening exercise has been undertaken to determine the types of major accidents and/or disasters relevant to the Proposed Development under the Regulations, these include:
  - vulnerability of the development to major accidents and disasters, which may then give rise to significant adverse effects on the environment; and
  - major accidents and disasters arising from development which may give rise to significant adverse effects on the environment.
- 1.1.1.4. Where there is potential for significant environmental effects, and the major accident or disaster is screened in, these are assessed in the relevant individual chapters presented in this ES. The screening exercise is based on a Source-Pathway-Receptor model and considers the following:
  - Source Likely major accidents and/or disasters using available guidance (Cabinet Office, 2017)(Dawson, 2016).
  - Source Description of the Proposed Development (the Aquind Interconnector is not within the scope of the Control of Major Accident Hazards ('COMAH') Regulations).

AQUIND INTERCONNECTOR

WSP

PINS Ref.: EN020022

Document Ref.: Environmental Statement Appendix 4.1 Screening for Major Accidents and Disasters

November 2019



- 3. Pathway Aspects of the Proposed Development which may interact with or give rise to natural and man-made hazards.
- 4. Receptor Identified environmental topics or receptors for major accidents and disasters and relevant chapter of the ES.

PINS Ref.: EN020022

Document Ref.: Environmental Statement Appendix 4.1 Screening for Major Accidents and Disasters

November 2019

WSP

AQUIND Limited Page 2 of 13



Table 1 - Screening Exercise to determine the types of major accidents and/or disasters relevant to the Proposed Development

Accident/ Disaster Group and Type (Source)	Location Risk (Source)	Risk to phase and aspect of development (Pathway)	Screening for Further Consideration (Receptors)
Flooding – Coastal, Rivers and Streams, Surface Water and Groundwater	Yes – In terms of the risk of flooding, there are areas of the site located within tidal flood zones 2 and 3 adjacent to Portsea Island, although these are typically at a low probability of tidal flooding considering the existing flood defences and the site's ground levels. In addition, there are several watercourses within the redline boundary. Land in the local vicinity of these watercourses is located within a combination of Flood Zone 2 and 3.  Notwithstanding the parts of the site located in Flood Zones 2 and 3, the majority of the Site is located in Flood Zone 1 (a low risk zone) due to the site's elevated elevation above the rivers within the	Construction and Decommissioning of the Onshore Cable Route and Converter Station.	Screen in – Chapter 19 (Groundwater) and Chapter 20 (Surface Water Resources and Flood Risk) of the ES Volume 1 (document reference 6.1.19 and 6.1.20).

PINS Ref.: EN020022

Document Ref.: Environmental Statement Appendix 4.1 Screening for Major Accidents and Disasters

**AQUIND Limited** 



	catchment. There are also isolated areas of the site located in areas of identified surface water flood risk, along or through surface water flow paths, and in isolated areas at risk of groundwater flooding.		
Severe weather – Storms and gales, Cold and snow, Heatwave, Drought	Yes – The site's coastal location increases its exposure to storms and gales.	Construction and Decommissioning – Risk of damage and/or harm during the construction of the Onshore and Marine Cable Route and the Converter Station.  Operation – Risk of damage causing exposure of the buried Marine Cable and damage to the Converter Station during the Operational Stage.	Screen in – Chapter 28: (Carbon and Climate Change) of the ES Volume 1 (document reference 6.1.28).
Space weather – Solar flares, Solar energetic particles, Coronal mass ejections	Yes –these events may cause electricity blackouts potentially causing fatalities and physical/psychological casualties, and/or disrupt essential energy services.	Operation – Disruption of the energy supply during the Operational Stage.	Screen out - loss of functionality to proposed development only, no impact on EIA topics/receptors.

PINS Ref.: EN020022

Document Ref.: Document Ref.: Environmental Statement Appendix 4.1 Screening for Major Accidents and Disasters

**AQUIND Limited** 



Volcanic eruptions	No – Volcanic eruptions occur outside the UK. The main consequence of these would potentially be ash and gas related air pollution (see below).	N/A	Screen out –No source, Volcanic activity does not occur in the UK and is not linked to the Proposed Development.
Poor air quality	Yes - Short term surges in poor air quality occur primarily due to weather conditions preventing pollution from dispersing, which can lead to fatalities, casualties, pressure on healthcare, economic damage, and environmental damage. The Onshore Cable Route will enter the Portsmouth Air Quality Management Area ('AQMA').	Construction and Decommissioning— Air quality effects from traffic emissions during the construction of the Onshore Cable Route have been screened out in this EIA.	Screen out. Cumulative effects with external poor air quality are likely to be insignificant.  In addition, procedures are in place for monitoring dust in Chapter 23 (Air Quality) of the ES Volume 1 (document reference 6.1.23).
Earthquakes/Ground Instability	No - Earthquakes in the UK are moderately frequent but rarely result in large amounts of damage and that an earthquake of sufficient intensity to inflict severe damage is unlikely. Earthquake activity is greatest at the major fault lines,	N/A	Screen out – no source.

PINS Ref.: EN020022

Document Ref.: Document Ref.: Environmental Statement Appendix 4.1 Screening for Major Accidents and Disasters

**AQUIND Limited** 



	which are far away from the UK. In addition, the Ground Investigation carried out in April 2018 did not indicate that the underlying geology is unsuitable for the Proposed Development in terms of the risk of ground instability.		
Wildfires	No – The risk of a wildfire is affected by the availability and dryness of fuel, e.g. vegetation. The Proposed Development is not located in areas of habitat at risk of wildfire, such as moorland or heathland.	N/A	Screen out – no source.
Human diseases - e.g. influenza ('flu') pandemic	Yes – The Proposed Development is located within and adjacent to a densely populated area.	None – Beyond the construction workforce, the project does not generate human interaction.	Screen out – no pathway.
Animal diseases – diseases which spread from animals to humans ('zoonotic diseases') and diseases which cannot	Yes – There is some limited pasture in the vicinity of the Proposed Development.	None – The project does not generate interaction with animals.	Screen out – no pathway.

PINS Ref.: EN020022

Document Ref.: Document Ref.: Environmental Statement Appendix 4.1 Screening for Major Accidents and Disasters

**AQUIND Limited** 



spread to humans ('non-zoonotic')			
Electricity failure	Yes - Electricity failure can be caused by a number of factors, such as severe weather. Although an electricity failure across entire regions of the UK has not happened before, if it were to occur, the impacts would be very severe causing widespread disruption to many critical sectors and wider society in general.	Operation – Disruption of the energy supply during the Operational Stage.	Screen out – loss of functionality to proposed development only, no impact on EIA topics/ receptors.  Whilst the probability of a region or UK wide electricity failure is low, experts consider that the risk of such a high consequence event needs to be taken very seriously (The Centre for the Study of Existential Risk, Cambridge University and The International Centre for Infrastructure Futures, 2017). Therefore, the Proposed Development should be designed in accordance with current best practice in terms of the risk of electricity failure.

PINS Ref.: EN020022

Document Ref.: Document Ref.: Environmental Statement Appendix 4.1 Screening for Major Accidents and Disasters

**AQUIND Limited** 



System failures	Yes - Electricity failure is a widespread system failure and an individual risk. The risk of system failure is, therefore, considered to be similar to electricity failure.	Operation – Disruption of the energy supply during the Operational Stage.	Screen out – loss of functionality to proposed development only, no impact on EIA topics/receptors.  As with the risk of Electricity failure, the Proposed Development should be designed in accordance with current best practice to reduce the risk of system failure.
Major Transport accidents	Yes – There is a risk of road accidents and marine accidents associated with the Proposed Development. The consequences of major transport accidents may include fatalities, disruption to essential services, disruption to business and tourism, damage to property and infrastructure and environmental contamination.  The Proposed Development crosses the English Channel with one section of the corridor crossing	Construction and Decommissioning - Risk of road accidents during the construction of the Onshore Cable Route and Converter Station and navigational risk during construction of the Marine Cable.	Screen in – Chapter 22 (Traffic and Transport), Chapter 13 (Shipping, Navigation and Other Marine Users) of the ES Volume 1 (document references 6.1.22 and 6.1.13).

PINS Ref.: EN020022

Document Ref.: Document Ref.: Environmental Statement Appendix 4.1 Screening for Major Accidents and Disasters

**AQUIND Limited** 



	the entrance of the eastbound shipping lane of the west of the Dover Strait Traffic Separation Scheme ('TSS'), which is one of the world's busiest shipping lanes. Construction of the Onshore Cable utilises several road corridors and construction traffic will use the road network potentially including the A3 Motorway, A roads, B roads and unclassified roads.		
Industrial and urban accidents	No – According to the Health and Safety Executive's search tool for sites subject to the COMAH Regulations, there are no COMAH sites within approximately 1 kilometre of the Proposed Development.  In addition, the Proposed Development itself would not create a major accident hazard and would not come under the COMAH Regulations.	N/A	Screen out – no source.
Industrial action	Yes – Services generally continue but at a reduced capacity during	Construction, maintenance and Decommissioning of	Screen out - no pathway.

PINS Ref.: EN020022

Document Ref.: Document Ref.: Environmental Statement Appendix 4.1 Screening for Major Accidents and Disasters

**AQUIND Limited** 



	industrial action. In addition, consequences are generally limited to disruption rather than damage.	the Proposed Development is not anticipated to be undertaken by labour associated with trade unions.	
Public disorder	Yes - The Proposed Development is located within and adjacent to a densely populated area. Serious disorder in the UK has been rare, however a possible consequence could be damage to property and infrastructure.	Construction and Decommissioning — potential for minor disruption to programme if public disorder event occurs.  Operation — Disruption of the energy supply unlikely due to underground cable and secure rural/ secure location of substation.	Screen out – loss of functionality to proposed development or short delay to programme only (few days), no impact on EIA topics/ receptors, including programme dependent aspects.
Malicious Attacks - Crowded places; Transport Systems; Infrastructure; Cyber Attacks; and Chemical, biological, radiological and nuclear	Yes – The Proposed Development would form a part of the UK's Energy Infrastructure. As such, it could be vulnerable to a malicious physical or cyber-attack. Physical attacks on infrastructure, including electricity substations, have occurred in the past. Cyber-attacks occur almost constantly and the	Construction and Decommissioning – potential for minor disruption to programme if public disorder event occurs.	Screen out – The Proposed Development would not form part of the UK's Critical National Infrastructure.  However, Considering the Proposed Development would form part of the UK's

PINS Ref.: EN020022

Document Ref.: Document Ref.: Environmental Statement Appendix 4.1 Screening for Major Accidents and Disasters

**AQUIND Limited** 



	Risk Register lists them as a top tier threat to the UK.	Operation – Disruption of the energy supply unlikely due to underground cable and secure rural/ secure location of substation.	energy infrastructure, it should be designed in accordance with current best practice in terms of protection from malicious attack.
Unexploded ordnance ('UXO')	No –  As outlined in the Ordtek Unexploded Ordnance Desk Based Study with Risk Assessment, the risk of UXO for the Onshore Cable Route and Converter Station can be managed to be as low as reasonably practicable with the implementation of the measures proposed in the report.  Identification of UXO in the Marine Cable Corridor will be undertaken as part of pre-construction surveys. If UXO are identified, clearance will be sought through a separate Marine Licence with the Marine Management Organisation ('MMO').	Construction and Decommissioning – Onshore and Marine Cable Corridor and the Converter Station.	Screen out –Considering the low residual risk of UXO in the vicinity of a densely populated area, there is low potential for damage to receptors.  Given the onshore studies to date, the risk to receptors is low.  UXO survey and clearance in the Marine Cable Corridor will also minimise risk to marine receptors.

PINS Ref.: EN020022

Document Ref.: Document Ref.: Environmental Statement Appendix 4.1 Screening for Major Accidents and Disasters

**AQUIND Limited** 



Electro-magnetic fields	Yes – The Proposed Development will produce static electric and magnetic fields.	Operation – Risk of public exposure to levels above those set by the UK Government.	Screen in – Chapter 26 (Human Health) of the ES Volume 1 (document reference 6.1.26).  Also see Chapter 3 (Description of the Proposed Development) of the ES Volume 1 (document reference 6.1.3).  A separate assessment is being prepared based on the UK voluntary Code of Practice (Department of Energy and Climate Change, 2012), which specifies that compliance should be specifically demonstrated for cables above 132 kV and substations containing aircored reactors.
Exposure to high voltage	Yes – The Proposed Development involves the transmission of high voltage electricity.	Commissioning - Risk of damage and/or harm during the commissioning of the Onshore and Marine	Screen in – Chapter 3 (Description of the Proposed Development), - The Proposed Development should be designed in accordance with current

PINS Ref.: EN020022

Document Ref.: Document Ref.: Environmental Statement Appendix 4.1 Screening for Major Accidents and Disasters

**AQUIND Limited** 



Cable Route and the Converter Station.

Operation – Risk of damage and/or harm during operation and maintenance of the Proposed Development.

best practice to reduce the risk of damage and/or harm to people and assets to an acceptable level.

PINS Ref.: EN020022

Document Ref.: Document Ref.: Environmental Statement Appendix 4.1 Screening for Major Accidents and Disasters

**AQUIND Limited** 



#### **REFERENCES**

- Cabinet Office. (2017). National Risk Register Of Civil Emergencies.
- Dawson, R. T. (2016). UK Climate Change Risk Assessment Evidence Report: Chapter 4, Infrastructure.
- Department of Energy and Climate Change. (2012). Power Lines: Demonstrating compliance with EMF public exposure guidelines. A Voluntary Code of Practice.
- HM Government. (2017). The Infrastructure Planning (Environmental Impact Assessment) Regulations.
- The Centre for the Study of Existential Risk, Cambridge University and The International Centre for Infrastructure Futures. (2017). "Black Sky" Infrastructure and Societal Resilience Workshop: Introductory Session Setting the Context Emerging Black Sky Hazards.

AQUIND INTERCONNECTOR

PINS Ref.: EN020022

Document Ref.: Environmental Statement Appendix 4.1 Screening for Major Accidents and Disasters

November 2019

