



AQUIND Limited

AQUIND INTERCONNECTOR

Environmental Statement – Volume 3 – Appendix 23.4 Air Quality Generator Emissions Modelling

The Planning Act 2008

The Infrastructure Planning (Applications: Prescribed Forms and Procedure) Regulations 2009 – Regulation 5(2)(a)

The Infrastructure Planning (Environmental Impact Assessment) Regulations 2017

Document Ref: 6.3.23.4

PINS Ref.: EN020022

AQUIND Limited

AQUIND INTERCONNECTOR

Environmental Statement – Volume 3 –
Appendix 23.4 Air Quality Generator
Emissions Modelling

PINS REF.: EN020022

DOCUMENT: 6.3.23.4

DATE: 14 NOVEMBER 2019

WSP

WSP House

70 Chancery Lane

London

WC2A 1AF

+44 20 7314 5000

www.wsp.com

DOCUMENT

Document	6.3.23.4 Environmental Statement – Volume 3 - Appendix 23.4 Air Quality Generator Emissions Modelling
Revision	001
Document Owner	WSP UK Limited
Prepared By	L. Shelton
Date	28 October 2019
Approved By	S. Bennett
Date	14 November 2019

CONTENTS

APPENDIX 23.4 AIR QUALITY GENERATOR EMISSIONS MODELLING	1
1.1. SCOPE OF THE ASSESSMENT	1
1.2. ASSESSMENT METHODOLOGY	2
1.3. PREDICTED IMPACTS	11
REFERENCES	25

TABLES

Table 1 – Emissions data for the HDD drilling generator model	4
Table 2 - EU Stage IV Emissions Standards	6
Table 3 - Permanent Effects Affected SSSI Units	10
Table 4 – Meteorological sensitivity modelling results based on ground level receptor grid results under ‘Worst-Case’ scenario emissions parameters	12
Table 5 - Do-Something Scenario results for modelled receptors (annual average)	13
Table 6 – Do-Something Scenario results for modelled receptors (24-hour PM₁₀ and max 8-hour CO)	14
Table 7 – Do-Something Scenario results for top 10 modelled receptors (1-hour NO₂)	15
Table 8 – Meteorological sensitivity modelling results based on ground level receptor grid results under ‘Worst-Case’ scenario emissions parameters	18
Table 9 – Do-Something Scenario results for modelled receptors (annual average)	19
Table 10 – Do-Something Scenario results for modelled receptors (24-hour PM₁₀ and max 8-hour CO)	20
Table 11 – Do-Something Scenario results for top 10 modelled receptors (1-hour NO₂)	21
Table 12 – NO_x Concentrations for the Eastney Lake SSSI Transect	22
Table 13 - NO_x Concentrations for the Langston Harbour West SSSI Transect	23

PLATES

Plate 1 - Indicative Receptors for Construction Local Power Generation Effects	5
Plate 2 - Permanent Effects Receptors	7
Plate 3 - Locations of Modelled Buildings	8
Plate 4 - 3D Representation of Modelled Buildings	9

APPENDIX 23.4 AIR QUALITY

GENERATOR EMISSIONS MODELLING

1.1. SCOPE OF THE ASSESSMENT

1.1.1. INTRODUCTION

1.1.1.1. This appendix details the methodology for the assessment of point emission sources involved with the construction and the permanent operation of the AQUIND Interconnector development.

1.1.2. STUDY AREA

1.1.2.1. The study areas for this assessment are defined as being a 1.5 km radius buffer from the point emissions source locations.

Horizontal Directional Drilling

1.1.2.2. Details were provided by the High Voltage Direct Current ('HVDC') engineering team on the predicted locations associated with Horizontal Directional Drilling ('HDD') operations. The HDD operation is predicted to involve the following:

- A diesel Power Pack to provide power to the drilling rig;
- A diesel-powered pump to remove mud, liquid and other detritus from the drill head;
- A diesel generator to run the mud recycling plant for processing material removed from the drill head; and
- A diesel generator to provide power for the site office and welfare facilities.

The predicted locations cross the following sections:

- Section 2;
- Section 3;
- Section 3;
- Section 6;
- Section 7;
- Section 8;
- Section 9; and

- Section 10.

Fibre Optic Cable Facility

- 1.1.2.3. Backup generators are to be provided at the Fibre Optic Cable ('FOC') facility at the landfall site to provide filtering and signal boost to fibre-optic cables that accompany the HVDC cables in the event of a power outage. The FOC facility is located in the Fort Cumberland Road car park in Section 10 as shown in Figure 23.5 of the ES Volume 2 (document reference 6.2.23.5).
- 1.1.2.4. The power rating of the generators is not yet determined, with estimates ranging between 50 kVA and 200 kVA.

1.2. ASSESSMENT METHODOLOGY

- 1.2.1.1. This section describes the methodology used for the derivation of emission factors and calculation of pollutant concentrations resulting from the operation of diesel power generators. For both the operation and construction stages, the following pollutants were modelled in the assessment:

- Nitrogen oxides (NO_x)
- Nitrogen dioxide (NO₂)
- Carbon monoxide (CO)
- Particulate matter (PM₁₀)
- Total hydrocarbons (THC)

- 1.2.1.2. Sulphur Dioxide (SO₂) is not assessed because ultra-low sulphur diesel will be used. Exhaust gas concentrations of general particulate matter were provided. Therefore, PM_{2.5} is assumed to equal PM₁₀ for comparison with the target value. This represents a conservative approach because as the exhaust gas concentration of the finer particle fraction PM_{2.5} will be lower than PM₁₀. THC were modelled as benzene which represents a conservative approach because no objective or limit value exists for THC. Therefore, benzene was selected for modelling as a limit value is prescribed for this particular hydrocarbon pollutant as shown in Chapter 23 (Air Quality) of the ES Volume 1 (document reference 6.1.23). It should be noted however that the toxicity of benzene in air is of a different nature to THC, particularly as benzene is a documented carcinogen (Chilcott, 2007). Therefore, the equivalent level of carcinogenesis should not be inferred from the results presented here.

1.2.2. CONSTRUCTION STAGE

Local Power Generation for HDD Operations

1.2.2.1. Following consultation with the Environmental Health Officers ('EHO') for Havant Borough Council ('HBC') and Portsmouth City Council ('PCC'), all power generating locations were scoped in to the assessment.

1.2.2.2. Modelling was undertaken using information provided by the WSP Engineering and HVDC Cabling Teams, and specialist advice regarding HDD works.

Embedded Mitigation

1.2.2.3. Operation of the generators is subject to the embedded mitigation measures for air quality detailed in the CEMP regarding operation, efficiency and maintenance. Any generators are subject to the minimum EU Emissions Stage requirements from the local Environmental Health Department.

Generator Characteristics

1.2.2.4. The information in Table 1 was provided for the HDD drilling operations, corrected for percentage of oxygen in the exhaust (%O₂) and temperature. No corrections were required for differences in water content as dry exhaust gas figures were provided, or for pressure.

Table 1 – Emissions data for the HDD drilling generator model

	Pump	Recycling*	Welfare**	PowerPack
Exhaust Mass Flow (m³/min)	31.8	30.3	13.0	37.3
Exit Velocity (m/s)	2.51	5.76	2.99	4.95
Exhaust Temperature (°C)	546.7	486.6	540.0	485.7
Exhaust Diameter (m)[†]	0.152	0.152	0.152	0.152
NO_x (mg/Nm³)	0.09	0.106	0.004	0.20
CO (mg/Nm³)	0.07	0.042	0.056	0.07
Hydrocarbons (mg/Nm³)	0.002	0.006	0.002	0.003
Particulate Matter (mg/Nm³)	0.0055	0.0101	0.0003	0.0093

* Emissions for the recycling plant were not supplied and so were derived from the data sheet for the PowerPack.

** Emissions for the Welfare generator were not supplied and so were derived from a standard 50kVA generator.

† The reference exhaust diameter for the PowerPack was used for all emission sources as no other information was supplied.

- 1.2.2.5. Following consultation with a drilling specialist, air quality modelling was undertaken at four out of the six drilling predicted locations due to the availability of information on the equipment that would be used on-site and the fact that any appointed drilling contractor might sub-contract or hire specific equipment for the smaller drilling operations.
- 1.2.2.6. The operating hours of all of the generators was considered to be between the hours of 0700 and 1900, Monday to Sunday during the predicted periods of operation.
- 1.2.2.7. Due to the short-term, temporary nature of the operation of the diesel generators, the 1-hourly (99.08th percentile) and 24-hourly (90.41th percentile) were reported.

Operation Stage Modelled Year

- 1.2.2.8. The operational modelled year was determined based on the meteorological data sensitivity testing. Model runs were undertaken for each of five years of meteorological data between 2014 and 2018. The worst-case year from the ADMS outputs was found to be 2014, so all of the results from this year are presented.

Receptors

- 1.2.2.9. Receptors were selected within a 1.5 km radius of each of the supplied predicted generator locations. Receptors were identified using the Ordnance Survey AddressBase Plus dataset and modelled at a height above ground of 1.5 m, as shown in Plate 1.




Plate 1 - Indicative Receptors for Construction Local Power Generation Effects

1.2.3. OPERATIONAL STAGE

FOC Back-Up Power Generation

Embedded Mitigation

1.2.3.1. Detailed information regarding the installation of the backup power generators at the FOC building was unavailable due to the stage of the design. Therefore, the emission limits from the EU Stage VI Q emissions standards were used, as shown in Table 2. As a new generator installation after the construction year of 2026, the generator will be required to meet this standard as a minimum, barring the introduction of further, more stringent emissions standards during the intervening period.

Generator Characteristics

1.2.3.2. Specifications for the backup generators ranged from two 50 kVA generators up to two 200 kVA generators. Modelling was undertaken for two 200 kVA generators as a conservative approach.

1.2.3.3. The conditions for the EU Stage VI Q emissions standards i.e. the operating temperature, pressure and %O₂ were applied to the equipment being modelled.

Table 2 - EU Stage IV Emissions Standards

Cat.	Net Power	Date (on sale)	CO	HC	NO _x	PM
	kW		g/kW			
Q	130 ≤ P ≤ 560	January 2014	3.5	0.19	0.4	0.025

1.2.3.4. The following additional data was used based on sample generator data sheets provided:

- Exhaust diameter – 0.15 m (assumed based on HDD generators);
- Exhaust mass flow – 35.8 m³/min; and
- Exhaust temperature – 561 °C.

1.2.3.5. The operation of this facility is dependent on the occurrence of power outages that might affect its ability to boost or process the fibre-optic signal in the cables. Specialist advice was sought on the possibility of power outages and the likely longest repair time to restore mains electricity. The number of expected power outages in any 12-month period is expected on no more than six occasions and for a maximum period of 24-hours.

1.2.3.6. Mandatory testing of the generating units will also take place for a duration of 1-hour on one occasion per year.

1.2.3.7. Based on the predicted operation of the generators the model represented the generators running continuously for 8,760 hours (or 8,784 hours), and the ten highest 1-hour means (99.79th percentile) were reported.

Operational Stage Modelled Year

1.2.3.8.

In order that a robust assessment could be undertaken, five years of meteorological data between 2014 and 2018 were used for the assessment of permanent effects from the FOC backup generators. This ensures that predictions are based upon the worst dispersion conditions experienced between 2014 and 2018 which is a conservative approach. The measuring station at Thorney Island Airport was used, with missing cloud cover filled in from the station at Southampton International Airport. Modelling was undertaken for each of the five years for which meteorological data had been obtained and the worst-case concentrations reported.

Receptors

1.2.3.9.

Receptors were selected within a 1.5 km radius of each of the supplied predicted generator locations. Receptors were identified using the Ordnance Survey AddressBase Plus dataset and modelled at a height above ground of 1.5 m, as shown in Plate 2. Two 200 m transects were also modelled within the Langston Harbour SSSI, also shown in Plate 2.




Plate 2 - Permanent Effects Receptors

Buildings

- 1.2.3.10. Buildings were not included for the modelling of temporary construction effects resulting from the operation of diesel power.
- 1.2.3.11. For the modelling of the permanent effects from the operation of the FOC backup generators, a number of buildings were modelled according to the prevailing wind direction and presence of local sensitive receptors. These are shown in Plate 3 and Plate 4.





Plate 3 - Locations of Modelled Buildings



Reproduced from Ordnance Survey digital map data © Crown copyright 2019. All rights reserved. Licence number 0100031673.
© [OpenStreetMap](#) contributors

Plate 4 - 3D Representation of Modelled Buildings

Results Processing

- 1.2.3.12. For the construction and operation stages, modelled concentration predictions for NO_x were post processed according to the Environment Agency guidance note on the conversion ratios for NO_x and NO₂ (Air Quality Modelling and Assessment Unit, 2006). Predicted concentrations for NO_x were converted on the basis that the impacts are all short-term in nature, and so NO₂ was expressed as 35 % of the predicted NO_x concentration.

Ecological Effects

- 1.2.3.13. The effects on Langston Harbour SSSI have been modelled for the two 200 m transects perpendicular to the SSSI boundary within the areas affected by prevailing winds. The two particular SSSI units affected are shown in Table 3.

Table 3 - Permanent Effects Affected SSSI Units

Unit ID	Unit Name	Habitat	Condition	N Dep Critical Load (kgN/ha/yr)	CLminN	CLmaxN
1019415	Eastney Lake	Littoral Sediment	Unfavourable - Recovering	20 - 30	-	-
1007445	Langston Harbour West	Littoral Sediment	Favourable	20 - 30	-	-

1.2.3.14. Results processing was undertaken following the AQTAG06 guidance (Environment Agency AQMAU, 2006).

1.2.3.15. Deposition flux was determined using the formula:

$$\text{Dry deposition Rate} = \text{Ground Level Concentration} \times \text{Deposition Velocity}$$

$$(\mu\text{g}/\text{m}^2/\text{s}) \quad (\mu\text{g}/\text{m}^3) \quad (\text{m}/\text{s})$$

1.2.3.16. A deposition velocity of 0.0015 m/s was selected for NO₂ based on the recommended deposition velocity from AQTAG06 for grassland. Whilst the habitat of Langston Harbour SSSI is not grassland, the flat characteristics of the bay are more reflective of grassland than the alternative forest habitat in AQTAG06.

1.2.3.17. Dry deposition flux of N from NO₂ is converted from the units of μg/m²/s to kgN/ha/yr for N deposition using the conversion factor 95.9, and to keq/ha/yr for acidification using the conversion factor 6.84.

1.2.3.18. Changes in composition were reported in comparison to the background contribution to deposition which was obtained from the Air Pollution Information system (APIS) website (Centre for Ecology and Hydrology, 2019), and reported according to the IAQM ecological site assessment guidance (Holman, et al., 2019).

1.2.4. DECOMMISSIONING

1.2.4.1. Works for decommissioning are expected to be equivalent to those involved in construction. The methodology for assessing the air quality effects of decommissioning is the same as that described for the construction stage with updated data based on the numbers of receptors present should these change significantly over the lifetime of the infrastructure.

1.3. PREDICTED IMPACTS

1.3.1. CONSTRUCTION STAGE LOCAL POWER GENERATION

Embedded Mitigation

- 1.3.1.1. Mitigation is embedded in the Proposed Development design through the use of generators which conform to a minimum of EU Stage III emissions standards for non-road diesel engines.

Description of Works

- 1.3.1.2. Diesel will be the source of fuel burned in generators to provide power for the HDD and FOC installation activities described in Chapter 23 (Air Quality). It has been confirmed by the proposed HDD contractor that the shift pattern for construction activities will be 12 hours (0700-1900) working 7 days per week with all HDD combustion sources operating accordingly.
- 1.3.1.3. Exhaust gas pollutant concentrations were available from example manufacturer specifications for the specified power generation equipment. These pollutants are nitrogen oxides, carbon monoxide, particulate matter and total hydrocarbons.
- 1.3.1.4. Pollutant concentrations have been predicted at the discrete receptors within 1.5 km of the expected locations of the diesel generators using the OS AddressBase Plus dataset. The relevant national air quality limits and objective values are prescribed in the national AQS as described in Chapter 23 (Air Quality).

Impacts

Meteorological Sensitivity

- 1.3.1.5. To test the sensitivity of the predicted concentrations in the construction stage to variable dispersion conditions, five years of meteorological data were tested to identify which year provides the most conservative dispersion conditions. The results of the meteorological sensitivity testing are presented for five years of hourly sequential data (2014 – 2018) for the main pollutant of concern which is NO_x/NO₂.
- 1.3.1.6. The top 10 annual mean and 99.79th percentile of hourly NO_x concentrations, based on the discrete receptor results, are presented for each modelled year under the worst-case scenario emissions parameters in Table 4.

Table 4 – Meteorological sensitivity modelling results based on ground level receptor grid results under ‘Worst-Case’ scenario emissions parameters

Ranked Value	NO _x concentration (µg/m ³)									
	2014		2015		2016		2017		2018	
	Annual	Hourly*	Annual	Hourly*	Annual	Hourly*	Annual	Hourly*	Annual	Hourly*
1	5.3	84.8	3.2	72.1	4.3	72.3	3.8	80.5	3.3	72.6
2	5.3	84.8	3.2	70.8	4.2	72.3	3.8	80.5	3.3	72.6
3	4.6	81.6	2.8	70.8	4.2	72.2	3.3	69.8	3.0	68.4
4	4.6	77.2	2.7	69.5	4.1	70.4	3.3	69.8	3.0	66.5
5	4.2	74.9	2.7	69.2	4.1	70.2	2.9	67.7	2.9	64.8
6	4.2	74.9	2.6	65.8	4.0	66.0	2.9	62.8	2.9	64.6
7	4.1	73.7	2.6	64.0	4.0	63.8	2.5	61.7	2.8	63.6
8	4.1	73.6	2.6	61.7	3.7	63.8	2.5	61.7	2.8	62.9
9	4.0	70.8	2.6	61.0	3.7	63.2	2.3	60.5	2.6	62.9
10	4.0	70.2	2.6	61.0	3.6	63.0	2.3	58.1	2.6	62.1

* 99.79th percentile of hourly means. Bold value indicates year with highest concentration

1.3.1.7. A review of the results in Table 4 for the top 10 ranked discrete receptors in each year shows that most of the highest annual mean and all of the 99.79th percentile hourly mean NO_x concentrations occur in 2014, thus demonstrating that this year yields the most conservative dispersion conditions of the years tested.

1.3.1.8. As such, hourly sequential data for 2014 from the Thorney Island meteorological station were used within all subsequent model scenario runs.

Impact Assessment

1.3.1.9. The results of the dispersion modelling are presented in tabular format for the likely construction phase scenario. Impacts are considered on human receptors as identified by the discrete receptor locations included in the model.

1.3.1.10. A summary of the predicted annual and short-term NO₂, CO, THC, PM₁₀ and PM_{2.5} results at the modelled discrete receptors are presented in Table 5, Table 6 and Table 7 show the maximum predicted concentration for each pollutant and averaging period and an interpretation of the magnitude of impact following the IAQM Planning guidance (Moorcroft, et al., 2017).

Table 5 - Do-Something Scenario results for modelled receptors (annual average)

Statistic	NO ₂	THC	PM ₁₀	PM _{2.5} **
Maximum Annual Mean PC (µg/m ³)	5.3	0.2	0.4	0.4
Maximum Annual Mean PEC (PC + Background) (µg/m ³)	17.3	0.6	14.0	11
AQAL (µg/m ³)	40	5*	40	25***
Change relative to AQAL (%)	13%	5%	1%	2%
IAQM impact magnitude	Moderate	Negligible	Negligible	Negligible

* Annual average AQLA for benzene

** The exhaust gas concentrations provided by generator manufacturers did not differentiate between PM₁₀ and PM_{2.5}. PM results are therefore assessed against the PM₁₀ and PM_{2.5} objectives.

*** Target value

1.3.1.11. Table 5 shows that the annual average objectives for NO₂, THC, PM₁₀ and PM_{2.5} will not be exceeded during construction at any of the sensitive receptors. The largest predicted increase relative to the AQAL is 13 % for NO₂ and the largest receptor concentration inclusive of background will be 17.3 µg/m³ for NO₂. Although this is a **moderate** impact in accordance with the IAQM criteria, it is 43 % of the annual mean objective.

Table 6 – Do-Something Scenario results for modelled receptors (24-hour PM₁₀ and max 8-hour CO)

Statistic (PC and PEC as µg/m ³)	CO	PM ₁₀
Max. Percentile PC (90.4 th daily PM ₁₀ and max daily 8-hour running mean CO)	5.0	1.8
Exceedance days	-	0
AQAL	10,000	50
IAQM impact magnitude	Negligible	Negligible

- 1.3.1.12. Table 6 shows that the highest 8-hour running mean CO concentration is 5.0 µg/m³ which is less than 1% of the AQLA. The 90.4th percentile daily mean PM₁₀ concentration is predicted to be 1.8 µg/m³ which is **negligible** in comparison to the AQAL.

Table 7 – Do-Something Scenario results for top 10 modelled receptors (1-hour NO₂)

Statistic (µg/m ³)	1	2	3	4	5	6	7	8	9	10
X	467836	467836	467810	467804	467834	467834	467853	467799	467866	467844
Y	99194	99194	99175	99173	99199	99199	99072	99172	99068	99075
Max. Percentile PC (99.79 th hourly NO ₂)	84.8	84.8	81.6	77.2	74.9	74.9	73.7	73.6	70.8	70.2
AQAL (µg/m³)	200	200	200	200	200	200	200	200	200	200
Change relative to AQAL (%)	42	42	41	39	37	37	37	37	35	35
IAQM impact magnitude	Moderate									

1.3.1.13. Table 7 shows that the highest 1-hour NO₂ concentration is 84.8 µg/m³ which is 42 % of the AQAL. The top ten 1-hour NO₂ concentrations range from 35-42 % of the AQAL. These are **moderate** impacts in accordance with the IAQM criteria.

Significance

- 1.3.1.14. The IAQM impact assessment process provides impact descriptor guidance to inform the significance judgement which varies depending on the pollutant and averaging period assessed. Negligible impacts are predicted for THC, PM₁₀ and PM_{2.5} and moderate impacts for both annual average and 1-hour NO₂ in accordance with the IAQM criteria. However, the predicted maximum annual average NO₂ concentration is under half of the objective and exceedances of the 1-hour objective are unlikely even assuming conservative operating hours and the temporary nature of the works as described in Chapter 23 (Air Quality).
- 1.3.1.15. Therefore, the effect of changes in local air quality as a result of construction phase local power generation is assessed as a **minor adverse significant** effect.

1.3.2. OPERATIONAL STAGE LOCAL POWER GENERATION

Embedded Mitigation

- 1.3.2.1. Due to detailed emissions information not being available, the emissions from the EU Stage VI Q emissions standards were used, as shown in Table 2. As a new generator installation after the construction year of 2026, the generator will be required to meet this standard at a minimum, barring the introduction of further, more stringent emissions standards during the intervening period.

Description of Works

- 1.3.2.2. Diesel will be the source of fuel burned in generators to provide back-up power for the landfall activities described in Chapter 23 (Air Quality). The generators will operate between the hours of 0700 and 1900 daily.
- 1.3.2.3. The pollutants considered in the quantitative assessment of local air quality are those for which exhaust gas concentrations were available from example manufacturer specifications. These are the same as those for the construction phase local power generation assessment.
- 1.3.2.4. Pollutant concentrations have been predicted at the discrete receptors described in within 1.5 km of the predicted generator locations using the OS AddressBase Plus dataset. The relevant national air quality limits and objective values are prescribed in the national AQS as described in Chapter 23 (Air Quality).

Impacts

Meteorological Sensitivity

- 1.3.2.5. To test the sensitivity of the predicted concentrations in the operational phase to variable dispersion conditions, five years of meteorological data were tested to identify which year provides the most conservative dispersion conditions. The results of the meteorological sensitivity testing are presented for five years of hourly sequential data (2014 – 2018) for the main pollutant of concern which is NO_x/NO₂.

- 1.3.2.6. The top 10 annual mean and 99.79th percentile of hourly NO_x concentrations, based on the discrete receptor results, are presented for each modelled year under the worst-case scenario emissions parameters.

Table 8 – Meteorological sensitivity modelling results based on ground level receptor grid results under ‘Worst-Case’ scenario emissions parameters

Ranked Value	NO _x concentration (µg/m ³)									
	2014		2015		2016		2017		2018	
	Annual	Hourly*	Annual	Hourly*	Annual	Hourly*	Annual	Hourly*	Annual	Hourly*
1	1.8	9.3	1.7	9.6	1.6	9.4	1.6	9.5	1.7	9.4
2	1.7	8.9	1.7	8.8	1.5	8.9	1.6	9.1	1.6	9.0
3	1.7	8.8	1.5	8.6	1.5	8.7	1.6	8.6	1.6	9.0
4	1.6	8.7	1.4	8.6	1.5	8.7	1.4	8.4	1.6	8.8
5	1.5	8.6	1.4	8.4	1.5	8.5	1.3	8.3	1.6	8.7
6	1.5	8.4	1.3	8.3	1.3	8.4	1.3	8.3	1.4	8.5
7	1.4	8.3	1.3	8.3	1.3	8.3	1.2	7.9	1.4	8.0
8	1.4	8.1	1.3	7.8	1.3	7.7	1.2	7.7	1.4	8.0
9	1.4	7.8	1.2	7.8	1.2	7.7	1.2	7.6	1.4	7.7
10	1.4	7.8	1.2	7.8	1.2	7.5	1.0	7.6	1.3	7.7

* 99.79th percentile of hourly means. Bold value indicates year with highest concentration

1.3.2.7. A review of the results for the top 10 ranked discrete receptors in each year shows that most of the highest annual mean and all of the 99.79th percentile hourly mean NO_x concentrations occur in 2014, thus demonstrating that this year yields the most conservative dispersion conditions of the years tested.

1.3.2.8. As such, hourly sequential data for 2014 from the Thorney Island meteorological station were used within all subsequent model scenario runs.

Impact Assessment

1.3.2.9. The results of the dispersion modelling are presented in tabular format for the likely construction phase scenario. Impacts are considered on human receptors as identified by the discrete receptor locations included in the model.

1.3.2.10. A summary of the predicted annual and short-term NO₂, CO, THC, PM₁₀ and PM_{2.5} results at the modelled discrete receptors are presented in Table 5, Table 6 and Table 7 show the maximum predicted concentration for each pollutant and averaging period and an interpretation of the magnitude of impact following the IAQM Planning guidance (Moorcroft, et al., 2017).

Table 9 – Do-Something Scenario results for modelled receptors (annual average)

Statistic	NO ₂	THC	PM ₁₀	PM _{2.5} **
Maximum Annual Mean PC (µg/m ³)	1.8	1.2	0.2	0.2
Maximum Annual Mean PEC (PC + Background) (µg/m ³)	13.8	1.6	13.7	10
AQAL (µg/m ³)	40	5*	40	25***
Change relative to AQAL (%)	4%	24%	0.4%	1%
IAQM impact magnitude	Negligible	Moderate	Negligible	Negligible

* Annual average AQLA for benzene

** The exhaust gas concentrations provided by generator manufacturers did not differentiate between PM₁₀ and PM_{2.5}. PM results are therefore assessed against the PM₁₀ and PM_{2.5} objectives.

*** Target value

1.3.2.11. Table 9 shows that the annual average objectives for NO₂, THC, PM₁₀ and PM_{2.5} will not be exceeded during construction at any of the sensitive receptors. The largest predicted increase relative to the AQAL is 24 % for THC and 4 % for NO₂. largest receptor concentration inclusive of background will be 17.3 µg/m³ for NO₂. Although this is a **moderate** impact in accordance with the IAQM criteria, it is just 24 % of the annual mean objective and no exceedances are likely.

Table 10 – Do-Something Scenario results for modelled receptors (24-hour PM₁₀ and max 8-hour CO)

Statistic (PC and PEC as µg/m ³)	CO	PM ₁₀
Max. Percentile PC (90.4th daily PM ₁₀ and max daily 8-hour running mean CO)	22.1	0.5
Exceedance days	-	0
AQAL	10,000	50
IAQM impact magnitude	Negligible	Negligible

- 1.3.2.12. Table 10 shows that the highest 8-hour running mean CO concentration is 22.1 µg/m³ which is less than 1 % of the AQLA. The 90.4th percentile daily mean PM₁₀ concentration is predicted to be 0.5 µg/m³ which is **negligible** in comparison to the AQAL.

Table 11 – Do-Something Scenario results for top 10 modelled receptors (1-hour NO₂)

Statistic (µg/m ³)	1	2	3	4	5	6	7	8	9	10
X	467810	467804	467797	467799	467805	467786	467815	467792	467836	467836
Y	99175	99173	99089	99172	99086	99093	99083	99171	99194	99194
Max. Percentile PC (99.79 th hourly NO ₂)	9.3	8.9	8.8	8.7	8.6	8.4	8.3	8.1	7.8	7.8
AQAL (µg/m³)	200	200	200	200	200	200	200	200	200	200
Change relative to AQAL (%)	5	4	4	4	4	4	4	4	4	4
IAQM impact magnitude	Negligible									

1.3.2.13. Table 11 shows that the highest 1-hour NO₂ concentration is 84.8 µg/m³ which is 42 % of the AQAL. The top ten 1-hour NO₂ concentrations range from 35-42 % of the AQAL. These are **moderate** impacts in accordance with the IAQM criteria.

1.3.3. ECOLOGICAL SITE ASSESSMENT

1.3.3.1. The results for the calculations of NO_x concentrations for the Eastney Lake unit of the Langston Harbour SSSI are shown in Table 12.

Table 12 – NO_x Concentrations for the Eastney Lake SSSI Transect

ID	NO _x PC (Annual)	NO _x Background (Defra)	NO _x PEC	% Change	IAQM Impact
SSSI1_0	0.11	15.95	16.05	0.69	Negligible
SSSI1_10	0.10	15.95	16.05	0.62	Negligible
SSSI1_20	0.09	15.95	16.04	0.56	Negligible
SSSI1_30	0.09	15.95	16.04	0.56	Negligible
SSSI1_40	0.08	15.95	16.03	0.5	Negligible
SSSI1_50	0.08	15.95	16.03	0.5	Negligible
SSSI1_60	0.08	15.95	16.02	0.5	Negligible
SSSI1_70	0.07	15.95	16.02	0.44	Negligible
SSSI1_80	0.07	15.95	16.01	0.44	Negligible
SSSI1_90	0.06	15.95	16.01	0.37	Negligible
SSSI1_100	0.06	15.95	16.01	0.37	Negligible
SSSI1_110	0.06	15.95	16.00	0.38	Negligible
SSSI1_120	0.05	15.95	16.00	0.31	Negligible
SSSI1_130	0.05	15.95	16.00	0.31	Negligible
SSSI1_140	0.05	15.95	16.00	0.31	Negligible
SSSI1_150	0.05	15.95	15.99	0.31	Negligible
SSSI1_160	0.04	15.95	15.99	0.25	Negligible
SSSI1_170	0.04	15.95	15.99	0.25	Negligible
SSSI1_180	0.04	15.95	15.99	0.25	Negligible
SSSI1_190	0.04	15.95	15.99	0.25	Negligible
SSSI1_200	0.04	15.95	15.98	0.25	Negligible

1.3.3.2. The results for the calculations of NO_x concentrations for the Langston Harbour West unit of the Langston Harbour SSSI are shown in Table 13e 13.

Table 13 - NO_x Concentrations for the Langston Harbour West SSSI Transect

ID	NO _x PC (Annual)	NO _x Background (Defra)	NO _x PEC	% Change	IAQM Impact
SSSI2_0	0.04	13.81	13.85	0.29	Negligible
SSSI2_10	0.04	13.81	13.85	0.29	Negligible
SSSI2_20	0.04	13.81	13.85	0.29	Negligible
SSSI2_30	0.04	13.81	13.85	0.29	Negligible
SSSI2_40	0.04	13.81	13.85	0.29	Negligible
SSSI2_50	0.04	13.81	13.85	0.29	Negligible
SSSI2_60	0.03	13.81	13.85	0.22	Negligible
SSSI2_70	0.03	13.81	13.85	0.22	Negligible
SSSI2_80	0.03	13.81	13.85	0.22	Negligible
SSSI2_90	0.03	13.81	13.85	0.22	Negligible
SSSI2_100	0.03	13.81	13.85	0.22	Negligible
SSSI2_110	0.03	13.81	13.85	0.22	Negligible
SSSI2_120	0.03	13.81	13.84	0.22	Negligible
SSSI2_130	0.03	13.81	13.84	0.22	Negligible
SSSI2_140	0.03	13.81	13.84	0.22	Negligible
SSSI2_150	0.03	13.81	13.84	0.22	Negligible
SSSI2_160	0.03	13.81	13.84	0.22	Negligible
SSSI2_170	0.03	13.81	13.84	0.22	Negligible
SSSI2_180	0.03	13.81	13.84	0.22	Negligible
SSSI2_190	0.03	13.81	13.84	0.22	Negligible
SSSI2_200	0.03	13.81	13.84	0.22	Negligible

- 1.3.3.3. The NO_x concentration results shown in Table 12 and Table 12 show that the NO_x PEC along the entire length of both transects within the Langston Harbour SSSI are below the limit value of 30 µg/m³ for the protection of vegetation, and below 70 % of the long term average limit value according to the IAQM designed site assessment guidance (Holman, et al., 2019). All of the predicted PC changes are less than 1% of the background concentration.

Significance

- 1.3.3.4. All of the predicted changes for permanently operating generator emissions range from negligible to moderate according to the IAQM impact assessment criteria, which would return a moderate to major significance according to Chapter 23 (Air Quality). However, given the conservative approach to the assessment adopted, and temporary, short-term nature of operational emissions from the FOC backup generators, it is determined that the overall significance for diesel generator operation should be **negligible adverse**.

REFERENCES

- Air Quality Modelling and Assessment Unit. (2006). *Conversion Ratios for NO_x and NO₂*. Environment Agency.
- Centre for Ecology and Hydrology. (2019). *Air Pollution Information System*. Retrieved from Air Pollution Information System: <http://www.apis.ac.uk/>
- Chilcott, R. P. (2007). *Benzene Toxicological Review*. Health Protection Agency.
- Department for Environment, Food & Rural Affairs. (2019, May). *Emissions Factors toolkit*. Retrieved from GOV.UK: <https://laqm.defra.gov.uk/review-and-assessment/tools/emissions-factors-toolkit.html>
- Department for Environment, Food and Rural Affairs. (2019, October). *Roadside NO₂ Projection Factors*. Retrieved from GOV.UK.
- Department for the Environment, Food & Rural Affairs. (2019, May). *NO_x to NO₂ Calculator*. Retrieved from GOV.UK: <https://laqm.defra.gov.uk/review-and-assessment/tools/background-maps.html#NOxNO2calc>
- Environment Agency AQMAU. (2006). *AQTAG06 Technical guidance on detailed modelling approach for an appropriate assessment for emissions to air*. London: Environment Agency.
- Havant Borough Council. (2019). *2018 Air Quality Annual Status Report (ASR)*. Havant: Havant Borough Council.
- Holman, C., Barrowcliffe, R., Harker, G., Hawkings, C., Horrocks, S., & Prismall, F. (2019). *A guide to the assessment of air quality impacts on designated nature conservation sites v1.0*. London: Institute of Air Quality Management. Retrieved from <https://iaqm.co.uk/text/guidance/air-quality-impacts-on-nature-sites-2019.pdf>
- Institute of Air Quality Management. (2016). *Guidance on the assessment of dust from demolition and construction*. London: Institute of Air Quality Management.
- Moorcroft, S., Barrowcliffe, R., Cartmell, P., Chapman, M., Coakley, B., Conlan, B., . . . Young, A. (2017). *Land Use And Development Development Control: Planning For Air Quality v1.2*. London: Institute of Air Quality Management.
- Planning Inspectorate. (2016). Advice note six: Preparation and submission of application documents.
- Portsmouth City Council. (2019). *2019 Air Quality Annual Status Report (ASR)*. Portsmouth: Portsmouth City Council.

The Highways Agency. (2007). *Design Manual for Roads and Bridges, Volume 11 Environmental Assessment, Section 3 Environmental Assessment Techniques, Part 1 HA 207/07 Air Quality*. The Stationery Office Ltd.

