

The Secretary of State
c/o The Planning Inspectorate
Temple Quay House
2 The Square, Temple Quay
Bristol
BS1 6PN

BY EMAIL

17 February 2025

Your Reference EN020035

Dear Sir/Madam,

**Section 46 Planning Act 2008
Duty to notify Secretary of State of a proposed application
Green GEN Vyrnwy Frankton Connection**

Green Generation Energy Networks Cymru Limited (Green GEN Cymru) (the "Applicant") is writing to provide formal notification under section 46(1) of the Planning Act 2008 (the "Act"), of its intention to start a statutory consultation under section 42 and section 47 of the Act for the Vyrnwy Frankton Connection ('the Project'). Green GEN Cymru proposes to develop a new 132 kilovolt (kV) electricity distribution connection from a collector substation near Cefn Coch in Powys to the national electricity transmission network near Lower Frankton in Shropshire. The connection would connect new renewable energy generation in Powys to the national electricity network for supply to homes and businesses.

The consultation period is due to start on Wednesday 19 February 2025 and runs until 11:59pm on Wednesday 16 April 2025.

In accordance with section 46(1) of the Act, the Applicant hereby supplies the Secretary of State with the materials that will be provided to the section 42 consultees, as follows:

- Copies of the letters sent to section 42 consultees
- A copy of the notice published in accordance with section 48 of the Act. This notice includes details of public consultation events where the consultation material can be inspected free of charge and
- Consultation feedback questionnaire

All consultees have been provided with a link to the Project website where the consultation documents can be downloaded:

<https://greengenvyrnwyfrankton.com/>

This is where the full suite of consultation documents can be downloaded. These include:



- Vyrnwy Frankton Connection – Consultation Brochure
- Vyrnwy Frankton Connection – Feedback Form
- Vyrnwy Frankton Connection – Consultation event programme
- Vyrnwy Frankton Connection – Statement of Community Consultation
- Vyrnwy Frankton Connection – 2023 Non-statutory Consultation Feedback Report
- Vyrnwy Frankton Connection – Preliminary Environmental Information Report
- Vyrnwy Frankton Connection – Preliminary Environmental Information Report – Appendices
- Vyrnwy Frankton Connection – Preliminary Environmental Information Report – Figures
- Vyrnwy Frankton Connection – Preliminary Environmental Information Report – Non-Technical Summary
- Vyrnwy Frankton Connection – Location Plan
- Vyrnwy Frankton Connection – Consultation Plans
- Vyrnwy Frankton Connection – Typical Layouts Construction
- Vyrnwy Frankton Connection – Typical Tower and Foundation Designs
- Vyrnwy Frankton Connection – Indicative Site Layouts
- Vyrnwy Frankton Connection – Grid Connection Strategy Phase 3
- Vyrnwy Frankton Connection – Route Alignment Document
- Vyrnwy Frankton Connection – Guide to the Plans

Further details of the consultation arrangements are set out in the SoCC and can be found in the enclosed section 48 Notice and on the Project website. Preparation of the SoCC was informed by the views of host local authorities (Powys County Council and Shropshire Council) and, as required by section 47 of the Act, notice of publication of the SoCC is being published in relevant newspapers.

In accordance with Regulation 13 of The Infrastructure Planning (Environmental Impact Assessment) Regulations 2017 (the "EIA Regulations") a copy of the section 48 Notice will be sent to the consultation bodies (as defined in the EIA Regulations).

If you have any queries or require any additional information, please do not hesitate to contact us at the address below. I would be grateful for acknowledgement that this notice has been received as a record of compliance.

Yours faithfully

Sean Taylor Digitally signed by Sean Taylor
Date: 2025.02.17 15:41:16 Z

Sean Taylor
Senior Project Manager
[REDACTED]@greengencymru.com
Mobile: [REDACTED]

Name Surname
Address line one
Address line two
City
Postcode

Dear

Green GEN Cymru Vyrnwy Frankton Project

Statutory consultation under section 42 of the Planning Act 2008 and the Infrastructure Planning (Applications: Prescribed Forms and Procedures) Regulations 2009 (the APFP Regulations)

Notification under Regulation 13 of the Infrastructure Planning (Environmental Impact Assessment) Regulations 2017 (the EIA Regulations)

GREEN GENERATION ENERGY NETWORKS CYMRU LIMITED (Green GEN Cymru) will launch a statutory consultation in accordance with sections 42, 47 and 48 of the Planning Act 2008 (the Act) for its Vyrnwy Frankton connection (the "Project") from **19 February to 16 April 2025**.

Green GEN Cymru proposes to develop a new 132 kilovolt (kV) electricity distribution connection from a collector substation near Cefn Coch in Powys to the national electricity transmission network near Lower Frankton in Shropshire. The connection would connect new renewable energy generation in Powys to the national electricity network for supply to homes and businesses.

The Project comprises:

- A new 132 kV collector substation near Cefn Coch, Powys, known as the Grug y Mynydd substation
- Approximately 4.8km of underground cable from Grug y Mynydd substation through the proposed Llyn Lort Energy Park to a cable sealing end compound at Cors y Carreg
- The Cors y Carreg cable sealing end compound would enable the transition between underground cables and overhead conductors
- Approximately 45km of new overhead line supported on L7(c) steel lattice pylons (average height of 28.5m) from Cors y Carreg sealing end compound through the Vyrnwy Valley to a new switching station
- A switching station near Lower Frankton, Shropshire which allows the power to be isolated from a new substation being developed by National Grid to connect to the existing 400 kV national electricity transmission system
- Land which will be required for environmental mitigation, compensation, and enhancement measures



As well as the permanent infrastructure, land would also be required temporarily for construction activities including, for example, working areas for construction equipment and machinery, site offices, welfare, storage and construction access.

Third party utilities diversions and/or modifications would also be required as part of the construction of the Project.

The project is a Nationally Significant Infrastructure Project (NSIP) under the Planning Act 2008. Green GEN Cymru is therefore required to submit an application for development consent to the Secretary of State for Energy Security and Net Zero. The development consent application will seek consent to construct, operate and maintain the Project, as well as powers for the compulsory acquisition of land and interests in and rights over land, over-riding easements and other rights, the temporary use of land, and other ancillary powers.

Statutory consultation

We are contacting you because you are a prescribed consultee under section 42(1) of the Act and in accordance with Schedule 1 of the Infrastructure Planning (Applications: Prescribed Forms and Procedure) Regulations 2009. This is therefore a formal notice that we are holding a statutory consultation under the Act.

Concurrent with the section 42 consultation, we are undertaking consultation with the public pursuant to section 47 and in accordance with a Statement of Community Consultation, notice of the publication of which has been published in local newspapers. The proposed application for the Project has also been publicised in local and national newspapers under section 48 of the Act.

We are also consulting on the potential environmental effects of the proposals. This information is detailed in the Preliminary Environmental Information Report (PEIR) available on the project website. An Environmental Statement will be produced subsequently in accordance with the EIA Regulations and will accompany the application for development consent.

The Vyrnwy Frankton connection is an “EIA development” for the purposes of the EIA Regulations. Regulation 13 requires Green GEN Cymru to send your organisation a copy of the notice which is being published in accordance with Section 48 of the Act, as enclosed.

Responding to the consultation

The consultation is open from 19 February to 16 April 2025.

Responses to this consultation can be submitted in the following ways:

- Online feedback form at www.greenenvyrnwyfrankton.com
- Hard copy feedback form (available on request)
- In writing to info@greengencymruvyrnwyfrankton.com or FREEPOST Green GEN Cymru V2F (no further stamp or address needed)

All responses to the consultation must be received by 23:59 on 16 April 2025.



All documents, plans and maps showing the nature and location of the proposed development, including the preliminary environmental information report, will be available to download free of charge from 19 February to 16 April on www.greenenvyrnwyfrankton.com. Reference hard copies of these documents will also be available at community events taking place at the locations below.

Location and Address	Date	Time
West Felton Village Hall Holyhead Road, West Felton, Oswestry, Shropshire, SY11 4EH	27 February	14:00 - 19:00
Hordley & Bagley Village Hall Lower Hordley, Ellesmere, Shropshire, SY12 9BQ	28 February	14:00 - 19:00
Llanymynech Village Hall Station Road, Llanymynech, Oswestry, Shropshire, SY22 6EE	1 March	10:00 - 15:00
Llanfair Caereinion Public Hall and Institute Bridge Street, Llanfair Caereinion, Welshpool, SY21 0RY	6 March	14:00 - 19:00
Llansantffraid Community Centre Treflan, Llansantffraid-Ym-Mechain, SY22 6AE	7 March	14:00 - 19:00
Meifod Village Hall Community Centre Meifod, SY22 6DF	8 March	10:00 - 15:00

Requests for paper copies of the documents, plans and maps will be reviewed on a case-by-case basis. To cover printing costs, a reasonable copying charge may apply, to be paid for by the recipient up-to a maximum value of £500 for the whole suite of consultation documents. These can be requested by contacting the Project team via the details below.

Telephone: 0800 915 3590

Email: info@greenenvyrnwyfrankton.com

We will review our proposals in light of the feedback we receive as part of this consultation and will consider if changes are needed to further reduce the effects on communities and the local area, before we make our application for development consent.

Green GEN Cymru may be required to make copies of representations available to the Secretary of State. However, Green GEN Cymru will request that personal details are not placed on the public record. Personal details will be held securely in accordance with the Data Protection Act 2018 and will be used solely in connection with the consultation process and the development of this Project and, except as noted above, will not be disclosed to any third parties.

If you have any questions, please get in touch with us.

Yours faithfully

Sean Taylor

Project Manager
Vyrnwy Frankton Project



Annwyl Syr/Madam,

Prosiect Green GEN Cymru Vyrnwy Frankton

Ymgynghoriad statudol o dan adran 42 o Ddeddf Cynllunio 2008 a Rheoliadau Cynllunio Seilwaith (Ceisiadau: Gweithdrefnau a Ffurflenni Rhagnodedig) 2009 (Rheoliadau APFP)

Hysbysiad dan Reoliad 13 o Reoliadau Cynllunio Seilwaith (Asesu Effaith Amgylcheddol) 2017 (y Rheoliadau AEA)

Bydd GREEN GENERATION ENERGY NETWORKS CYMRU LIMITED (Green GEN Cymru) yn lansio ymgynghoriad statudol yn unol ag adrannau 42, 47 a 48 o Ddeddf Cynllunio 2008 (y Ddeddf) ar gyfer ei chysylltiad Vyrnwy Frankton (y "Prosiect") rhwng **19 Chwefror a 16 Ebrill 2025**.

Mae Green GEN Cymru yn bwriadu datblygu cysylltiad dosbarthu trydan 132 cilofolt (kV) newydd o is-orsaf gasglu ger Cefn Coch ym Mhowys i'r rhwydwaith trawsyrru trydan cenedlaethol ger Lower Frankton yn Swydd Amwythig. Byddai'r cysylltiad yn cysylltu ynni adnewyddadwy newydd a gynhyrchir ym Mhowys â'r rhwydwaith trydan cenedlaethol i'w gyflenwi i gartrefi a busnesau.

Mae'r prosiect yn cynnwys:

- Is-orsaf gasglu 132 kV newydd ger Cefn Coch, Powys, a elwir yn is-orsaf Grug y Mynydd
- Tua 4.8km o gebl tanddaearol o is-orsaf Grug y Mynydd trwy Barc Ynni Arfaethedig Llyn Lort i gompownd selio pen cebl yng Nghors y Carreg
- Byddai compownd selio pen cebl Cors y Carreg yn galluogi pontio rhwng ceblau tanddaearol a dargludyddion uwchben
- Tua 45km o linell newydd uwchben a gynhelir ar beilonau rhwylllog dur L7(c) (uchder cyfartalog o 28.5m) o gompownd selio pen cebl yng Nghors y Carreg trwy Ddyffryn Efyrrwy i orsaf gyfnewid newydd
- Gorsaf gyfnewid ger Lower Frankton, Swydd Amwythig sy'n caniatáu i'r pŵer gael ei ynysu o is-orsaf newydd sy'n cael ei datblygu gan y Grid Cenedlaethol i gysylltu â'r system drawsyrro trydan cenedlaethol 400kV bresennol
- Tir y bydd ei angen ar gyfer mesurau lliniaru amgylcheddol, iawndal a gwella

Yn ogystal â'r seilwaith parhaol, byddai angen tir dros dro hefyd ar gyfer gweithgareddau adeiladu, gan gynnwys, er enghraifft, manau gweithio ar gyfer offer a pheiriannau adeiladu, swyddfeydd safle, lles, storio a mynediad dros dro ar gyfer gwaith adeiladu.

Byddai angen dargyfeiriadau a / neu addasiadau o gyfleustodau trydydd parti hefyd i hwyluso'r gwaith o adeiladu'r Prosiect.

Mae'r prosiect yn Brosiect Seilwaith o Arwyddocâd Cenedlaethol o dan Ddeddf Cynllunio 2008. Felly mae'n ofynnol i Green GEN Cymru gyflwyno cais am gydsyniad datblygu i'r



Ysgrifennydd Gwladol dros Ddiogeled Ynni a Sero Net. Bydd y cais am gydsyniad datblygu yn gofyn am gydsyniad i adeiladu, gweithredu a chynnal y Prosiect, yn ogystal â phwerau ar gyfer caffael tir yn orfodol a buddiannau mewn tir a hawliau dros dir, trechu hawddfreintiau a hawliau eraill, defnydd dros dro o dir, a phwerau ategol eraill.

Ymgynghoriad statudol

Rydym yn cysylltu â chi oherwydd eich bod yn ymgynghorai rhagnodedig o dan adran 42(1) o'r Ddeddf ac yn unol ag Atodlen 1 Rheoliadau Cynllunio Seilwaith (Ceisiadau: Ffurflenni a Gweithdrefnau Rhagnodedig) 2009. Mae'r bobl hyn yn cynnwys, er enghraifft, awdurdodau lleol o fewn neu'n agos at y Datblygiad Arfaethedig, cyrff ymgynghori rhagnodedig (er enghraifft, Asiantaeth yr Amgylchedd neu Cyfoeth Naturiol Cymru), y rhai sydd â buddiant yn y tir y mae'r cais am gydsyniad datblygu yn ymwneud ag ef (megis tiffeddianwyr, tenantiaid, meddianwyr, neu bersonau sydd â buddiannau eraill yn y tir) a'r rhai a allai fod â hawl i ddwyn hawliad o dan ddeddfwriaeth iawndal tir penodol pe bai'r Datblygiad Arfaethedig yn cael ei adeiladu ar y tir a ddefnyddir ar gyfer y datblygiad arfaethedig.

Mae Green GEN Cymru wedi nodi eich bod yn perthyn i un o'r categorïau o bobl y mae angen iddo ymgynghori â nhw o dan adran 42 Deddf Cynllunio 2008. Mae hwn felly yn rhybudd ffurfiol ein bod yn cynnal ymgynghoriad statudol o dan y Ddeddf.

Ar yr un pryd ag ymgynghoriad adran 42, rydym yn cynnal ymgynghoriad â'r cyhoedd yn unol ag adran 47 ac yn unol â Datganiad o Ymgynghori Cymunedol, y mae hysbysiad o'i gyhoeddi wedi'i gyhoeddi mewn papurau newydd lleol. Mae'r cais arfaethedig ar gyfer y Prosiect hefyd wedi cael cyhoeddusrwydd mewn papurau newydd lleol a chenedlaethol o dan adran 48 o'r Ddeddf.

Rydym hefyd yn ymgynghori ar effeithiau amgylcheddol posibl y cynigion. Mae'r wybodaeth hon i'w gweld yn yr Adroddiad Gwybodaeth Amgylcheddol Rhagarweiniol (PEIR) sydd ar gael ar wefan y prosiect. Bydd Datganiad Amgylcheddol yn cael ei gynhyrchu yn unol â'r Rheoliadau AEA a bydd yn cyd-fynd â'r cais am ganiatâd datblygu.

Mae cysylltiad Efyrrwy Frankton yn "ddatblygiad AEA" at ddibenion y Rheoliadau AEA. Mae rheoliad 13 yn ei gwneud yn ofynnol i Green GEN Cymru anfon copi o'r hysbysiad i'ch sefydliad sy'n cael ei gyhoeddi yn unol ag Adran 48 o'r Ddeddf, fel y'i amgaewyd.

Ymateb i'r ymgynghoriad

Mae'r ymgynghoriad ar agor rhwng 19 Chwefror a 16 Ebrill 2025.

Gellir cyflwyno ymatebion i'r ymgynghoriad hwn yn y ffyrdd canlynol:

- Ffurflen adborth ar-lein yn www.greengenvyrnwyfrankton.com
- Ffurflen adborth copi caled (ar gael ar gais)
- Yn ysgrifenedig i info@greengencymruvyrnwyfrankton.com neu FREEPOST Green GEN Cymru V2F (nid oes angen stamp na chyfeiriad pellach)

Rhaid derbyn pob ymateb i'r ymgynghoriad erbyn 23:59 ar 16 Ebrill 2025.

Bydd yr holl ddogfennau, cynlluniau a mapiau sy'n dangos natur a lleoliad y datblygiad arfaethedig, gan gynnwys yr adroddiad gwybodaeth amgylcheddol rhagarweiniol, ar gael i'w lawrlwytho am ddim rhwng 19 Chwefror ac 16 Ebrill ar www.greengenvyrnwyfrankton.com

Bydd copiâu caled cyfeiriol o'r dogfennau hyn hefyd ar gael mewn digwyddiadau cymunedol a gynhelir yn y lleoliadau isod.



Lleoliad a Chyfeiriad	Dyddiad	Amser
Neuadd Bentref West Felton Holyhead Road, West Felton, Croesoswallt, Swydd Amwythig, SY11 4EH	27 Chwefror	14:00 - 19:00
Neuadd Bentref Hordley a Bagley Lower Hordley, Ellesmere, Swydd Amwythig, SY12 9BQ	28 Chwefror	14:00 - 19:00
Neuadd Bentref Llanymynech Station Road, Llanymynech, Croesoswallt, Swydd Amwythig, SY22 6EE	1 Mawrth	10:00 - 15:00
Neuadd Gyhoeddus ac Institiwt Llanfair Caereinion Stryd y Bont, Llanfair Caereinion, Y Trallwng, SY21 0RY	6 Mawrth	14:00 - 19:00
Canolfan Gymunedol Llansantffraid Treflan, Llansantffraid-ym-Mechain, SY22 6AE	7 Mawrth	14:00 - 19:00
Canolfan Gymunedol Neuadd Bentref Meifod, Meifod, SY22 6DF	8 Mawrth	10:00 - 15:00

Bydd ceisiadau am gopïau papur o'r dogfennau, cynlluniau a mapiau yn cael eu hadolygu fesul achos. I dalu costau argraffu, gall tâl copïo rhesymol fod yn berthnasol, i'w dalu gan y derbynnydd hyd at uchafswm gwerth o £500 am y gyfres gyfan o ddogfennau ymgynghori. Gellir gofyn am y rhain drwy gysylltu â thîm y Prosiect drwy'r manylion isod.

Ffôn: 0800 915 3590

E-bost: info@greengenvyrnwyfrankton.com

Byddwn yn adolygu ein cynigion yng ngoleuni'r adborth a gawn fel rhan o'r ymgynghoriad hwn a byddwn yn ystyried a oes angen newidiadau i leihau'r effeithiau ar gymunedau a'r ardal leol ymhellach, cyn i ni wneud ein cais am ganiatâd datblygu.

Efallai y bydd gofyn i Green GEN Cymru sicrhau bod copïau o sylwadau ar gael i'r Ysgrifennydd Gwladol. Fodd bynnag, bydd Green GEN Cymru yn gofyn am sicrwydd na fydd manylion personol yn cael eu rhoi ar y cofnod cyhoeddus. Bydd manylion personol yn cael eu cadw'n ddiogel yn unol a Deddf Diogelu Data 2018 a chant eu defnyddio mewn cysylltiad a'r broses ymgynghori a datblygu'r Prosiect hwn yn unig, gan eithrio fel y nodwyd uchod, ac ni fyddant yn cael eu datgelu i unrhyw drydydd parti.

Os oes gennych unrhyw gwestiynau, peidiwch ag oedi cyn cysylltu â ni.

Yn gywir

Sean Taylor



Rheolwr Prosiect

Prosiect Vyrnwy Frankton



Green GEN Cymru
Hodge House
Guildhall Place
Cardiff CF10 1DY

0800 915 3590
info@greengenvyrnwyfrankton.com

greengenvyrnwyfrankton.com

Name Surname
Address line one
Address line two
City
Postcode

XX February 2025

Dear Sir/Madam/Name,

Green GEN Cymru Vyrnwy Frankton Project

Statutory consultation under section 42 of the Planning Act 2008 and the Infrastructure Planning (Applications: Prescribed Forms and Procedures) Regulations 2009 (the APFP Regulations)

Notification under Regulation 13 of the Infrastructure Planning (Environmental Impact Assessment) Regulations 2017 (the EIA Regulations)

GREEN GENERATION ENERGY NETWORKS CYMRU LIMITED (Green GEN Cymru) will launch a statutory consultation in accordance with sections 42, 47 and 48 of the Planning Act 2008 (the Act) for its Vyrnwy Frankton connection (the "Project") from **19 February to 16 April 2025**.

Green GEN Cymru proposes to develop a new 132 kilovolt (kV) electricity distribution connection from a collector substation near Cefn Coch in Powys to the national electricity transmission network near Lower Frankton in Shropshire. The connection would connect new renewable energy generation in Powys to the national electricity network for supply to homes and businesses.

The Project comprises:

- A new 132 kV collector substation near Cefn Coch, Powys, known as the Grug y Mynydd substation
- Approximately 4.8km of underground cable from Grug y Mynydd substation through the proposed Llyn Lort Energy Park to a cable sealing end compound at Cors y Carreg
- The Cors y Carreg cable sealing end compound would enable the transition between underground cables and overhead conductors
- Approximately 45km of new overhead line supported on L7(c) steel lattice pylons (average height of 28.5m) from Cors y Carreg sealing end compound through the Vyrnwy Valley to a new switching station



- A switching station near Lower Frankton, Shropshire which allows the power to be isolated from a new substation being developed by National Grid to connect to the existing 400kV national electricity transmission system
- Land which will be required for environmental mitigation, compensation, and enhancement measures

As well as the permanent infrastructure, land would also be required temporarily for construction activities including, for example, working areas for construction equipment and machinery, site offices, welfare, storage and construction access.

Third party utilities diversions and/or modifications would also be required as part of the construction of the Project.

The project is a Nationally Significant Infrastructure Project (NSIP) under the Planning Act 2008. Green GEN Cymru is therefore required to submit an application for development consent to the State for Energy Security and Net Zero. The development consent application will seek consent to construct, operate and maintain the Project, as well as powers for the compulsory acquisition of land and interests in and rights over land, over-riding easements and other rights, the temporary use of land, and other ancillary powers.

Statutory consultation

We are contacting you because you are a prescribed consultee under section 42(1) of the Act and in accordance with Schedule 1 of the Infrastructure Planning (Applications: Prescribed Forms and Procedure) Regulations 2009. These persons include, for example, local authorities within or near to the Proposed Development, prescribed consultation bodies (for example, the Environment Agency or Natural Resources Wales), those with an interest in the land to which the DCO application relates (such as landowners, tenants, occupiers, or persons with other interests in the land) and those who may be entitled to bring a claim under certain land compensation legislation should the Proposed Development be constructed and the land used for the Proposed Development.

Green GEN Cymru has identified that you fall into one of the categories of people that it needs to consult under section 42 of the PA2008. This is therefore a formal notice that we are holding a statutory consultation under the Act.

Concurrent with the section 42 consultation, we are undertaking consultation with the public pursuant to section 47 and in accordance with a Statement of Community Consultation, notice of the publication of which has been published in local newspapers. The proposed application for the Project has also been publicised in local and national newspapers under section 48 of the Act.

We are also consulting on the potential environmental effects of the proposals. This information is detailed in the Preliminary Environmental Information Report (PEIR) available on the project website. An Environmental Statement will be produced subsequently in accordance with the EIA Regulations and will accompany the application for development consent.

The Vyrnwy Frankton connection is an "EIA development" for the purposes of the EIA Regulations. Regulation 13 requires Green GEN Cymru to send your organisation a copy of the notice which is being published in accordance with Section 48 of the Act, as enclosed.



Responding to the consultation

The consultation is open from 19 February to 16 April 2025.

Responses to this consultation can be submitted in the following ways:

- Online feedback form at www.greengenvyrnwyfrankton.com
- Hard copy feedback form (available on request)
- In writing to info@greengencymruvyrnwyfrankton.com or FREEPOST Green GEN Cymru V2F (no further stamp or address needed)

All responses to the consultation must be received by 23:59 on 16 April 2025.

All documents, plans and maps showing the nature and location of the proposed development, including the preliminary environmental information report, will be available to download free of charge from 19 February to 16 April on www.greengenvyrnwyfrankton.com

Reference hard copies of these documents will also be available at community events taking place at the locations below.

Location and Address	Date	Time
West Felton Village Hall Holyhead Road, West Felton, Oswestry, Shropshire, SY11 4EH	27 February	14:00 - 19:00
Hordley & Bagley Village Hall Lower Hordley, Ellesmere, Shropshire, SY12 9BQ	28 February	14:00 - 19:00
Llanymynech Village Hall Station Road, Llanymynech, Oswestry, Shropshire, SY22 6EE	1 March	10:00 – 15:00
Llanfair Caereinion Public Hall and Institute Bridge Street, Llanfair Caereinion, Welshpool, SY21 0RY	6 March	14:00 - 19:00
Llansantffraid Community Centre Treflan, Llansantffraid-Ym-Mechain, SY22 6AE	7 March	14:00 - 19:00
Meifod Village Hall Community Centre Meifod, SY22 6DF	8 March	10:00 – 15:00

Requests for paper copies of the documents, plans and maps will be reviewed on a case by-case basis. To cover printing costs a reasonable copying charge may apply, to be paid for by the recipient up-to a maximum value of £500 for the whole suite of consultation documents. These can be requested by contacting the Project team via the details below.

Telephone: 0800 915 3590

Email: info@greengenvyrnwyfrankton.com

We will review our proposals in light of the feedback we receive as part of this consultation and will consider if changes are needed to further reduce the effects on communities and the local area, before we make our application for development consent.



We may be required to make copies of representations available to the Secretary of State. Personal details will be held securely in accordance with the applicable data laws and will be used solely in connection with the consultation process and the development of this project and, except as noted above, will not be disclosed to any third parties.

If you have any questions, please don't hesitate to get in touch with us.

Yours faithfully

Sean Taylor

Project Manager

Vyrnwy Frankton Project

Name Surname
Address line one
Address line two
City
Postcode

XX Chwefror 2025

Annwyl Sir/Madam/Name,

Prosiect Green GEN Cymru Efyrrwy Frankton

Ymgynghoriad statudol o dan adran 42 o Ddeddf Cynllunio 2008 a Rheoliadau Cynllunio Seilwaith (Ceisiadau: Gweithdrefnau a Ffurflenni Rhagnodedig) 2009 (Rheoliadau APFP)

Hysbysiad dan Reoliad 13 o Reoliadau Cynllunio Seilwaith (Asesu Effaith Amgylcheddol) 2017 (y Rheoliadau AEA)

Bydd GREEN GENERATION ENERGY NETWORKS CYMRU LIMITED (Green GEN Cymru) yn lansio ymgynghoriad statudol yn unol ag adrannau 42, 47 a 48 o Ddeddf Cynllunio 2008 (y Ddeddf) ar gyfer ei chysylltiad Efyrrwy Frankton (y "Prosiect") rhwng **19 Chwefror a 16 Ebrill 2025**.

Mae Green GEN Cymru yn bwriadu datblygu cysylltiad dosbarthu trydan 132 cilofolt (kV) newydd o is-orsaf gasglu ger Cefn Coch ym Mhowys i'r rhwydwaith trawsyrru trydan cenedlaethol ger Lower Frankton yn Swydd Amwythig. Byddai'r cysylltiad yn cysylltu ynni adnewyddadwy newydd a gynhyrchir ym Mhowys â'r rhwydwaith trydan cenedlaethol i'w gyflenwi i gartrefi a busnesau.

Mae'r prosiect yn cynnwys:

- Is-orsaf gasglu 132 kV newydd ger Cefn Coch, Powys, a elwir yn is-orsaf Grug y Mynydd
- Tua 4.8km o gebl tanddaearol o is-orsaf Grug y Mynydd trwy Barc Ynni Arfaethedig Llyn Lort i gompownd selio pen cebl yng Nghors y Carreg
- Byddai compownd selio pen cebl Cors y Carreg yn galluogi pontio rhwng ceblau tanddaearol a dargludyddion uwchben
- Tua 45km o linell newydd uwchben a gynhelir ar beilonau rhwylllog dur L7(c) (uchder cyfartalog o 28.5m) o gompownd selio pen cebl yng Nghors y Garreg trwy Ddyffryn Efyrrwy i orsaf gyfnewid newydd
- Gorsaf gyfnewid ger Lower Frankton, Swydd Amwythig sy'n caniatáu i'r pŵer gael ei ynysu o is-orsaf newydd sy'n cael ei datblygu gan y Grid Cenedlaethol i gysylltu â'r system drawsyrro trydan cenedlaethol 400kV bresennol



- Tir y bydd ei angen ar gyfer mesurau lliniaru amgylcheddol, iawndal a gwella

Yn ogystal â'r seilwaith parhaol, byddai angen tir dros dro hefyd ar gyfer gweithgareddau adeiladu, gan gynnwys, er enghraifft, mannau gweithio ar gyfer offer a pheiriannau adeiladu, swyddfeydd safle, lles, storio a mynediad dros dro ar gyfer gwaith adeiladu.

Byddai angen dargyfeiriadau a / neu addasiadau o gyfleustodau trydydd parti hefyd i hwyluso'r gwaith o adeiladu'r Prosiect.

Mae'r prosiect yn Brosiect Seilwaith o Arwyddocâd Cenedlaethol o dan Ddeddf Cynllunio 2008. Felly mae'n ofynnol i Green GEN Cymru gyflwyno cais am gydsyniad datblygu i'r Ysgrifennydd Gwladol dros Ddiogeledd Ynni a Sero Net. Bydd y cais am gydsyniad datblygu yn gofyn am gydsyniad i adeiladu, gweithredu a chynnal y Prosiect, yn ogystal â phwerau ar gyfer caffael tir yn orfodol a buddiannau mewn tir a hawliau dros dir, trechu hawddfreintiau a hawliau eraill, defnydd dros dro o dir, a phwerau ategol eraill.

Ymgynghoriad statudol

Rydym yn cysylltu â chi oherwydd eich bod yn ymgynghorai rhagnodedig o dan adran 42(1) o'r Ddeddf ac yn unol ag Atodlen 1 Rheoliadau Cynllunio Seilwaith (Ceisiadau: Ffurflenni a Gweithdrefnau Rhagnodedig) 2009. Mae'r bobl hyn yn cynnwys, er enghraifft, awdurdodau lleol o fewn neu'n agos at y Datblygiad Arfaethedig, cyrff ymgynghori rhagnodedig (er enghraifft, Asiantaeth yr Amgylchedd neu Cyfoeth Naturiol Cymru), y rhai sydd â buddiant yn y tir y mae'r cais am gydsyniad datblygu yn ymwneud ag ef (megis tîrffeddiannwyr, tenantiaid, meddianwyr, neu bersonau sydd â buddiannau eraill yn y tir) a'r rhai a allai fod â hawl i ddwyn hawliad o dan ddeddfwriaeth iawndal tir penodol pe bai'r Datblygiad Arfaethedig yn cael ei adeiladu ar y tir a ddefnyddir ar gyfer y datblygiad arfaethedig.

Mae Green GEN Cymru wedi nodi eich bod yn perthyn i un o'r categorïau o bobl y mae angen iddo ymgynghori â nhw o dan adran 42 Ddeddf Cynllunio 2008. Mae hwn felly yn rhybudd ffurfiol ein bod yn cynnal ymgynghoriad statudol o dan y Ddeddf.

Ar yr un pryd ag ymgynghoriad adran 42, rydym yn cynnal ymgynghoriad â'r cyhoedd yn unol ag adran 47 ac yn unol â Datganiad o Ymgynghori Cymunedol, y mae hysbysiad o'i gyhoeddi wedi'i gyhoeddi mewn papurau newydd lleol. Mae'r cais arfaethedig ar gyfer y Prosiect hefyd wedi cael cyhoeddusrwydd mewn papurau newydd lleol a chenedlaethol o dan adran 48 o'r Ddeddf.

Rydym hefyd yn ymgynghori ar effeithiau amgylcheddol posibl y cynigion. Mae'r wybodaeth hon i'w gweld yn yr Adroddiad Gwybodaeth Amgylcheddol Rhagarweiniol (PEIR) sydd ar gael ar wefan y prosiect. Bydd Datganiad Amgylcheddol yn cael ei gynhyrchu yn unol â'r Rheoliadau AEA a bydd yn cyd-fynd â'r cais am ganiatâd datblygu.

Mae cysylltiad Efyrrwy Frankton yn "ddatblygiad AEA" at ddibenion y Rheoliadau AEA. Mae rheoliad 13 yn ei gwneud yn ofynnol i Green GEN Cymru anfon copi o'r hysbysiad i'ch sefydliad sy'n cael ei gyhoeddi yn unol ag Adran 48 o'r Ddeddf, fel y'i amgawyd.

Ymateb i'r ymgynghoriad

Mae'r ymgynghoriad ar agor rhwng 19 Chwefror a 16 Ebrill 2025.

Gellir cyflwyno ymatebion i'r ymgynghoriad hwn yn y ffyrdd canlynol:



- Ffurflen adborth ar-lein yn www.greengenvyrnwyfrankton.com
- Ffurflen adborth copi caled (ar gael ar gais)
- Yn ysgrifenedig i info@greengencymruvyrnwyfrankton.com neu FREEPOST Green GEN Cymru V2F (nid oes angen stamp na chyfeiriad pellach)

Rhaid derbyn pob ymateb i'r ymgynghoriad erbyn 23:59 ar 16 Ebrill 2025.

Bydd yr holl ddogfennau, cynlluniau a mapiau sy'n dangos natur a lleoliad y datblygiad arfaethedig, gan gynnwys yr adroddiad gwybodaeth amgylcheddol rhagarweiniol, ar gael i'w lawrlwytho am ddim rhwng 19 Chwefror ac 16 Ebrill ar www.greengenvyrnwyfrankton.com

Bydd copïau caled cyfeiriol o'r dogfennau hyn hefyd ar gael mewn digwyddiadau cymunedol a gynhelir yn y lleoliadau isod.

Lleoliad a Chyfeiriad	Dyddiad	Amser
Neuadd Bentref West Felton Holyhead Road, West Felton, Croesoswallt, Swydd Amwythig, SY11 4EH	27 Chwefror	14:00 - 19:00
Neuadd Bentref Hordley a Bagley Lower Hordley, Ellesmere, Swydd Amwythig, SY12 9BQ	28 Chwefror	14:00 - 19:00
Neuadd Bentref Llanymynech Station Road, Llanymynech, Croesoswallt, Swydd Amwythig, SY22 6EE	1 Mawrth	10:00 – 15:00
Neuadd Gyhoeddus ac Institiwt Llanfair Caereinion Stryd y Bont, Llanfair Caereinion, Y Trallwng, SY21 0RY	6 Mawrth	14:00 - 19:00
Canolfan Gymunedol Llansantffraid Treflan, Llansantffraid-ym-Mechain, SY22 6AE	7 Mawrth	14:00 - 19:00
Canolfan Gymunedol Neuadd Bentref Meifod, Meifod, SY22 6DF	8 Mawrth	10:00 – 15:00

Bydd ceisiadau am gopïau papur o'r dogfennau, cynlluniau a mapiau yn cael eu hadolygu fesul achos. I dalu costau argraffu, gall tâl copïo rhesymol fod yn berthnasol, i'w dalu gan y derbynnydd hyd at uchafswm gwerth o £500 am y gyfres gyfan o ddogfennau ymgynghori. Gellir gofyn am y rhain drwy gysylltu â thîm y Prosiect drwy'r manylion isod.

Ffôn: 0800 915 3590

E-bost: info@greengenvyrnwyfrankton.com

Byddwn yn adolygu ein cynigion yng ngoleuni'r adborth a gawn fel rhan o'r ymgynghoriad hwn a byddwn yn ystyried a oes angen newidiadau i leihau'r effeithiau ar gymunedau a'r ardal leol ymhellach, cyn i ni wneud ein cais am ganiatâd datblygu.

Efallai y bydd gofyn i ni sicrhau bod copïau o sylwadau ar gael i'r Ysgrifennydd Gwladol. Bydd manylion personol yn cael eu cadw'n ddiogel yn unol â'r deddfau data perthnasol a



chânt eu defnyddio mewn cysylltiad â'r broses ymgynghori a datblygu'r prosiect hwn yn unig ac, ac eithrio fel y nodwyd uchod, ni fyddant yn cael eu datgelu i unrhyw drydydd parti.

Os oes gennych unrhyw gwestiynau, peidiwch ag oedi cyn cysylltu â ni.

Yn gywir

Sean Taylor

Rheolwr Prosiect

Prosiect Efyrrwy Frankton

Notice is hereby given that GREEN GENERATION ENERGY NETWORKS CYMRU LIMITED (Green GEN Cymru) of Hodge House, Guildhall Place, Cardiff, United Kingdom, CF10 1DY intends to apply to the Secretary of State for Energy Security and Net Zero for a Development Consent Order (DCO) under Section 37 of the Planning Act 2008 (the Act) to authorise the construction of the Vyrnwy Frankton Connection (the “Project”).

Green GEN Cymru proposes to develop a new 132 kilovolt (kV) electricity distribution connection from a collector substation near Cefn Coch in Powys to the national electricity transmission network near Lower Frankton in Shropshire. The connection would connect new renewable energy generation in Powys to the national electricity network for supply to homes and businesses.

The Project comprises:

- A new 132 kV collector substation near Cefn Coch, Powys, known as the Grug y Mynydd substation
- Approximately 4.8km of underground cable from Grug y Mynydd substation through the proposed Llyn Lort Energy Park to a cable sealing end compound at Cors y Carreg
- The Cors y Carreg cable sealing end compound would enable the transition between underground cables and overhead conductors
- Approximately 45km of new overhead line supported on L7(c) steel lattice pylons (average height of 28.5m) from Cors y Carreg sealing end compound through the Vyrnwy Valley to a new switching station
- A switching station near Lower Frankton, Shropshire which allows the power to be isolated from a new substation being developed by National Grid to connect to the existing 400kV national electricity transmission system
- Land which will be required for environmental mitigation, compensation, and enhancement measures

As well as the permanent infrastructure, land would also be required temporarily for construction activities including, for example, working areas for construction equipment and machinery, site offices, welfare, storage and temporary construction access.

Third party utilities diversions and/or modifications would also be required to facilitate the construction of the Project.

The project is a Nationally Significant Infrastructure Project (NSIP) under the Planning Act 2008. Green GEN Cymru is therefore required to submit an application for development consent to the Secretary of State for Energy Security and Net Zero. The development consent application will seek consent to construct, operate and maintain the Project, as well as powers for the compulsory acquisition of land and interests in and rights over land, over-riding easements and other rights, the temporary use of land, and other ancillary powers.

The Project is an Environmental Impact Assessment (EIA) development under the Infrastructure Planning (Environmental Impact Assessment) Regulations 2017. An Environmental Statement will therefore be submitted as part of the application, which will contain information about the environmental effects of the Project.

All documents, plans and maps showing the nature and location of the proposed development, including the preliminary environmental information report, will be available to download free of charge from **19 February until 16 April 2025** in the documents section on the Project website: www.greengenvyrnwyfrankton.com.

Reference hard copies of these documents will also be available at community events taking place at the locations below.

Location and Address	Date	Time
West Felton Village Hall, Holyhead Road, West Felton, Oswestry, Shropshire, SY11 4EH	27 February	14:00 - 19:00
Hordley & Bagley Village Hall, Lower Hordley, Ellesmere, Shropshire, SY12 9BQ	28 February	14:00 - 19:00
Llanymynech Village Hall, Station Road, Llanymynech, Oswestry, Shropshire, SY22 6EE	1 March	10:00 – 15:00
Llanfair Caereinion Public Hall and Institute, Bridge Street, Llanfair Caereinion, Welshpool, SY21 0RY	6 March	14:00 - 19:00
Llansantffraid Community Centre, Treflan, Llansantffraid-Ym-Mechain, SY22 6AE	7 March	14:00 - 19:00
Meifod Village Hall Community Centre, Meifod, SY22 6DF	8 March	10:00 – 15:00

Requests for paper copies of the documents, plans and maps will be reviewed on a case by-case basis. To cover printing costs a reasonable copying charge may apply, to be paid for by the recipient up-to a maximum value of £500 for the whole suite of consultation documents. These can be requested by contacting the Project team via the details at the bottom of this notice.

How to respond to the consultation

The consultation is open from 19 February to 16 April 2025.

Responses to the consultation can be submitted in the following ways:

- Complete a feedback form on www.greengenvyrnwyfrankton.com or request one from our team by calling 0800 915 3590
- Email us at info@greengenvyrnwyfrankton.com
- Write to us at FREEPOST Green GEN Cymru V2F (no further stamp or address needed)

All responses must be received by Green GEN Cymru by 11:59pm on 16 April 2025 to ensure they are considered.

When deciding on the final form of the proposed application for a DCO for the Project, Green GEN Cymru will take into account any response to this publicity or the consultation that is received before the specified deadline.

Green GEN Cymru may be required to make copies of representations available to the Secretary of State. However, Green GEN Cymru will request that personal details are not placed on the public record. Personal details will be held securely in accordance with the Data Protection Act 2018 and will be used solely in connection with the consultation process and the development of this Project and, except as noted above, will not be disclosed to any third parties.

If you have any questions about the Project or the consultation, please get in touch:

Email: info@greengenvyrnwyfrankton.com
Telephone: **0800 915 3590**

Connecting renewable energy to homes and businesses

Statutory consultation 19 February to 16 April 2025

FEEDBACK FORM

Green GEN Cymru is consulting on updated proposals for a new 132 kV electricity connection to transport energy to the national electricity network. This is part of our mission to help deliver renewable energy to homes, businesses, and communities.

Following careful consideration of feedback to our first consultation, and further technical and environmental assessments, we have developed a draft route alignment, showing proposed locations of the infrastructure we need. For this consultation, we are asking for your feedback on:

- A new 132 kV collector substation near Cefn Coch, Powys, known as the Grug y Mynydd substation
- Approximately 4.8km of underground cable from Grug y Mynydd substation through the proposed Llyn Lort Energy Park to a cable sealing end compound at Cors y Carreg
- The Cors y Carreg cable sealing end compound would enable the transition between underground cables and overhead conductors
- Approximately 45km of new overhead line supported on L7(c) steel lattice pylons (average height of 28.5m) from Cors y Carreg sealing end compound to a new switching station
- A switching station near Lower Frankton, Shropshire which allows the power to be isolated from a new proposed substation being developed by National Grid to connect to the existing 400kV national electricity transmission system
- Land which will be required for environmental mitigation, compensation, and enhancement measures

As well as the permanent infrastructure, land would also be required temporarily for construction activities including, for example, working areas for construction equipment and machinery, site offices, welfare, storage and construction access.

Third party utilities diversions and/or modifications would also be required as part of the construction of the Project.

We have published a range of information for you to find out more about our proposals, and to support you in providing feedback. Please see the back page for details. We encourage you to read these materials before completing this form. These documents are available, along with further information and an interactive map on our website www.greengenvyrnwyfrankton.com

We are committed to delivering the Project that seeks to balance the effects on those who live and work close to our proposals, with the policy and technical requirements we must also meet.

We know that people have different views on new infrastructure, and we recognise people have concerns about pylons featuring in the landscape. Delivering the infrastructure we need to add grid capacity, address climate change and help the country transition to electric vehicles and heating requires a careful balance.

Your knowledge is very valuable to us and we welcome any feedback you have on our proposals. It will help develop our understanding of potential impacts and opportunities arising from the Project, and inform the continued development of our proposals before we make an application for development consent. Please provide as much detail as you can when providing feedback including, if possible, specific pylon numbers. These can be found on the interactive map on our website.

Please contact our team on **0800 915 3590** or info@greengenvyrnwyfrankton.com if you need support in providing feedback.

**Please provide your feedback by
23:59 on 16 April 2025.**

About you	
Title:	Name:
Age group:	<input type="checkbox"/> Under 18 <input type="checkbox"/> 18 – 34 <input type="checkbox"/> 35 – 50 <input type="checkbox"/> 51 – 65 <input type="checkbox"/> Over 65
Address:	
Postcode:	Email address:
Would you like to receive email updates about the Project? <input type="checkbox"/> Yes <input type="checkbox"/> No	
Are you responding on behalf of an organisation? <input type="checkbox"/> Yes <input type="checkbox"/> No	
If yes, which organisation:	
Do you own or occupy land within the Project boundary? <input type="checkbox"/> Yes <input type="checkbox"/> No	
If yes, have you been contacted by our lands team? <input type="checkbox"/> Yes <input type="checkbox"/> No	
If you have not been contacted by us, please provide the details of this land, including the address, if different to the above, so we can contact you.	



Providing feedback

Feedback we've received to date from local people, landowners and specialist organisations has been important in developing our proposals, alongside our own assessments.

Our proposals are still open to influence and we'd like your feedback so we can continue to look at ways to keep effects as low as we can. We are keen to understand if people have comments on the potential environmental effects of the proposals or ideas for mitigating these effects, and if you have comments on the potential benefits of the Project. Please tell us if there are changes you think we can make to improve the proposals or reduce impacts and, importantly, why.

We're asking for comments on all of our proposals, including:

- A new 132 kV collector substation near Cefn Coch, Powys, known as the Grug y Mynydd substation
- Approximately 4.8km of underground cable from Grug y Mynydd substation through the proposed Llyn Lort Energy Park to a cable sealing end compound at Cors y Carreg
- The Cors y Carreg cable sealing end compound would enable the transition between underground cables and overhead conductors
- Approximately 45km of new overhead line supported on L7(c) steel lattice pylons (average height of 28.5m) from Cors y Carreg sealing end compound to a new switching station
- A switching station near Lower Frankton, Shropshire which allows the power to be isolated from a proposed new substation being developed by National Grid to connect to the existing 400kV national electricity transmission system
- Land which will be required for environmental mitigation, compensation, and enhancement measures

As well as the permanent infrastructure, land would also be required temporarily for construction activities including, for example, working areas for construction equipment and machinery, site offices, welfare, storage and construction access.

Third party utilities diversions and/or modifications would also be required as part of the construction of the Project.

We can only consider feedback about proposals, not wider themes such as energy generation or government policy.

Please provide feedback about our proposals only. The more detail you can provide, the better we can understand the potential impacts of our work.

We have organised the draft route alignment into five sections. If your feedback is about one of these sections or a particular location, please let us know.

There are several ways to provide Project feedback.



Online feedback form on our website:
www.greengenvyrnwyfrankton.com



Sending an email to
info@greengenvyrnwyfrankton.com



Hard copy feedback form, available
at consultation events or on request




Sending written feedback to
FREEPOST GREEN GEN CYMRU V2F

We'll look carefully at all of the feedback we receive and use it to review our work to date, and to inform how we develop the Project going forward.

ROUTE SECTIONS

We have organised our draft detailed route alignment into five sections to provide the opportunity for more detailed feedback.

For further information on each route section, please refer to our statutory consultation brochure.



Q1 Section 1: Cefn Coch to Llangyniew. Are there any specific factors we should consider when reviewing and developing our proposals for this section of the route?

If your feedback concerns the proposed locations of pylons in this area, then please provide the pylon number (as outlined on our interactive detailed draft route alignment map) where possible.

Q2 Section 2: Llangyniew to Meifod. Are there any specific factors we should consider when reviewing and developing our proposals for this section of the route?

If your feedback concerns the proposed locations of pylons in this area, then please provide the pylon number (as outlined on our interactive detailed draft route alignment map) where possible.

Q3 Section 3: Meifod to Llansantffraid-ym-Mechan. Are there any specific factors we should consider when reviewing and developing our proposals for this section of the route?

If your feedback concerns the proposed locations of pylons in this area, then please provide the pylon number (as outlined on our interactive detailed draft route alignment map) where possible.

Q4 Section 4: Llansantffraid-ym-Mechan to Llanymynech. Are there any specific factors we should consider when reviewing and developing our proposals for this section of the route?

If your feedback concerns the proposed locations of pylons in this area, then please provide the pylon number (as outlined on our interactive detailed draft route alignment map) where possible.

Q5 Section 5: Llanymynech to Lower Frankton. Are there any specific factors we should consider when reviewing and developing our proposals for this section of the route?

If your feedback concerns the proposed locations of pylons in this area, then please provide the pylon number (as outlined on our interactive detailed draft route alignment map) where possible.

Privacy notice

Green Generation Networks Cymru Limited (a company within the Windward Energy Group) is committed to protecting your personal information. Whenever you provide such information, we are legally obliged to use it in line with all applicable laws concerning the protection of personal data, including the UK General Data Protection Regulation (GDPR).

How will Green GEN Cymru use information we collect about you?

We will use your personal data collected via this consultation for our legitimate business purposes, including:

- To analyse your feedback to the consultation
- To produce a Consultation Report, based on our analysis of responses (individuals will not be identified in the Report)
- To write to you with updates about the results of the consultation and other developments if you have opted in to receive these updates
- To keep up to date records of our communications with individuals and organisations

Any personal information you include in this form will be handled and used by (or made available to) the following recipients to record, analyse and report on the feedback we receive:

- Green GEN Cymru (which may include any subsidiary and parent companies).
- The Planning Inspectorate (which will consider our application for consent to build the Green GEN Vyrnwy Frankton Project).
- Legal authorities including law enforcement agencies or regulatory bodies as required by law to allow us to comply with our legal and regulatory obligations.
- The relevant secretary of state.
- Professional advisers, including our legal advisers and third-party companies and consultants that provide services on our behalf in connection with the Green GEN Vyrnwy Frankton Project.

What rights do I have over my personal data?

Under the terms of the UK GDPR, you have certain rights over how your personal data is retained and used by Green GEN Cymru. For more information, see our full data privacy statement at www.greengencymru.com/privacy-policy

Contact



info@greengen
vyrnwyfrankton.com



0800 915 3590



FREEPOST
Green GEN
Cymru V2F

We have used sustainable sources for the production of this feedback form.



Cysylltu ynni adnewyddadwy â chartrefi a busnesau

Ymgynghoriad Statudol 19 Chwefror i 16 Ebrill 2025

FFURFLEN ADBORTH

Mae Green GEN Cymru yn datblygu cysylltiad trydan newydd rhwng is-orsaf gasglu arfaethedig Grug y Mynydd ger Cefn Coch ym Mhowys i is-orsaf newydd y Grid Cenedlaethol yn Lower Frankton yn Swydd Amwythig. Byddai hyn yn ychwanegu capasiti trydan lleol sydd ei angen i ddatgloi ynni glân, adnewyddadwy ar gyfer cymunedau a busnesau.

Ar ôl ystyried yn ofalus yr adborth i'n hymgyngoriad cyntaf, yn ogystal ag asesiadau technegol ac amgylcheddol pellach, rydym wedi datblygu llwybr drafft, sy'n dangos lleoliadau arfaethedig y seilwaith sydd ei angen arnom. Fel rhan o'r ymgynghoriad hwn, rydym yn gofyn am eich adborth ar y canlynol:

- Is-orsaf gasglu 132 kV newydd ger Cefn Coch, Powys, a elwir yn is-orsaf Grug y Mynydd
- Tua 4.8km o gebl tanddaearol o is-orsaf Grug y Mynydd trwy Barc Ynni Arfaethedig Llyn Lort i gompownd selio pen cebl yng Nghors y Carreg
- Byddai compownd selio pen cebl Cors y Carreg yn galluogi pontio rhwng ceblau tanddaearol a dargludyddion uwchben
- Tua 45km o linell newydd uwchben a gynhelir ar beilonau rhwylllog dur L7(c) (uchder cyfartalog o 28.5m) o gompownd selio pen cebl yng Nghors y Garreg i orsaf gyfnewid newydd
- Gorsaf gyfnewid ger Lower Frankton, Swydd Amwythig sy'n caniatáu i'r pŵer gael ei ynysu o is-orsaf newydd posib sy'n cael ei datblygu gan y Grid Cenedlaethol i gysylltu â'r system drawsyrro trydan cenedlaethol 400kV bresennol
- Tir y bydd ei angen ar gyfer mesurau lliniaru amgylcheddol, iawndal a gwella

Yn ogystal â'r seilwaith parhaol, byddai angen tir dros dro hefyd ar gyfer gweithgareddau adeiladu, gan gynnwys, er enghraifft, manau gweithio ar gyfer offer a pheiriannau adeiladu, swyddfeydd safle, lles, storio a mynediad dros dro ar gyfer gwaith adeiladu.

Byddai angen dargyfeiriadau a / neu addasiadau o gyfleustodau trydydd parti hefyd i hwyluso'r gwaith o adeiladu'r Prosiect.

Rydym wedi cyhoeddi ystod o wybodaeth er mwyn i chi gael rhagor o wybodaeth am ein cynigion, ac i'ch helpu i roi adborth. Gweler y manylion ar y dudalen gefn am ragor o wybodaeth. Rydym yn eich annog i ddarllen y deunyddiau hyn cyn llenwi'r ffurflen hon. Mae'r dogfennau hyn ar gael ar ein gwefan, ynghyd â rhagor o wybodaeth a map rhyngweithiol <https://greengenvyrnwyfrankton.com/cy/>

Rydym wedi ymrwmo i gyflawni'r Prosiect sy'n ceisio cydbwysu'r effeithiau ar y rhai sy'n byw ac yn gweithio'n agos at ein cynigion, â'r gofynion polisi a thechnegol y mae'n rhaid i ni eu bodloni hefyd.

Gwyddom fod gan bobl farn wahanol ar seilwaith newydd, ac rydym yn cydnabod bod gan bobl bryderon am beilonau ar dirwedd yr ardal. Mae angen cydbwysedd gofalus er mwyn darparu'r seilwaith sydd ei angen arnom i ychwanegu capasiti'r grid, mynd i'r afael â newid yn yr hinsawdd a helpu'r wlad i drosglwyddo i gerbydau trydan a gwresogi.

Mae eich gwybodaeth yn werthfawr iawn i ni ac rydym yn croesawu unrhyw adborth sydd gennych chi ar ein cynigion. Bydd yn helpu i ddatblygu ein dealltwriaeth o'r effeithiau a'r cyfleoedd posibl sy'n deillio o'r Prosiect, ac yn cyfrannu at ddatblygiad parhaus ein cynigion cyn i ni wneud cais am gydsyniad datblygu. Rhowch gymaint o fanylion ag y gallwch chi wrth roi eich adborth.

Mae croeso i chi gysylltu â'n tîm ar **0800 915 3590** neu anfon e-bost at info@greengenvyrnwyfrankton.com os oes angen cymorth arnoch chi i roi adborth.

Cyflwynwch eich adborth erbyn 23:59 ar 16 Ebrill 2025.

Gwybodaeth amdanoch chi	
Teitl:	Enw:
Grŵp oedran:	<input type="checkbox"/> Dan 18 <input type="checkbox"/> 18-34 <input type="checkbox"/> 35-50 <input type="checkbox"/> 51-65 <input type="checkbox"/> Dros 65 oed
Cyfeiriad:	
Cod Post:	Cyfeiriad e-bost:
Ydych chi eisiau derbyn diweddariadau e-bost am y Prosiect? <input type="checkbox"/> Ydw <input type="checkbox"/> Nac ydw	
Ydych chi'n ymateb ar ran sefydliad? <input type="checkbox"/> Ydw <input type="checkbox"/> Nac ydw	
Os ydych chi, pa sefydliad:	
Ydych chi'n berchen ar dir neu'n meddiannu tir o fewn ffin y Prosiect?	
Os ydych chi, a yw ein tîm tiroedd wedi cysylltu â chi? <input type="checkbox"/> Ydw <input type="checkbox"/> Nac ydw	
Os nad ydym wedi cysylltu â chi, rhowch fanylion y tir hwn, gan gynnwys y cyfeiriad, os yw'n wahanol i'r uchod, er mwyn i ni allu cysylltu â chi.	



Rhannu Adborth

Mae adborth rydym wedi'i dderbyn hyd yma gan bobl leol, tîrfeddianwyr a sefydliadau arbenigol wedi bod yn bwysig wrth ddatblygu ein cynigion, ochr yn ochr â'n hasesiadau ein hunain.

Mae ein cynigion yn dal yn agored i ddylanwad a hoffem gael eich adborth fel y gallwn barhau i edrych ar ffyrdd o gadw effeithiau mor isel ag y gallwn. Rydym yn awyddus i ddeall a oes gan bobl sylwadau ar effeithiau amgylcheddol posibl y cynigion neu syniadau ar gyfer lliniaru'r effeithiau hyn, ac a oes gennych sylwadau ar fanteision posibl y Prosiect. Dywedwch wrthym os oes unrhyw newidiadau y credwch y gallwn eu gwneud i wella'r cynigion neu leihau effeithiau ac, yn bwysig iawn, pam.

Rydym yn gofyn am sylwadau ar ein holl gynigion, gan gynnwys:

- Is-orsaf gasglu 132 kV newydd ger Cefn Coch, Powys, a elwir yn is-orsaf Grug y Mynydd
- Tua 4.8km o gebl tanddaearol o is-orsaf Grug y Mynydd trwy Barc Ynni Arfaethedig Llyn Lort i gompownd selio pen cebl yng Nghors y Carreg
- Byddai compownd selio pen cebl Cors y Carreg yn galluogi pontio rhwng ceblau tanddaearol a dargludyddion uwchben
- Tua 45km o linell newydd uwchben a gynhelir ar beilonau rhwylog dur L7(c) (uchder cyfartalog o 28.5m) o gompownd selio pen cebl yng Nghors y Carreg i orsaf gyfnewid newydd
- Gorsaf gyfnewid ger Lower Frankton, Swydd Amwythig sy'n caniatáu i'r pŵer gael ei ynyso o is-orsaf newydd posib sy'n cael ei datblygu gan y Grid Cenedlaethol i gysylltu â'r system drawsyrn trydan cenedlaethol 400kV bresennol
- Tir y bydd ei angen ar gyfer mesurau lliniaru amgylcheddol, iawndal a gwella

Yn ogystal â'r seilwaith parhaol, byddai angen tir dros dro hefyd ar gyfer gweithgareddau adeiladu, gan gynnwys, er enghraifft, mannau gweithio ar gyfer offer a pheiriannau adeiladu, swyddfeydd safle, lles, storio a mynediad dros dro ar gyfer gwaith adeiladu.

Byddai angen dargyfeiriadau a / neu addasiadau o gyfleustodau trydydd parti hefyd i hwyloso'r gwaith o adeiladu'r Prosiect.

Dim ond adborth am gynigion y gallwn ei ystyried, ac nid themâu ehangach fel cynhyrchu ynni na pholisïau'r llywodraeth.

Rhowch adborth am ein cynigion yn unig. Po fwyaf o fanylion y gallwch eu darparu, y gorau y gallwn ddeall effeithiau posibl ein gwaith.

Rydym wedi trefnu'r llwybr drafft rydym ei ffafrio yn bum rhan. Os yw eich adborth yn ymwneud ag un o'r adrannau hyn, neu am leoliad penodol, rhowch wybod i ni.

Mae sawl ffordd o ddarparu adborth ar y Prosiect.



Llenwi'r ffurflen adborth ar ein gwefan:
<https://greengenvyrwyfrankton.com/cy/>



Anfon e-bost at
info@greengenvyrwyfrankton.com



Llenwi copi caled o'r adborth, sydd ar gael mewn digwyddiadau ymgynghori neu ar gais



Anfon adborth ysgrifenedig at
RHADBOST GREEN GEN CYMRU V2F

Byddwn yn edrych yn ofalus ar yr holl adborth a gawn, ac yn ei ddefnyddio i adolygu ein gwaith hyd yma, ac i lywio sut rydym yn datblygu'r Prosiect yn y dyfodol.

ADRANNAU Y LLWYBR

Rydym wedi trefnu ein haliniad llwybr manwl drafft yn bum adran i roi cyfle i gael adborth manylach.

I gael rhagor o wybodaeth am bob adran llwybr, cyfeiriwch at ein llyfryn ymgynghori statudol.

1	2	3	4	5
Cefn Coch i Langynyw	Llangynyw i Feifod	Meifod i Lansantffraid-ym-Mechain	Llansantffraid-ym-Mechain i Lanymynech	Llanymynech i Lower Frankton

C1 Rhan 1: Cefn Coch i Langynyw. A oes unrhyw ffactorau penodol y dylem eu hystyried wrth adolygu a datblygu ein cynigion ar gyfer y rhan hon o'r llwybr?

Os yw eich adborth yn ymwneud â lleoliadau posib y peilonau yn yr ardal hon, rhowch rif y peilonau (fel yr amlinellir ar ein map aliniad llwybr drafft manwl rhyngweithio) lle bo modd.

C2 Rhan 2: Llangynyw i Feifod. A oes unrhyw ffactorau penodol y dylem eu hystyried wrth adolygu a datblygu ein cynigion ar gyfer y rhan hon o'r llwybr?

Os yw eich adborth yn ymwneud â lleoliadau posib y peilonau yn yr ardal hon, rhowch rif y peilonau (fel yr amlinellir ar ein map aliniad llwybr drafft manwl rhyngweithio) lle bo modd.

C3 Rhan 3: Meifod i Lansantffraid-ym-Mechain. A oes unrhyw ffactorau penodol y dylem eu hystyried wrth adolygu a datblygu ein cynigion ar gyfer y rhan hon o'r llwybr?

Os yw eich adborth yn ymwneud â lleoliadau posib y peilonau yn yr ardal hon, rhowch rif y peilonau (fel yr amlinellir ar ein map aliniad llwybr drafft manwl rhyngweithio) lle bo modd.

C4 Rhan 4: Llansantffraid-ym-Mechain i Lanymynech. A oes unrhyw ffactorau penodol y dylem eu hystyried wrth adolygu a datblygu ein cynigion ar gyfer y rhan hon o'r llwybr?

Os yw eich adborth yn ymwneud â lleoliadau posib y peilonau yn yr ardal hon, rhowch rif y peilonau (fel yr amlinellir ar ein map aliniad llwybr drafft manwl rhyngweithio) lle bo modd.

C5 Rhan 5: Llanymynech i Lower Frankton. A oes unrhyw ffactorau penodol y dylem eu hystyried wrth adolygu a datblygu ein cynigion ar gyfer y rhan hon o'r llwybr?

Os yw eich adborth yn ymwneud â lleoliadau posib y peilonau yn yr ardal hon, rhowch rif y peilonau (fel yr amlinellir ar ein map aliniad llwybr drafft manwl rhyngweithio) lle bo modd.

Hysbysiad Preifatrwydd

Mae **Green Generation Networks Cymru Limited** (cwmni o fewn y Windward Energy Group) wedi ymrwymo i ddiogelu eich gwybodaeth bersonol. Pryd bynnag y byddwch yn darparu gwybodaeth o'r fath, mae rhwymedigaeth gyfreithiol arnom i'w defnyddio yn unol â'r holl gyfreithiau perthnasol sy'n ymwneud â diogelu data personol, gan gynnwys Rheoliad Diogelu Data Cyffredinol y DU (GDPR).

Sut bydd Green GEN Cymru yn defnyddio gwybodaeth a gasglwn amdanoch chi?

Byddwn yn defnyddio'ch data personol a gesglir drwy'r ymgynghoriad hwn at ein dibenion busnes cyfreithlon, gan gynnwys:

- I ddadansoddi eich adborth i'r ymgynghoriad
- Cynhyrchu Adroddiad Ymgynghori, yn seiliedig ar ein dadansoddiad o ymatebion (ni chaiff unigolion eu nodi yn yr Adroddiad)
- I ysgrifennu atoch gyda diweddariadau am ganlyniadau'r ymgynghoriad a datblygiadau eraill os ydych wedi optio i mewn i dderbyn y diweddariadau hyn
- Cadw cofnodion cyfredol o'n cyfathrebiadau ag unigolion a sefydliadau

Bydd unrhyw wybodaeth bersonol y byddwch yn ei chynnwys yn y ffurflen hon yn cael ei thrin a'i defnyddio gan y derbynwyr canlynol (neu bydd ar gael iddynt) i gofnodi, dadansoddi ac adrodd ar yr adborth a gawn:

- Green GEN Cymru (a all gynnwys unrhyw is-gwmni a rhiant-gwmnïau).
- Yr Arolygiaeth Gynllunio (a fydd yn ystyried ein cais am ganiatâd i adeiladu Prosiect Green GEN Fyrnwy Frankton).
- Awdurdodau cyfreithiol gan gynnwys asiantaethau gorfodi'r gyfraith neu gyrff rheoleiddio fel sy'n ofynnol yn ôl y gyfraith i ganiatáu i ni gydymffurfio â'n rhwymedigaethau cyfreithiol a rheoleiddiol.
- Yr ysgrifennydd gwladol perthnasol.
- Ymgynghorwyr proffesiynol, gan gynnwys ein cyngorwyr cyfreithiol a chwmnïau ac ymgynghorwyr trydydd parti sy'n darparu gwasanaethau ar ein rhan mewn cysylltiad â phrosiect Green GEN Fyrnwy Frankton.

Pa hawliau sydd gennyf dros fy nata personol?

O dan delerau GDPR y DU, mae gennych hawliau penodol ynghylch sut mae Green GEN Cymru yn cadw ac yn defnyddio eich data personol. I gael rhagor o wybodaeth, gweler ein datganiad preifatrwydd data llawn yn www.greengencymru.com/privacy-policy

Cysylltwch



info@greengen.vyrnwyfrankton.com



0800 915 3590



RHADBOST
Green GEN
Cymru V2F

Rydym ni wedi defnyddio ffynonellau cynaliadwy i greu'r llyfryn hwn.

