

APPENDIX SES2.3
PIPELINE ENGINEERING ASSESSMENT REPORT
PINS document reference: 14.6.2.3



Pipetechnics Ltd.

REPORT ON ISSUES CONCERNING THE ANGLIAN WATER SERVICES WATER MAINS CROSSING THE AUGEAN SITE

Sandra Rolfe-Dickinson



Table of Contents

| | | |
|----------|---|-----------|
| 1 | Introduction | 1 |
| 2 | Pipe Material | 1 |
| 3 | Potential breach of mains | 4 |
| 4 | External loading & potential for damage | 5 |
| 5 | Potential size of crater in the event of pipe rupture | 9 |
| 6 | Stability of pipelines due to excavations & effect of shrink/swell clays | 11 |
| 7 | Access for pipe repair | 12 |
| 8 | Effect of water in pipeline embedment | 14 |
| 9 | Conclusions | 15 |
| | References | 16 |

LIST OF FIGURES

| | |
|--|----|
| Figure 1 – Vehicular loading..... | 6 |
| Figure 2 – Structural analysis using a 7.1mm wall thickness | 7 |
| Figure 3 – Structural analysis using a 5.5mm wall thickness | 8 |
| Figure 4 – Diameter of failure crater | 10 |
| Figure 5 – Profile of the ground between Wing WTW and Peterborough | 11 |
| Figure 6 – Zone of influence around a buried pipeline..... | 12 |
| Figure 7 – Access requirements | 13 |

APPENDICES

| | |
|------------|--|
| Appendix A | Vehicular loading analysis |
| Appendix B | Structural design of steel pipelines at 1.2m and 3m burial depth |



1 Introduction

- 1.1 Pipetechnics Ltd was engaged by Augean South Ltd to examine specific potential issues raised by Anglian Water Services (AWS) pertaining to their existing steel 800mm diameter twin water mains. These water mains cross diagonally through the site of the proposed future western expansion at the Augean site and adjacent to the existing East Northants Resource Management Facility (ENRMF).
- 1.2 The concerns raised by AWS relate to how the pipelines might be affected by being left insitu (rather than being diverted away from the active site). These issues include:
- Potential failure of the pipelines, including crater size and access for repair.
 - External loading on the pipelines from equipment used to manage the Augean site.
 - Effect of excavations at the Augean site on the pipelines.

2 Pipe Material

- 2.1 It is understood from AWS that the twin pipelines crossing the Augean site are made of steel. To date, no as-built information has been provided, so reasonably worst-case assumptions have been made regarding the original wall thickness of the pipes, the grade of steel from which they were manufactured, the coating and lining provided to the pipes, and their burial depth.



- 2.2 Steel is a ductile pipeline material, which can be susceptible to corrosion if it is not adequately protected. Steel is very strong in tension, and therefore the wall thicknesses used in water pipelines are generally governed by the handling, welding and installation requirements, rather than their ability to resist internal pressure. This is particularly true in the water industry, where operating pressures are generally low compared to, for example, oil pipelines.
- 2.3 If failures of the steel pipe body occur, they are most often associated with through wall corrosion, rather than a catastrophic burst that can be seen in more brittle materials, such as cast iron. More serious issues can occur at the welded joints, if these have not been correctly executed and supervised, or if, during construction, pipe alignments are not correct. As an example, I have investigated the failure of a large diameter welded steel special (a bespoke, factory-made bend). In this case, steel pipework laid under two different contracts was to be pieced together with a shop-made steel special. The alignment of the two legs of pipework was not accurate, and there was about a 5mm mismatch. The pipes were forced to fit the steel special, and were welded up, but less than a year later one of the welds had “let go” due to the stress it was under. I have heard of cases (but I don’t have direct experience) of welds also “letting go” where unaccounted for differential settlement of the pipeline has put undue stress on welds.
- 2.4 Steel pipes can be typically supplied in lengths of 6m, 9m and 12m, so there could be in the region of 30 to 55 joints per pipeline in the length crossing the ENRMF site.
- 2.5 The precise age of the pipelines is not known at this time, but it is assumed that they were laid within the last 25 years based on the



known diversion of the pipelines during the development of the existing landfill site. Given this information, it seems likely that the pipes were supplied by FT Pipelines (formerly known as Frazer & Tabberer).

- 2.6 Where bends and fittings are present in pressurised water mains, thrust forces are generated due to changes in pipeline diameter or direction. These forces are countered by the provision of thrust restraint. This can take the form of concrete thrust blocks, designed to resist the forces generated, or by joining pipes together by welded or anchored joints, and resisting the generated forces by the friction created between the embedment soil and the walls of the pipeline along the length of the continuous pipework.
- 2.7 The benefit of welding the joints means that thrust forces generated by the under-pressure water can be accommodated at changes of direction in the pipeline, without the need for large concrete thrust blocks.
- 2.8 Typically, the structural design of buried pipelines is concerned with the response of the pipe cross section when subjected to loads from both soil backfill and any vehicular loading. Steel pipes are generally classified as flexible in their behaviour, since their response to external load is to deflect into an out-of-circle shape.
- 2.9 The lining (internal protection) and coating (external protection) of the pipelines is also not known. Steel pipes are generally supplied with either a cement mortar lining, or an epoxy lining. Limits of pipe deflection are specified in order to ensure no damage occurs to the internal linings when the pipeline deflects into an out-of-circle shape. For this reason, a cement mortar lining has been assumed in the structural calculations, as this has a slightly more onerous deflection limit (3%, compared with an epoxy lining of 5%).



2.10 There have been no failures of the pipelines crossing the ENRMF site, although it is understood from AWS that there has been prior leakage on one of these pipelines in a different location.

3 Potential breach of mains

3.1 As indicated previously, the most likely failure scenario is a small, through-wall corrosion leak. Left undetected, small leaks can develop, and lead to loosening of the pipe embedment, and potential loss of support locally to the pipelines. Ultimately, this could lead to a more catastrophic failure.

3.2 It is not known whether these pipelines are already acoustically monitored, but if they're not, it would be possible to install equipment to specifically monitor the section of pipeline crossing the Augean site. Typically, this would consist of a pair of monitoring devices (ultrasonic / acoustic / correlators) which could be fixed to the outside of the pipelines at each end of the section to be monitored. These would detect any low-level leaks that may be developing in the pipelines, giving operators the location of the defect to enable a timely repair to be carried out.

3.3 It was indicated by AWS at the hearing held on 8th June 2022 that the pipelines have an impressed current cathodic protection system in place, but they were unsure whether or not this was working. Cathodic protection is a process by which steel pipelines are electrically protected, either by provision of sacrificial anodes, or by application of an impressed current. It is typically used in more aggressive ground conditions as a back-up corrosion control measure in the event of damage to the external pipe coating.



4 External loading & potential for damage

- 4.1 Standard vehicular loading applied to pipeline structural design is laid out in BS EN 1295-1 (1997) National Annex A (likely to be the standard in place when the pipelines were laid), or in the more recent BS 9295 (2020). Both give vehicular loadings at various depths of cover for standard scenarios of main roads, light roads (omitted from BS 9295), and fields, as well as construction plant and rail loadings. The loadings incorporate an impact factor, to account for the dynamic effect of the vehicle movements. Vibration effects are not taken into account separately and are usually only considered where buried pipelines are likely to be subjected to the effects of piling or explosions arising from mining etc.
- 4.2 For more specific types of plant, a bespoke analysis can be carried out using Holl's integration of the Boussinesq equation. This is a standard way in pipeline engineering to evaluate the pressure at pipe crown of loads applied at the ground surface, and the procedure is laid out in the TRRL document "A guide to design loadings for buried rigid pipes" (1983), Appendix 2. The types of plant that would likely be used in the future development of the Augean ENRMF site have been analysed in this way, which has yielded the following results, for two likely burial depth scenarios. The burial depths used are 1.2m cover, a typical burial depth for water mains, and an indicated likely depth from AWS, and 3m cover, an estimated likely worst-case burial depth. The details of this analysis can be found in Appendix A.



Figure 1 – Vehicular loading

| Vehicle | Load at pipe crown at 1.2m cover depth (kN/m ²) | Load at pipe crown at 3m cover depth (kN/m ²) | Image |
|-------------------------------|---|---|-------|
| Hitachi ZX670LCH-3 or similar | 77.59 | 18.93 | |
| A40 dump truck or similar | 108.31 | 35.90 | |

4.3 These loadings have then been taken forward in calculations laid out in BS 9295 (2020) "Guide to the structural design of buried pipes". The pipelines are currently in a loading condition that would be defined in the current standard BS 9295 (2020) as "Fields & Gardens". In the earlier standard, BS EN 1295-1 National Annex A, this loading would have been classified as "Fields" (numerically, these two loading scenarios are the same). The date at which the pipelines were installed is not known, but is assumed to be approximately 25 years ago. Therefore, the standard that would have been used for the original structural pipeline design would have been BS EN 1295-1



(1997) "Structural design of buried pipelines under various conditions of loading".

- 4.4 The standard wall thickness for an 800mm diameter steel pipe supplied by Frazer and Tabberer is 7.1mm, which is a typical value for steel pipes of this diameter supplied to the water industry.
- 4.5 Steel pipes are generally classified as flexible in their behaviour, since their response to external load is to deflect into an out-of-circle shape. Calculations have been undertaken, following the procedure set out in BS 9295 (2020), Section 7 "Flexible Pipe Design". The details of this analysis can be found in Appendix B. Figure 2 below summarises the results using the original wall thickness of 7.1mm. Figure 3 shows the results using a reduced wall thickness scenario of 5.5mm (a corrosion allowance around the full circumference of 1.6mm).

Figure 2 – Structural analysis using a 7.1mm wall thickness

| | | Burial depth = 1.2m | | |
|----------------------|-------------------|-------------------------------------|----------------|-----------------|
| | | Pipe wall thickness = 7.1mm | | |
| | | Field loading (current scenario) | A40 Dump Truck | Large Excavator |
| Earth Pressure | kN/m ² | 23.76 | 23.76 | 23.76 |
| Vehicular loading | kN/m ² | 27.21 | 108.00 | 77.59 |
| Total pressure | kN/m ² | 50.97 | 131.76 | 101.35 |
| FOS against buckling | Must be >2 | 7.83 | 3.06 | 3.98 |
| Ovalisation | Must be < 3% | 1.05 | 2.39 | 1.88 |

| | | Burial depth = 3m | | |
|----------------------|-------------------|-------------------------------------|----------------|-----------------|
| | | Pipe wall thickness = 7.1mm | | |
| | | Field loading (current scenario) | A40 Dump Truck | Large Excavator |
| Earth Pressure | kN/m ² | 59.40 | 59.40 | 59.40 |
| Vehicular loading | kN/m ² | 5.47 | 35.90 | 18.93 |
| Total pressure | kN/m ² | 64.87 | 95.30 | 78.33 |
| FOS against buckling | Must be >2 | 6.18 | 4.23 | 5.13 |
| Ovalisation | Must be < 3% | 1.97 | 2.60 | 2.25 |



Figure 3 – Structural analysis using a 5.5mm wall thickness

| | | Burial depth = 1.2m | | |
|----------------------|-------------------|-------------------------------------|----------------|-----------------|
| | | Pipe wall thickness = 5.5mm | | |
| | | Field loading (current scenario) | A40 Dump Truck | Large Excavator |
| Earth Pressure | kN/m ² | 23.76 | 23.76 | 23.76 |
| Vehicular loading | kN/m ² | 27.21 | 108.00 | 77.59 |
| Total pressure | kN/m ² | 50.97 | 131.76 | 101.35 |
| FOS against buckling | Must be >2 | 6.09 | 2.39 | 3.09 |
| Ovalisation | Must be < 3% | 1.20 | 2.73 | 2.15 |

| | | Burial depth = 3m | | |
|----------------------|-------------------|-------------------------------------|----------------|-----------------|
| | | Pipe wall thickness = 5.5mm | | |
| | | Field loading (current scenario) | A40 Dump Truck | Large Excavator |
| Earth Pressure | kN/m ² | 59.40 | 59.40 | 59.40 |
| Vehicular loading | kN/m ² | 5.47 | 35.90 | 18.93 |
| Total pressure | kN/m ² | 64.87 | 95.30 | 78.33 |
| FOS against buckling | Must be >2 | 4.81 | 3.29 | 3.99 |
| Ovalisation | Must be < 3% | 2.25 | 2.97 | 2.57 |

4.6 These results show that, whilst the pipelines may not have been originally designed to accommodate significant vehicular loading, the pipelines comfortably pass the ovalisation check, and have a factor of safety against buckling significantly greater than the required value of 2 in all loading cases, using the original wall thickness. Even at a reduced pipe wall thickness of 5.5mm, the structural calculations pass all the required design checks. This demonstrates that there is a very low risk of an increased vehicular loading being detrimental to the integrity of the pipelines.

4.7 Despite the results of the analysis above, it is recommended that designated crossing points are constructed to allow vehicular movement across the pipelines, simply to ensure that the ground surface doesn't deteriorate. Rutting of the ground surface could result in wheel loads becoming unacceptably close to the pipeline crowns, and this should be avoided. However, the analysis has shown that the predicted loads are unlikely to compromise the




structural integrity of the pipelines. The options for the crossing detail could range from a simple slab or crane mat at ground level, in order to protect the ground surface and spread the loads, to a piled bridge construction which would take any loads to below the invert level of the pipelines. A piled bridge solution is seen as an extreme solution not justified by the preliminary analysis undertaken, and whose construction would introduce new risks of load and vibration in close proximity to the pipelines. For these reasons, the piled bridge option is not a preferred crossing solution.

5 Potential size of crater in the event of pipe rupture

- 5.1 The potential size of crater has been calculated using geometry, for a number of different burial depths, and assuming a worst-case scenario of both pipelines failing. An angle of repose of 45 degrees has been used, which is a very conservative estimate for the stiff clay found in the boreholes on site (this angle of repose is more commonly used with looser, granular soils). An average pipe spacing centre to centre of 5m has been assumed.
- 5.2 Although a burial depth to pipe crown of 1.2m has been indicated by AWS, a further conservative estimate of 3m burial to pipe crown is suggested as a reasonable worst-case assumption. As can be seen from Figure 3 below, this would lead to a crater size of diameter approximately 12.6m.



Figure 4 – Diameter of failure crater




| | | | | | |
|---------------------------------|---------|-------|-------|-------|-------|
| Depth to pipe crown | m | 1.5 | 2 | 2.5 | 3 |
| Pipe spacing (centre to centre) | m | 5 | 5 | 5 | 5 |
| Pipe inside diameter | m | 0.8 | 0.8 | 0.8 | 0.8 |
| Pipe outside diameter | m | 0.813 | 0.813 | 0.813 | 0.813 |
| Depth to springing | m | 1.91 | 2.41 | 2.91 | 3.41 |
| Worst case angle of repose | degrees | 45 | 45 | 45 | 45 |

| | | | | | |
|-----------------|---|-------|-------|-------|-------|
| Dimension A | m | 1.91 | 2.41 | 2.91 | 3.41 |
| Dimension B | m | 5.813 | 5.813 | 5.813 | 5.813 |
| Crater diameter | m | 9.63 | 10.63 | 11.63 | 12.63 |

5.3 It has been indicated by AWS that the pipelines run at a pressure of 8 bars. They are gravity fed from the Wing WTW, taking potable water to the city of Peterborough. Examination of the topography of the land between Wing and Peterborough, and accounting for the level at the Augean site would suggest that the likely pressure in the mains at the Augean site is approximately 2.6 bars. This is shown in Figure 5 below:



Figure 5 – Profile of the ground between Wing WTW and Peterborough




5.4 Despite the apparent pressure at the ENRMF site being approximately 2.6 bars, the structural design calculations have been undertaken using an internal pressure of 8 bars as stated by AWS.

6 Stability of pipelines due to excavations & effect of shrink/swell clays

- 6.1 It is understood from the soils investigations undertaken at the ENRMF site that the soils are stiff clays, which may be subject to shrink / swell upon loading and unloading.
- 6.2 When designing new pipelines, it is generally accepted that when the trench width is greater than 4.3 multiplied by the pipe outside diameter, the effect of the native soil to the sides of the pipe are ignored (see BS 9295 (2020) section 7.2.5). It is stated in Section 4.6 of that standard that "the zone of soil which has a structural




influence on the buried pipe typically extends between one and two diameters from the pipe wall in all directions” (see Figure 6).



6.3 The stand-off dimension proposed by Augean of between 7m and 30m is more than adequate in all cases to ensure that the pipelines will be unaffected by any excavations taking place, and the presence of the excavation activity will not increase the likelihood of pipe failure from the shrink/swell effects associated with the excavation of the clay.

7 Access for pipe repair

7.1 A key consideration is the future access to the full length of the pipelines crossing the ENRMF site for maintenance purposes. The worst-case scenario is that of a catastrophic burst affecting both pipelines, as outlined in Section 5 above.



7.2 If a burst were to occur, the following general steps are taken:

- Isolation of the affected pipeline.
- Removal of water at ground level and in crater.
- Secure the crater to allow safe access and establish safe working area.
- Repair can commence.



When a repair is undertaken, every effort is made to ensure the cleanliness of the pipeline is not compromised. Water and soil debris are kept away from the internal surfaces of the existing pipeline, the repair piece and couplings. AWS will have strict protocols regarding mains repair to ensure no contamination of the water occurs, and typically this will include spraying repair pieces and fittings with chlorous acid or similar, flushing of the main, and bacteriological sampling after completion of the repair to demonstrate water hygiene compliance.

- 7.3 All the activities for the repair of a pipeline burst outlined in 7.2 above can be safely carried out within the proposed stand-off distances of 7m to 30m, and well within the 20m stated as preferred by AWS.

8 Effect of water in pipeline embedment

- 8.1 Anecdotally, the pipelines do not have a full gravel embedment. It has been indicated by AWS that the pipelines are laid in gravel to their haunch level, with the remaining backfill being an as-dug material.
- 8.2 Generally, gravel pipe embedment can act like a land drain, and for this reason, it is good practice that impermeable layers are placed at regular intervals across the pipe trench in order to discourage the flow of water within the embedment. Whilst it is not known if this was done during the construction of the pipelines, since it is general good practice, it is assumed to have taken place.
- 8.3 If the ground water is static, it is unlikely to cause deterioration of the pipeline coatings, or to cause a loss of support to the pipelines. The groundwater body at the site is well below the level of the pipelines



and, as addressed in the Pipeline Risk Assessment report, the Surface Water Management Plan is designed to maintain the surface water flow to follow the pre-development pattern.

9 Conclusions

- 9.1 The steel pipeline material is ductile, and any deterioration is likely to come about via local through wall corrosion, rather than catastrophic rupture.
- 9.2 The pipelines can be readily monitored to mitigate the risk of leakage / corrosion effects.
- 9.3 External loads placed on the pipelines due to future plant and equipment is unlikely to cause detriment to the pipelines as long as the surface is appropriately protected.
- 9.4 In the very unlikely event that a pipeline rupture were to occur, involving the failure of both pipelines together, the likely diameter of the resulting crater is around 12.5m (from a reasonable worst-case assumed pipeline burial depth of 3m).
- 9.5 The pressure in the pipelines at the Augean site is likely to be approximately 2.6 bars.
- 9.6 Water in the pipeline embedment should not significantly increase the risk of corrosion.
- 9.7 The suggested stand-off range of between 7m and 30m proposed by Augean includes the 20m distance preferred by AWS which is more than adequate to allow for the access, maintenance and repair of the pipelines, even in the unlikely event of a significant rupture.



References

BS 9295 (2020) – Guide to the structural design of buried pipes under various conditions of load.

BS EN 1295-1 (1997) – Structural design of buried pipelines under various conditions of loading

TRRL – A guide to design loadings for buried rigid pipes (1983).



Pipetechnics Ltd.

APPENDIX A

Vehicular loading analysis



CALCULATION PACK

DOCUMENT No

PT/AU/Vehicular loads_1.2m

PROJECT NO.

PROJECT TITLE

N/A

Augean / ENRMF site

SUBJECT

SHEET No

Vehicular loading calcs @ 1.2m depth of cover

1 of 3

| ISSUE | TOTAL SHEET (S) | AUTHOR | DATE | CHECKED BY | DATE | APPROVED BY | DATE | COMMENTS |
|-------|-----------------|--------|----------|------------|----------|-------------|------|-------------|
| 1 | 3 | SJRD | 24/05/22 | SJRD | 27/05/22 | | | First Draft |
| 2 | | | | | | | | |
| 3 | | | | | | | | |
| 4 | | | | | | | | |

SUPERSEDES DOC No

DATE

DESIGN BASIS STATEMENT (Inc. sources of info/data, assumptions made, standards, etc.)

Source of Info

1. ENRMF DCO Application Anglian Water Pipelines. Table 1 Scoping Table for Scenarios of Risk Assessment
- 2.
- 3.


Standards and References

4. TRRL A guide to design loadings for buried rigid pipes, Appendix 2
- 5.
- 6.
- 7.

Remit

PROJECT: Augean ENRMF site
 Part of Work: Effect of A40 dump truck on buried steel pipelines
 Date: 24-May-22
 Job Number:
 Calcs by: SJRD
 Checked:
 Reviewed:

Data Sheets



| Pos | Metric (mm) | | Imperial (Feet) | |
|----------------|-------------|--------|-----------------|--------|
| | A35D | A40D | A35D | A40D |
| A | 11 178 | 11 287 | 36'8" | 37'0" |
| A ₂ | 6 224 | 6 428 | 20'5" | 21'1" |
| B | 5 527 | 5 730 | 18'2" | 18'10" |
| C | 3 681 | 3 746 | 12'1" | 12'0" |
| C ₁ | 3 566 | 3 626 | 11'8" | 11'5" |
| C ₂ | 1 768 | 1 768 | 5'10" | 5'10" |
| C ₃ | 3 987 | 4 093 | 13'1" | 13'5" |
| D | 3 103 | 3 103 | 10'2" | 10'2" |
| E | 1 976 | 1 976 | 4'9" | 4'9" |
| F | 4 501 | 4 448 | 14'9" | 14'7" |
| G | 1 820 | 1 940 | 6'0" | 6'3" |
| H | 1 754 | 1 796 | 5'9" | 5'11" |
| I | 726 | 638 | 2'5" | 2'1" |
| J | 2 912 | 3 075 | 9'7" | 10'1" |
| K | 2 302 | 2 492 | 7'7" | 8'2" |
| L | 915 | 896 | 3'0" | 3'0" |
| M | 7 242 | 7 384 | 23'9" | 24'3" |
| N | 8 720 | 8 863 | 28'7" | 29'1" |
| N ₁ | 4 367 | 4 238 | 14'5" | 13'11" |
| O | 3 103 | 3 268 | 10'2" | 10'9" |
| P | 2 870 | 3 076 | 9'5" | 10'1" |
| R | 384 | 654 | 1'11" | 2'2" |
| R ₁ | 670 | 761 | 2'2" | 2'6" |
| U | 3 528 | 3 590 | 11'7" | 11'9" |
| V | 2 515 | 2 636 | 8'3" | 8'8" |
| V' | 2 626 | --- | 8'7" | --- |
| W | 3 208 | 3 432 | 10'6" | 11'3" |
| W ₁ | 3 410 | 3 570 | 11'2" | 11'9" |
| X | 572 | 617 | 1'11" | 2'0" |
| X ₁ | 606 | 639 | 1'10" | 2'1" |
| X ₂ | 720 | 765 | 2'4" | 2'6" |
| Y | 2 515 | 2 636 | 8'3" | 8'8" |
| Y' | 2 626 | --- | 8'7" | --- |
| Z | 3 208 | 3 432 | 10'6" | 11'3" |
| Z ₁ | 3 410 | 3 570 | 11'2" | 11'9" |
| a ₁ | 23" | 29" | 23" | 29" |
| a ₂ | 70" | 70" | 70" | 70" |
| a ₃ | 45" | 45" | 45" | 45" |


| Weights | | |
|---------------------------|--------------------------------|--------------------------------|
| Tires | A35D | A40D |
| | 26,5R25" | 29,5R25" |
| Operating weight unloaded | | |
| Front | 15 320 kg 33 776 lb | 16 300 kg 35 935 lb |
| Rear | 12 980 kg 28 616 lb | 14 070 kg 31 005 lb |
| Total | 28 300 kg 62 391 lb | 31 270 kg 68 938 lb |
| Payload | 32 500 kg 71 650 lb | 37 000 kg 81 571 lb |
| Total weight | | |
| Front | 17 770 kg 39 176 lb | 19 170 kg 42 263 lb |
| Rear | 43 030 kg 94 865 lb | 49 100 kg 108 247 lb |
| Total | 60 800 kg 134 041 lb | 68 270 kg 150 509 lb |

Operating weight includes all fluids and operator
 * A35D with tires 775/65R29, add 200 kg
 (441 lb) axle
 * A40D with tires 875/65R29, add 300 kg
 (661 lb) axle

| Load Capacity | | |
|------------------------|--|--|
| | A35D | A40D |
| Standard Body | | |
| Load capacity | 32 500 kg 36 sh tn | 37 000 kg 41 sh tn |
| Body, struck | 15.2 m ³ 19.9yd³ | 16.0 m ³ 21.1yd³ |
| Body, heaped | 20.0 m ³ 26.2yd³ | 22.5 m ³ 29.4yd³ |
| With overhung tailgate | | |
| Body, struck | 15.5 m ³ 20.3yd³ | 17.2 m ³ 22.5yd³ |
| Body, heaped | 20.7 m ³ 27.1yd³ | 23.2 m ³ 30.3yd³ |

Body volume according to SAE 2:1

Wheel Arrangement



Calculations

| Wheel | Virtual Rectangles | Dimensions (m) | |
|-------|--------------------|----------------|-------|
| | | B | L |
| A | AQTS | 0.407 | 3.948 |
| | ARVS | 0.407 | 4.948 |
| B | KLBQ | 0.407 | 0.5 |
| | JMZE | 3.043 | 4.948 |
| E | JKYE | 3.043 | 3.948 |
| | SVZE | 2.230 | 4.948 |
| | STYE | 2.230 | 3.948 |
| F | KLFY | 3.043 | 0.5 |
| | TUFY | 2.230 | 0.5 |
| C | QCWT | 0.407 | 2.44 |
| | RCWV | 0.407 | 1.44 |
| | KNGY | 3.043 | 2.44 |
| G | MNGZ | 3.043 | 1.44 |
| | TWGY | 2.230 | 2.44 |
| | VWGZ | 2.230 | 1.44 |

Variable Inputs

| | | |
|-----------------------------|--------|-------------------------------|
| Vehicle Axle Spacing 1 (m) | 4.448 | Dimension F |
| Vehicle Axle Spacing 2 (m) | 1.94 | Dimension G |
| Vehicle Axle Length (m) | 2.636 | Dimension V/V' |
| Load per axle (front) kg | 19170 | |
| Load per axle (rear) kg | 90000 | |
| Load per Wheel (front) (kN) | 94.03 | |
| Load per Wheel (rear) (kN) | 220.73 | |
| Wheel Impact Factor | 1.7 | Construction plant (ref TRRL) |
| External Pipe Diameter (m) | 0.81 | |

Results Summary

| Depth to Pipe Crown (m) | Pressure (kN/m ²) |
|-------------------------|-------------------------------|
| 1.2 | 108.305 |


Load Calculations

| Depth under consideration (m) | |
|---|-----------|
| being considered | Value IQ |
| AQTS | 0.100 |
| ARVS | 0.100 |
| KLBQ | 0.054 |
| JMZE | 0.244 |
| JKYE | 0.243 |
| SVZE | 0.237 |
| STYE | 0.236 |
| KLFY | 0.118 |
| TUFY | 0.117 |
| QCWT | 0.099 |
| RCWV | 0.093 |
| KNGY | 0.237 |
| MNGZ | 0.215 |
| TWGY | 0.231 |
| VWGZ | 0.211 |
| Load Coeff for Each Wheel | |
| A | 0.000339 |
| B | 0.217229 |
| C | 0.012371 |
| E | 0.000165 |
| F | 0.003469 |
| G | 0.001377 |
| Sum of Load Coeff (front) | 0.000503 |
| Load (front) (kN) | 0.080478 |
| Sum of Load Coeff (rear) | 0.234446 |
| Load (rear) (kN) | 87.971580 |
| TOTAL LOAD (kN) | 88.052 |
| Total Pressure on Pipe Crown (kN/m ²) | 108.305 |

| | | | |
|--------------|---|------------|-----------|
| PROJECT | Augean ENRMF site | Date | 24-May-22 |
| Part of Work | Effect of Hitachi large excavator on buried steel pipelines | Job Number | |
| Calcs by | SJRD | Checked | |
| | | Reviewed | |

Data Sheets

DIMENSIONS



| Retractable gauge | ZX670LC-sq | ZX670LCH-sq |
|---|-----------------|---------------|
| A Distance between tumbler | 4 590 | 4 590 |
| B Undercarriage length | 5 840 | 5 840 |
| * C Counterweight clearance | 1 530 | 1 530 |
| D Rear-end swing radius | 4 020 | 4 020 |
| D' Rear-end length | 3 910 | 3 910 |
| E Overall width upperstructure | 4 090 | 4 090 |
| F Overall height of cab | 3 550 | 3 660 |
| * G Min. ground clearance | 860 | 860 |
| H Track gauge : Extended / Retracted | 3 300 / 2 830 | 3 300 / 2 830 |
| I Track shoe width | 650 / 750 / 900 | 650 |
| J Undercarriage width with 650 mm shoe | 3 950 / 3 480 | 3 950 / 3 480 |
| : Extended / Retracted with 750 mm shoe | 4 050 / 3 580 | — |
| with 900 mm shoe | 4 200 / 3 730 | — |
| K Overall width | 4 360 | 4 360 |
| L Overall length | 13 400 | 13 400 |
| M Overall height of boom | 4 460 | 4 460 |
| N Track height | 1 440 | 1 440 |


Unit: mm
*) Excluding track shoe lug

WEIGHTS AND GROUND PRESSURE

Operating Weight and Ground Pressure

| Shoe type | | Boom type | | Arm type | | ZX670LC-sq | | |
|-----------|---------------------------|-----------|---------------------------|--------------------|---------------------------|------------|---------------------------|--------------------|
| kg | kPa (kg/ft ²) | kg | kPa (kg/ft ²) | kg | kPa (kg/ft ²) | kg | kPa (kg/ft ²) | |
| 600 mm | 6.6 m BE | 2.9 m BE | 67 300 | 3.5 m ² | 101 (1.03) | 67 300 | 101 (1.03) | |
| | | | | | | | | Bucket capacity |
| | 7.8 m | 3.5 m | 66 800 | 2.5 m ³ | 101 (1.02) | 67 000 | 101 (1.02) | |
| | | | | | | | | Bucket capacity |
| | Double | 7.8 m | 3.5 m | 67 200 | 2.5 m ³ | 87 (0.89) | 67 200 | 87 (0.89) |
| | | | | | | | | |
| 7.8 m | | 4.2 m | 67 400 | 2.5 m ³ | 88 (0.89) | 67 400 | 88 (0.89) | |
| | | | | | | | | Bucket capacity |
| 900 mm | | 6.6 m BE | 2.9 m BE | 68 700 | 3.5 m ² | 74 (0.76) | 68 700 | 74 (0.76) |
| | | | | | | | | |
| | 7.8 m | 3.5 m | 68 200 | 2.5 m ³ | 74 (0.76) | 68 400 | 74 (0.76) | |
| | | | | | | | | Bucket capacity |
| 7.8 m | 4.2 m | 68 400 | 2.5 m ³ | 74 (0.76) | 68 400 | 74 (0.76) | | |
| | | | | | | | Bucket capacity | 2.5 m ³ |

Wheel Arrangement



Calculations

| Wheel | Virtual Rectangles | Dimensions (m) | |
|-------|--------------------|----------------|------|
| | | B | L |
| A | AQTU | 0.4065 | 0.5 |
| B | BQTW | 0.4065 | 5.09 |
| | BRVW | 0.4065 | 4.09 |
| C | CLKY | 3.2365 | 0.5 |
| | CUTY | 2.4235 | 0.5 |
| D | DNKY | 3.2365 | 5.09 |
| | DWTY | 2.4235 | 5.09 |
| | DNMZ | 3.2365 | 4.09 |
| | DWVZ | 2.4235 | 4.09 |

Variable Inputs

| | |
|-----------------------------|--------|
| Vehicle Axle Spacing 1 (m) | 4.59 |
| Vehicle Axle Length (m) | 2.83 |
| Total operating weight (kg) | 68700 |
| Assumed Load per Wheel (kN) | 168.49 |
| Wheel Impact Factor | 1.7 |
| External Pipe Diameter (m) | 0.81 |

Dimension A
Dimension H
Worst case

Results Summary

| | |
|-------------------------|-------------------------------|
| Depth to Pipe Crown (m) | Pressure (kN/m ²) |
| 1.2 | 77.586 |

Construction plant (ref TRRL)

Load Calculations

Depth under consideration (m) **1.2**

| Virtual Rectangle being considered | Influence Value IQ |
|--|--------------------|
| AQTU | 0.054 |
| BQTW | 0.100 |
| BRVW | 0.100 |
| CLKY | 0.119 |
| CUTY | 0.117 |
| DNKY | 0.245 |
| DWTY | 0.240 |
| DNMZ | 0.244 |
| DWVZ | 0.239 |
| Load Coeff for Each Wheel | |
| A | 0.217229 |
| B | 0.000292 |
| C | 0.002566 |
| D | 0.000134 |
| Sum of Load Coeff | 0.220 |
| Total Load (kN) | 63.077 |
| Total Pressure on Pipe Crown (kN/m²) | 77.586 |



CALCULATION PACK

DOCUMENT No

PT/AU/Vehicular loads_3m

PROJECT NO.

PROJECT TITLE

N/A

Augean / ENRMF site

SUBJECT

SHEET No

Vehicular loading calcs @ 3m depth of cover

1 of 3

| ISSUE | TOTAL SHEET (S) | AUTHOR | DATE | CHECKED BY | DATE | APPROVED BY | DATE | COMMENTS |
|-------|-----------------|--------|----------|------------|----------|-------------|------|-------------|
| 1 | 3 | SJRD | 24/05/22 | SJRD | 27/05/22 | | | First Draft |
| 2 | | | | | | | | |
| 3 | | | | | | | | |
| 4 | | | | | | | | |

SUPERSEDES DOC No

DATE

DESIGN BASIS STATEMENT (Inc. sources of info/data, assumptions made, standards, etc.)

Source of Info

1. ENRMF DCO Application Anglian Water Pipelines. Table 1 Scoping Table for Scenarios of Risk Assessment
- 2.
- 3.


Standards and References

4. TRRL A guide to design loadings for buried rigid pipes, Appendix 2
- 5.
- 6.
- 7.

Remit

PROJECT: Augean ENRMF site
 Part of Work: Effect of A40 dump truck on buried steel pipelines @ 3m burial depth
 Date: 24-May-22
 Job Number: _____
 Calcs by: SJRD
 Checked: _____
 Reviewed: _____

Data Sheets



| Pos | Metric (mm) | | Imperial (Feet) | |
|----------------|-------------|--------|-----------------|--------|
| | A35D | A40D | A35D | A40D |
| A | 11 178 | 11 381 | 36'6" | 37'0" |
| A ₂ | 6 224 | 6 426 | 20'5" | 21'1" |
| B | 5 527 | 5 730 | 18'2" | 18'10" |
| C | 3 681 | 3 746 | 12'1" | 12'3" |
| C ₁ | 3 560 | 3 626 | 11'8" | 11'11" |
| C ₂ | 1 768 | 1 768 | 5'10" | 5'10" |
| C ₃ | 3 987 | 4 053 | 13'1" | 13'3" |
| D | 3 103 | 3 103 | 10'2" | 10'2" |
| E | 1 275 | 1 275 | 4'2" | 4'2" |
| F | 4 501 | 4 448 | 14'9" | 14'7" |
| G | 1 820 | 1 940 | 6'0" | 6'3" |
| H | 1 754 | 1 796 | 5'9" | 6'1" |
| I | 726 | 688 | 2'4" | 2'3" |
| J | 2 912 | 3 075 | 9'7" | 10'1" |
| K | 2 302 | 2 492 | 7'7" | 8'2" |
| L | 915 | 906 | 3'0" | 3'0" |
| M | 7 242 | 7 384 | 23'9" | 24'3" |
| N | 6 720 | 6 853 | 22'0" | 22'1" |
| N ₁ | 4 287 | 4 298 | 14'1" | 13'11" |
| O | 3 103 | 3 066 | 10'2" | 10'0" |
| P | 2 870 | 3 078 | 9'5" | 10'1" |
| R | 584 | 654 | 1'11" | 2'2" |
| R ₁ | 670 | 751 | 2'2" | 2'6" |
| U | 3 528 | 3 550 | 11'5" | 11'5" |
| V | 2 515 | 2 636 | 8'3" | 8'8" |
| V' | 2 625 | ----- | 8'7" | ----- |
| W | 3 208 | 3 432 | 10'6" | 11'3" |
| W ₁ | 3 410 | 3 570 | 11'2" | 11'5" |
| X | 572 | 617 | 1'11" | 2'0" |
| X ₁ | 606 | 658 | 1'10" | 2'1" |
| X ₂ | 720 | 765 | 2'4" | 2'6" |
| Y | 2 515 | 2 636 | 8'3" | 8'8" |
| Y' | 2 625 | ----- | 8'7" | ----- |
| Z | 3 208 | 3 432 | 10'6" | 11'3" |
| Z ₁ | 3 410 | 3 570 | 11'2" | 11'5" |
| a ₁ | 22" | 20" | 29" | 25" |
| a ₂ | 70" | 70" | 70" | 70" |
| a ₃ | 45" | 45" | 45" | 45" |

| Weights | | | |
|---------------------------|-------------------|-------------------|--|
| Tires | A35D | A40D | |
| Operating weight unloaded | | | |
| Front | 15 320 kg | 16 300 kg | |
| | 33 775 lb | 35 935 lb | |
| Rear | 12 980 kg | 14 970 kg | |
| | 28 616 lb | 33 003 lb | |
| Total | 28 300 kg | 31 270 kg | |
| | 62 391 lb | 68 938 lb | |
| Payload | 32 500 kg | 37 000 kg | |
| | 71 650 lb | 81 571 lb | |
| Total weight | | | |
| Front | 17 770 kg | 19 170 kg | |
| | 39 176 lb | 42 263 lb | |
| Rear | 43 030 kg | 49 100 kg | |
| | 94 865 lb | 108 247 lb | |
| Total | 60 800 kg | 68 270 kg | |
| | 134 041 lb | 150 509 lb | |


Operating weight includes all fluids and operator
 *) A35D with tires 775/65R20, add 200 kg (441 lb) axle
 **) A40D with tires 875/65R20, add 300 kg (661 lb) axle

| Load Capacity | | |
|------------------------|---------------------------|---------------------------|
| | A35D | A40D |
| Standard Body | | |
| Load capacity | 32 500 kg | 37 000 kg |
| | 36 sh tn | 41 sh tn |
| Body, struck | 15.2 m ³ | 16.8 m ³ |
| | 19.9yd³ | 22.1yd³ |
| Body, heaped | 20.0 m ³ | 22.5 m ³ |
| | 26.2yd³ | 29.4yd³ |
| With overhang tailgate | | |
| Body, struck | 15.5 m ³ | 17.2 m ³ |
| | 20.3yd³ | 22.5yd³ |
| Body, heaped | 20.7 m ³ | 23.2 m ³ |
| | 27.1yd³ | 30.3yd³ |

Body volume according to SAE 2-1

A35D: Unloaded machine with 26.5R20
 A40D: Unloaded machine with 29.5R29
 *) A35D with optional 775/65R20 tires
 **) A40D with optional 875/65R20 tires

Wheel Arrangement



Calculations

| Wheel | Virtual Rectangles | Dimensions (m) | |
|-------|--------------------|----------------|-------|
| | | B | L |
| A | AQTS | 0.407 | 3.948 |
| | ARVS | 0.407 | 4.948 |
| B | KLBO | 0.407 | 0.5 |
| | JMZE | 3.043 | 4.948 |
| E | JKYE | 3.043 | 3.948 |
| | SVZE | 2.230 | 4.948 |
| | STYE | 2.230 | 3.948 |
| F | KLFY | 3.043 | 0.5 |
| | TUFY | 2.230 | 0.5 |
| C | QCWT | 0.407 | 2.44 |
| | RCWV | 0.407 | 1.44 |
| G | KNGY | 3.043 | 2.44 |
| | MNGZ | 3.043 | 1.44 |
| | TWGY | 2.230 | 2.44 |
| | VWGZ | 2.230 | 1.44 |

Results Summary

| Depth to Pipe Crown (m) | Pressure (kN/m ²) |
|-------------------------|-------------------------------|
| 3.0 | 35.904 |

Variable Inputs

| | |
|-----------------------------|--------|
| Vehicle Axle Spacing 1 (m) | 4.448 |
| Vehicle Axle Spacing 2 (m) | 1.94 |
| Vehicle Axle Length (m) | 2.636 |
| Load per axle (front) kg | 19170 |
| Load per axle (rear) kg | 90000 |
| Load per Wheel (front) (kN) | 94.03 |
| Load per Wheel (rear) (kN) | 220.73 |
| Wheel Impact Factor | 1.7 |
| External Pipe Diameter (m) | 0.81 |

Dimension F
 Dimension G
 Dimension V/Y

Construction plant (ref TRRL)


Load Calculations

| Depth under consideration (m) | |
|--|---------------|
| being considered | 3.0 |
| AGTS | 0.040 |
| ARVS | 0.041 |
| KLBO | 0.010 |
| JMZE | 0.197 |
| JKYE | 0.190 |
| SVZE | 0.171 |
| STYE | 0.166 |
| KLFY | 0.046 |
| TUFY | 0.041 |
| QCWT | 0.035 |
| RCWV | 0.026 |
| KNGY | 0.162 |
| MNGZ | 0.117 |
| TWGY | 0.142 |
| VWGZ | 0.104 |
| Load Coeff for Each Wheel | |
| A | 0.002412 |
| B | 0.041534 |
| C | 0.018113 |
| E | 0.001398 |
| F | 0.010363 |
| G | 0.008159 |
| Sum of Load Coeff (front) | 0.003810 |
| Load (front) (kN) | 0.699013 |
| Sum of Load Coeff (rear) | 0.076169 |
| Load (rear) (kN) | 28.581061 |
| TOTAL LOAD (kN) | 29.190 |
| Total Pressure on Pipe Crown (kN/m²) | 35.904 |

PROJECT: Augean ENRMF site
 Part of Work: Effect of Hitachi large excavator on buried steel pipelines @ 3m burial depth
 Date: 24-May-22
 Job Number:
 Calcs by: SJRD
 Checked:
 Reviewed:

Data Sheets

DIMENSIONS




| Retractable gauge | ZX670LC-ss | ZX670LCH-ss |
|---|-----------------|---------------|
| A Distance between tumbler | 4 590 | 4 590 |
| B Undercarriage length | 5 840 | 5 840 |
| *1 C Counterweight clearance | 1 530 | 1 530 |
| D Rear-end swing radius | 4 020 | 4 020 |
| D' Rear-end length | 3 910 | 3 910 |
| E Overall width upperstructure | 4 090 | 4 090 |
| F Overall height of cab | 3 550 | 3 660 |
| *1 G Min. ground clearance | 860 | 860 |
| H Track gauge : Extended / Retracted | 3 300 / 2 830 | 3 300 / 2 830 |
| I Track shoe width | 650 / 750 / 900 | 650 |
| J Undercarriage width with 650 mm shoe | 3 950 / 3 480 | 3 950 / 3 480 |
| : Extended / Retracted with 750 mm shoe | 4 050 / 3 580 | - |
| with 900 mm shoe | 4 200 / 3 730 | - |
| K Overall width | 4 360 | 4 360 |
| L Overall length | 13 400 | 13 400 |
| M Overall height of boom | 4 460 | 4 460 |
| N Track height | 1 440 | 1 440 |

Unit: mm
 *1 Excluding track shoe lug

WEIGHTS AND GROUND PRESSURE

| Operating Weight and Ground Pressure | | | |
|--------------------------------------|------------|-----------|----------------|
| Shoe type | Shoe width | Boom type | Arm type |
| 600 mm | 6.6 m BE | 2.9 m BE | kg |
| | | | MPa (kg/force) |
| | 7.8 m | 3.6 m | kg |
| | | | MPa (kg/force) |
| | 7.8 m | 4.2 m | kg |
| | | | MPa (kg/force) |
| Double | 6.6 m BE | 2.9 m BE | kg |
| | | | MPa (kg/force) |
| | 7.8 m | 3.6 m | kg |
| | | | MPa (kg/force) |
| | 7.8 m | 4.2 m | kg |
| | | | MPa (kg/force) |
| 900 mm | 6.6 m BE | 2.9 m BE | kg |
| | | | MPa (kg/force) |
| | 7.8 m | 3.6 m | kg |
| | | | MPa (kg/force) |
| | 7.8 m | 4.2 m | kg |
| | | | MPa (kg/force) |

Wheel Arrangement



Calculations

| Wheel | Virtual Rectangles | Dimensions (m) | |
|-------|--------------------|----------------|------|
| | | B | L |
| A | AQTU | 0.4065 | 0.5 |
| | BQTV | 0.4065 | 5.09 |
| B | BRVW | 0.4065 | 4.09 |
| | CLKY | 3.2365 | 0.5 |
| C | CUTY | 2.4235 | 0.5 |
| | DNKY | 3.2365 | 5.09 |
| D | DWTY | 2.4235 | 5.09 |
| | DNMZ | 3.2365 | 4.09 |
| | DWVZ | 2.4235 | 4.09 |
| | | | |

Variable Inputs

| | |
|-----------------------------|--------|
| Vehicle Axle Spacing 1 (m) | 4.59 |
| Vehicle Axle Length (m) | 2.83 |
| Total operating weight (kg) | 68700 |
| Assumed Load per Wheel (kN) | 168.49 |
| Wheel Impact Factor | 1.7 |
| External Pipe Diameter (m) | 0.81 |

Dimension A
 Dimension H
 Worst case

Results Summary

| | |
|-------------------------|-------------------------------|
| Depth to Pipe Crown (m) | Pressure (kN/m ²) |
| 3.0 | 18.928 |

Construction plant (ref TRRL)

Load Calculations

Depth under consideration (m) 3.0

| Virtual Rectangle being considered | Influence Value IQ |
|--|--------------------|
| AQTU | 0.010 |
| BQTV | 0.041 |
| BRVW | 0.040 |
| CLKY | 0.047 |
| CUTY | 0.043 |
| DNKY | 0.202 |
| DWTY | 0.179 |
| DNMZ | 0.195 |
| DWVZ | 0.174 |
| Load Coeff for Each Wheel | |
| A | 0.041534 |
| B | 0.002162 |
| C | 0.008838 |
| D | 0.001192 |
| Sum of Load Coeff | 0.054 |
| Total Load (kN) | 15.388 |
| Total Pressure on Pipe Crown (kN/m²) | 18.928 |



Pipetechnics Ltd.

APPENDIX B

Structural design of steel pipelines
at 1.2m and 3m burial depths



CALCULATION PACK

DOCUMENT No

PT/AU/Calcs_1.2m

PROJECT NO.

PROJECT TITLE

N/A

Augean / ENRMF site

SUBJECT

SHEET No

Steel Pipeline Calculations @ 1.2m cover, wall thickness 7.1mm

1 of 6

| ISSUE | TOTAL SHEET (S) | AUTHOR | DATE | CHECKED BY | DATE | APPROVED BY | DATE | COMMENTS |
|-------|-----------------|--------|----------|------------|----------|-------------|------|-------------|
| 1 | 6 | SJRD | 24/05/22 | SJRD | 27/05/22 | | | First Draft |
| 2 | | | | | | | | |
| 3 | | | | | | | | |
| 4 | | | | | | | | |

SUPERSEDES DOC No

DATE

DESIGN BA: 0.01

Source of Info

1. ENRMF DCO Application Anglian Water Pipelines. Table 1 Scoping Table for Scenarios of Risk Assessment
- 2.
- 3.

Standards and References

4. BS 9295:2020.
- 5.
- 6.
- 7.

Remit

Design Scenario:
Burial depth = 1.2m

STEEL PRESSURE PIPELINE

VARIABLE INPUTS

Pipe Properties

| | Units | Symbol | Value | Notes (assumed values etc) |
|--|-------------------|-----------------------|---------------|---|
| Is this calculation for twin steel pipes laid in a single trench? | | | Yes | Select |
| Steel Grade | | | L235 | Select pipe grade Assumed - worst case |
| Internal diameter (Nominal) | m | DN | 0.8 | Select pipe diameter |
| External diameter | m | Bc | 0.8142 | |
| Wall thickness (standard for the diameter selected) | m | t | 0.0071 | From look up table |
| Wall thickness (choose) | m | t | 0.0071 | Type in value |
| Poisson's ratio (steel) | | ν_{steel} | 0.3 | |
| Type of pipe lining | | | Cement mortar | Select Assumed - worst case |
| Cement mortar lining thickness | m | t_L | 0.01 | |
| Poisson's ratio (mortar) | | ν_{mortar} | 0.3 | |
| Weight of pipe + cement mortar | | kg/m | 219 | |
| Poisson's ratio (epoxy) | | ν_{epoxy} | N/A | |
| Weight of pipe + epoxy | | kg/m | N/A | |
| Modulus of Elasticity (steel) | MN/m ² | E | 207000 | Standard value |
| Second moment of area of pipe wall | m ⁴ /m | I | 2.98259E-08 | |
| Pipe stiffness (no CM lining) | N/m ² | S | 11743 | |
| Density of mild steel | Kg/m ³ | | 7850 | Assumed |
| Yield Strength | MN/m ² | F_y | 235 | |

Installation variables

| | | | | |
|---|-------------------|----------|-------|---|
| Depth of cover | m | H | 1.2 | ENRMF DCO application Table 1 |
| Height of water above pipeline | m | H_w | 0 | No groundwater found in any borehole |
| Trench width | m | B_d | 7 | Assumed original trench width |
| Soil density | kN/m ³ | γ | 19.8 | Typical value (BS EN 1295-1) |
| Native soil modulus | MN/m ² | E^3 | 5 | Input soil modulus from BS 9295 Table 13 (stiff clay) |
| Modulus of surround | MN/m ² | E^2 | 5 | BS 9295 Table 14 (Class B1 85% compacted gravel to pipe haunches) |
| Thickness of bedding | m | | 0.15 | Assumed - standard value |
| Deflection lag factor | | D_L | 1.5 | BS 9295 Table 14 (85% compacted graded gravel) |
| Max pressure | bar | P_i | 8 | ENRMF DCO application Table 1 |
| Min pressure - vacuum ONLY. If vacuum = 0, enter 0.01 | bar | P_u | 0.01 | No vacuum |
| If twin pipes, spacing between pipes (OD to OD) | m | s | 4.816 | Leave blank if single pipe |

Pipe Data

Source: FT Pipelines
<https://ftpipelinesystems.co.uk/wp-content/uploads/2012/11/data-sheel-large-bore-welded-joints-nov2012.pdf>

| Internal diameter | Outside diameter | steel wall thickness* | Cement mortar lining thickness | Weight of pipe + CM lining | Weight of pipe + CM lining | Weight of pipe + epoxy lining | Weight of pipe + epoxy lining | Pressure rating** |
|-------------------|------------------|-----------------------|--------------------------------|----------------------------|----------------------------|-------------------------------|-------------------------------|-------------------|
| m | m | m | m | kg/m | kN/m | kg/m | kN/m | Bar |
| 0.08 | 0.0889 | 0.0036 | 0.003 | 11.4 | 0.11 | 8 | 0.08 | 123 |
| 0.1 | 0.1145 | 0.0036 | 0.003 | 14.6 | 0.14 | 10.2 | 0.10 | 95 |
| 0.15 | 0.1683 | 0.004 | 0.003 | 23.3 | 0.23 | 16.3 | 0.16 | 73 |
| 0.2 | 0.2191 | 0.0045 | 0.004 | 34.9 | 0.34 | 24.4 | 0.24 | 64 |
| 0.25 | 0.273 | 0.005 | 0.004 | 46.9 | 0.46 | 32.8 | 0.32 | 57 |
| 0.3 | 0.3239 | 0.0056 | 0.004 | 60.9 | 0.60 | 42.6 | 0.42 | 54 |
| 0.35 | 0.3556 | 0.0056 | 0.0071 | 69.4 | 0.68 | 48.6 | 0.48 | 50 |
| 0.4 | 0.4064 | 0.0063 | 0.005 | 86.4 | 0.85 | 60.5 | 0.59 | 49 |
| 0.45 | 0.457 | 0.0063 | 0.006 | 77 | 0.76 | 55 | 0.54 | 33 |
| 0.5 | 0.508 | 0.0056 | 0.006 | 92 | 0.90 | 67 | 0.66 | 27 |
| 0.6 | 0.61 | 0.0063 | 0.008 | 130 | 1.28 | 82 | 0.80 | 26 |
| 0.7 | 0.711 | 0.0071 | 0.008 | 164 | 1.61 | 106 | 1.04 | 26 |
| 0.8 | 0.813 | 0.0071 | 0.01 | 219 | 2.15 | 136 | 1.33 | 25 |
| 0.9 | 0.914 | 0.008 | 0.01 | 266 | 2.61 | 171 | 1.68 | 25 |
| 1 | 1.016 | 0.0088 | 0.012 | 333 | 3.27 | 213 | 2.09 | 24 |
| 1.1 | 1.118 | 0.01 | 0.014 | 417 | 4.09 | 256 | 2.51 | 25 |
| 1.2 | 1.219 | 0.01 | 0.014 | 485 | 4.76 | 315 | 3.09 | 24 |

* Where more than one wall thickness is given for a size, the lower value has been taken here
 ** Where more than one pressure rating is given for a size, the lower value has been taken here

Pipe lining

| Lining | Poisson |
|---------------|---------|
| Cement mortar | 0.3 |
| Epoxy | 0.36 |

Vehicular loading data

@1.2m deep @3m deep

| | @1.2m deep | @3m deep |
|-------------------------|------------|----------|
| Main Roads | | |
| Fields & Gardens | | |
| A40 Dump Truck | 108.31 | 35.9 |
| Hitachi Large Excavator | 77.59 | 18.93 |
| | | |

General soil properties BS 9295 Section 6.6

| | | |
|------------|------|-------------------|
| K_{μ} | 0.19 | |
| K_{μ}' | 0.13 | |
| γ | 19.6 | kN/m ³ |

CALCULATIONS IN ACCORDANCE WITH BS 9295 (2020)

Fields & Gardens

| | UNIT | SYMBOL | VALUE | |
|---|-------------------|------------------|--------------|-----------------------------|
| Loading | | | | |
| Backfill pressure, <i>BS 9295 Equation 27</i> | kN/m ² | P _e | 23.76 | Fields & Gardens |
| Road traffic loading, <i>BS 9295 Section 5.3</i> | kN/m ² | P _s | 27.21 | |
| Total vertical pressure, <i>BS 9295 Equation 28</i> | kN/m ² | P | 50.97 | |
| Leonhardt's coefficient, <i>BS 9295 Equation 29</i> | | C _L | 1.00 | |
| Overall modulus of soil reaction, <i>BS 9295 Equation 30</i> | MN/m ² | E' | 5.00 | |
| Buckling | | | | |
| Critical buckling pressure, <i>BS 9295 Equation 31</i> | kN/m ² | P _{cr} | 406.90 | Fields & Gardens |
| Unconstrained buckling pressure, <i>BS 9295 Equation 34</i> | kN/m ² | P _{cra} | 0.01 | |
| Stiffness of pipe | kN/m ² | | 11.74 | |
| Deflection lag factor | | D _L | 1.50 | |
| Factor of safety (buckling - with soil support), <i>BS 9295 Equation 32, pg 52</i> | | FOS | 7.83 | |
| Factor of safety (buckling - without soil support), <i>BS 9295 Equation 33</i> | | FOS | 0.00 | Fail (FOS<1) |
| Ovalisation & Bending Stress | | | | |
| Ovalisation, <i>BS 9295 Equation 35</i> | | Δ/D | 0.01046 | Fields & Gardens |
| Ratio of wall thickness to diameter | | t/D | 0.01 | |
| Ovalisation | % | Y | 1.05 | |
| | | m | 0.008 | |
| Hoop stress (Barlow) | kN/m ² | | 45070 | |
| Factor of safety (against bursting) | | FOS | 5.21 | OK (FOS>2) |

CALCULATIONS IN ACCORDANCE WITH BS 9295 (2020)

A40 Dump Truck

| | UNIT | SYMBOL | VALUE | |
|---|-------------------|------------------|--------------|------------------------------|
| Loading | | | | |
| Backfill pressure, <i>BS 9295 Equation 27</i> | kN/m ² | P _e | 23.76 | A40 Dump Truck |
| Road traffic loading, <i>BS 9295 Section 5.3</i> | kN/m ² | P _s | 108.00 | |
| Total vertical pressure, <i>BS 9295 Equation 28</i> | kN/m ² | P | 131.76 | |
| Leonhardt's coefficient, <i>BS 9295 Equation 29</i> | | C _L | 1.00 | |
| Overall modulus of soil reaction, <i>BS 9295 Equation 30</i> | MN/m ² | E' | 5.00 | |
| Buckling | | | | |
| Critical buckling pressure, <i>BS 9295 Equation 31</i> | kN/m ² | P _{cr} | 406.90 | |
| Unconstrained buckling pressure, <i>BS 9295 Equation 34</i> | kN/m ² | P _{cra} | 0.01 | |
| Stiffness of pipe | kN/m ² | | 11.74 | |
| Deflection lag factor | | D _L | 1.50 | |
| Factor of safety (buckling - with soil support), <i>BS 9295 Equation 32, pg 52</i> | | FOS | 3.06 | |
| Factor of safety (buckling - without soil support), <i>BS 9295 Equation 33</i> | | FOS | 0.00 | Fail (FOS<1) |
| Ovalisation & Bending Stress | | | | |
| Ovalisation, <i>BS 9295 Equation 35</i> | | Δ/D | 0.02391 | |
| Ratio of wall thickness to diameter | | t/D | 0.01 | |
| Ovalisation | % | Y | 2.39 | OK (deflection<3%) |
| | | m | 0.019 | |
| Hoop stress (Barlow) | kN/m ² | | 45070 | OK (FOS>2) |
| Factor of safety (against bursting) | | FOS | 5.21 | |

CALCULATIONS IN ACCORDANCE WITH BS 9295 (2020)

Large Excavator

| | UNIT | SYMBOL | VALUE | | |
|---|-------------------|------------------|--------------|-----------------|--------------------|
| Loading | | | | | |
| Backfill pressure, <i>BS 9295 Equation 27</i> | kN/m ² | P _e | 23.76 | Large Excavator | |
| Road traffic loading, <i>BS 9295 Section 5.3</i> | kN/m ² | P _s | 77.59 | | |
| Total vertical pressure, <i>BS 9295 Equation 28</i> | kN/m ² | P | 101.35 | | |
| Leonhardt's coefficient, <i>BS 9295 Equation 29</i> | | C _L | 1.00 | | |
| Overall modulus of soil reaction, <i>BS 9295 Equation 30</i> | MN/m ² | E' | 5.00 | | |
| Buckling | | | | | |
| Critical buckling pressure, <i>BS 9295 Equation 31</i> | kN/m ² | P _{cr} | 406.90 | Large Excavator | |
| Unconstrained buckling pressure, <i>BS 9295 Equation 34</i> | kN/m ² | P _{cra} | 0.01 | | |
| Stiffness of pipe | kN/m ² | | 11.74 | | |
| Deflection lag factor | | D _L | 1.50 | | |
| Factor of safety (buckling - with soil support), <i>BS 9295 Equation 32, pg 52</i> | | FOS | 3.98 | | OK (FOS>2) |
| Factor of safety (buckling - without soil support), <i>BS 9295 Equation 33</i> | | FOS | 0.00 | Fail (FOS<1) | |
| Ovalisation & Bending Stress | | | | | |
| Ovalisation, <i>BS 9295 Equation 35</i> | | Δ/D | 0.01885 | Large Excavator | |
| Ratio of wall thickness to diameter | | t/D | 0.01 | | |
| Ovalisation | % | Y | 1.88 | | OK (deflection<3%) |
| | | m | 0.015 | | |
| Hoop stress (Barlow) | kN/m ² | | 45070 | | |
| Factor of safety (against bursting) | | FOS | 5.21 | OK (FOS>2) | |



CALCULATION PACK

DOCUMENT No

PT/AU/Calcs_1.2m

PROJECT NO.

PROJECT TITLE

N/A

Augean / ENRMF site

SUBJECT

SHEET No

Steel Pipeline Calculations @ 1.2m cover, wall thickness 5.5mm

1 of 6

| ISSUE | TOTAL SHEET (S) | AUTHOR | DATE | CHECKED BY | DATE | APPROVED BY | DATE | COMMENTS |
|-------|-----------------|--------|----------|------------|----------|-------------|------|-------------|
| 1 | 6 | SJRD | 24/05/22 | SJRD | 27/05/22 | | | First Draft |
| 2 | | | | | | | | |
| 3 | | | | | | | | |
| 4 | | | | | | | | |

SUPERSEDES DOC No

DATE

DESIGN BA: 0.01**Source of Info**

1. ENRMF DCO Application Anglian Water Pipelines. Table 1 Scoping Table for Scenarios of Risk Assessment
- 2.
- 3.

Standards and References

4. BS 9295:2020.
- 5.
- 6.
- 7.

Remit

Design Scenario:
Burial depth = 1.2m

STEEL PRESSURE PIPELINE

VARIABLE INPUTS

Pipe Properties

| | Units | Symbol | Value | Notes (assumed values etc) |
|--|-------------------|----------------|----------------------|---|
| Is this calculation for twin steel pipes laid in a single trench? | | | Yes | Select |
| Steel Grade | | | L235 | Select pipe grade Assumed - worst case |
| Internal diameter (Nominal) | m | DN | 0.8 | Select pipe diameter |
| External diameter | m | Bc | 0.811 | |
| Wall thickness (standard for the diameter selected) | m | t | 0.0071 | From look up table |
| Wall thickness (choose) | m | t | 0.0055 | Type in value |
| Poisson's ratio (steel) | | ν_{steel} | 0.3 | |
| Type of pipe lining | | | Cement mortar | Select Assumed - worst case |
| Cement mortar lining thickness | m | t_l | 0.01 | |
| Poisson's ratio (mortar) | | ν_{mortar} | 0.3 | |
| Weight of pipe + cement mortar | | kg/m | 219 | |
| Poisson's ratio (epoxy) | | ν_{epoxy} | N/A | |
| Weight of pipe + epoxy | | kg/m | N/A | |
| Modulus of Elasticity (steel) | MN/m ² | E | 207000 | Standard value |
| Second moment of area of pipe wall | m ⁴ /m | I | 1.38646E-08 | |
| Pipe stiffness (no CM lining) | N/m ² | S | 5491 | |
| Density of mild steel | Kg/m ³ | | 7850 | Assumed |
| Yield Strength | MN/m ² | F_y | 235 | |

Installation variables

| | | | | |
|---|-------------------|----------|-------|---|
| Depth of cover | m | H | 1.2 | ENRMF DCO application Table 1 |
| Height of water above pipeline | m | H_w | 0 | No groundwater found in any borehole |
| Trench width | m | B_d | 7 | Assumed original trench width |
| Soil density | kN/m ³ | γ | 19.8 | Typical value (BS EN 1295-1) |
| Native soil modulus | MN/m ² | E^3 | 5 | Input soil modulus from BS 9295 Table 13 (stiff clay) |
| Modulus of surround | MN/m ² | E^2 | 5 | BS 9295 Table 14 (Class B1 85% compacted gravel to pipe haunches) |
| Thickness of bedding | m | | 0.15 | Assumed - standard value |
| Deflection lag factor | | D_L | 1.5 | BS 9295 Table 14 (85% compacted graded gravel) |
| Max pressure | bar | P_i | 8 | ENRMF DCO application Table 1 |
| Min pressure - vacuum ONLY. If vacuum = 0, enter 0.01 | bar | P_u | 0.01 | No vacuum |
| If twin pipes, spacing between pipes (OD to OD) | m | s | 4.816 | Leave blank if single pipe |

Pipe Data

Source: FT Pipelines
<https://ftpipelinesystems.co.uk/wp-content/uploads/2012/11/data-sheel-large-bore-welded-joints-nov2012.pdf>

| Internal diameter | Outside diameter | steel wall thickness* | Cement mortar lining thickness | Weight of pipe + CM lining | Weight of pipe + CM lining | Weight of pipe + epoxy lining | Weight of pipe + epoxy lining | Pressure rating** |
|-------------------|------------------|-----------------------|--------------------------------|----------------------------|----------------------------|-------------------------------|-------------------------------|-------------------|
| m | m | m | m | kg/m | kN/m | kg/m | kN/m | Bar |
| 0.08 | 0.0889 | 0.0036 | 0.003 | 11.4 | 0.11 | 8 | 0.08 | 123 |
| 0.1 | 0.1145 | 0.0036 | 0.003 | 14.6 | 0.14 | 10.2 | 0.10 | 95 |
| 0.15 | 0.1683 | 0.004 | 0.003 | 23.3 | 0.23 | 16.3 | 0.16 | 73 |
| 0.2 | 0.2191 | 0.0045 | 0.004 | 34.9 | 0.34 | 24.4 | 0.24 | 64 |
| 0.25 | 0.273 | 0.005 | 0.004 | 46.9 | 0.46 | 32.8 | 0.32 | 57 |
| 0.3 | 0.3239 | 0.0056 | 0.004 | 60.9 | 0.60 | 42.6 | 0.42 | 54 |
| 0.35 | 0.3556 | 0.0056 | 0.005 | 69.4 | 0.68 | 48.6 | 0.48 | 50 |
| 0.4 | 0.4064 | 0.0063 | 0.005 | 86.4 | 0.85 | 60.5 | 0.59 | 49 |
| 0.45 | 0.457 | 0.0063 | 0.006 | 77 | 0.76 | 55 | 0.54 | 33 |
| 0.5 | 0.508 | 0.0056 | 0.006 | 92 | 0.90 | 67 | 0.66 | 27 |
| 0.6 | 0.61 | 0.0063 | 0.008 | 130 | 1.28 | 82 | 0.80 | 26 |
| 0.7 | 0.711 | 0.0071 | 0.008 | 164 | 1.61 | 106 | 1.04 | 26 |
| 0.8 | 0.813 | 0.0071 | 0.01 | 219 | 2.15 | 136 | 1.33 | 25 |
| 0.9 | 0.914 | 0.008 | 0.01 | 266 | 2.61 | 171 | 1.68 | 25 |
| 1 | 1.016 | 0.0088 | 0.012 | 333 | 3.27 | 213 | 2.09 | 24 |
| 1.1 | 1.118 | 0.01 | 0.014 | 417 | 4.09 | 256 | 2.51 | 25 |
| 1.2 | 1.219 | 0.01 | 0.014 | 485 | 4.76 | 315 | 3.09 | 24 |

* Where more than one wall thickness is given for a size, the lower value has been taken here
 ** Where more than one pressure rating is given for a size, the lower value has been taken here

Pipe lining

| Lining | Poisson |
|---------------|---------|
| Cement mortar | 0.3 |
| Epoxy | 0.36 |

Vehicular loading data

@1.2m deep @3m deep

| | @1.2m deep | @3m deep |
|-------------------------|------------|----------|
| Main Roads | | |
| Fields & Gardens | | |
| A40 Dump Truck | 108.31 | 35.9 |
| Hitachi Large Excavator | 77.59 | 18.93 |
| | | |

General soil properties BS 9295 Section 6.6

| | |
|------------|------------------------|
| K_{μ} | 0.19 |
| K_{μ}' | 0.13 |
| γ | 19.6 kN/m ³ |

CALCULATIONS IN ACCORDANCE WITH BS 9295 (2020)

Fields & Gardens

| | UNIT | SYMBOL | VALUE | |
|---|-------------------|------------------|--------------|------------------------------|
| Loading | | | | |
| Backfill pressure, <i>BS 9295 Equation 27</i> | kN/m ² | P _e | 23.76 | Fields & Gardens |
| Road traffic loading, <i>BS 9295 Section 5.3</i> | kN/m ² | P _s | 27.21 | |
| Total vertical pressure, <i>BS 9295 Equation 28</i> | kN/m ² | P | 50.97 | |
| Leonhardt's coefficient, <i>BS 9295 Equation 29</i> | | C _L | 1.00 | |
| Overall modulus of soil reaction, <i>BS 9295 Equation 30</i> | MN/m ² | E' | 5.00 | |
| Buckling | | | | |
| Critical buckling pressure, <i>BS 9295 Equation 31</i> | kN/m ² | P _{cr} | 316.63 | |
| Unconstrained buckling pressure, <i>BS 9295 Equation 34</i> | kN/m ² | P _{cra} | 131.79 | |
| Stiffness of pipe | kN/m ² | | 5.49 | |
| Deflection lag factor | | D _L | 1.50 | |
| Factor of safety (buckling - with soil support), <i>BS 9295 Equation 32, pg 52</i> | | FOS | 6.09 | OK (FOS>2) |
| Factor of safety (buckling - without soil support), <i>BS 9295 Equation 33</i> | | FOS | 5.32 | OK (FOS>1) |
| Ovalisation & Bending Stress | | | | |
| Ovalisation, <i>BS 9295 Equation 35</i> | | Δ/D | 0.01196 | |
| Ratio of wall thickness to diameter | | t/D | 0.01 | |
| Ovalisation | % | Y | 1.20 | OK (deflection<3%) |
| | | m | 0.010 | |
| Hoop stress (Barlow) | kN/m ² | | 58182 | |
| Factor of safety (against bursting) | | FOS | 4.04 | OK (FOS>2) |

CALCULATIONS IN ACCORDANCE WITH BS 9295 (2020)

A40 Dump Truck

| | UNIT | SYMBOL | VALUE | |
|---|-------------------|------------------|--------------|--------------------|
| Loading | | | | |
| Backfill pressure, <i>BS 9295 Equation 27</i> | kN/m ² | P _e | 23.76 | |
| Road traffic loading, <i>BS 9295 Section 5.3</i> | kN/m ² | P _s | 108.00 | A40 Dump Truck |
| Total vertical pressure, <i>BS 9295 Equation 28</i> | kN/m ² | P | 131.76 | |
| Leonhardt's coefficient, <i>BS 9295 Equation 29</i> | | C _L | 1.00 | |
| Overall modulus of soil reaction, <i>BS 9295 Equation 30</i> | MN/m ² | E' | 5.00 | |
| Buckling | | | | |
| Critical buckling pressure, <i>BS 9295 Equation 31</i> | kN/m ² | P _{cr} | 316.63 | |
| Unconstrained buckling pressure, <i>BS 9295 Equation 34</i> | kN/m ² | P _{cra} | 131.79 | |
| Stiffness of pipe | kN/m ² | | 5.49 | |
| Deflection lag factor | | D _L | 1.50 | |
| Factor of safety (buckling - with soil support), <i>BS 9295 Equation 32, pg 52</i> | | FOS | 2.39 | OK (FOS>2) |
| Factor of safety (buckling - without soil support), <i>BS 9295 Equation 33</i> | | FOS | 5.32 | OK (FOS>1) |
| Ovalisation & Bending Stress | | | | |
| Ovalisation, <i>BS 9295 Equation 35</i> | | Δ/D | 0.02733 | |
| Ratio of wall thickness to diameter | | t/D | 0.01 | |
| Ovalisation | % | Y | 2.73 | OK (deflection<3%) |
| | | m | 0.022 | |
| Hoop stress (Barlow) | kN/m ² | | 58182 | |
| Factor of safety (against bursting) | | FOS | 4.04 | OK (FOS>2) |

CALCULATIONS IN ACCORDANCE WITH BS 9295 (2020)

Large Excavator

| | UNIT | SYMBOL | VALUE | |
|---|-------------------|------------------|--------------|--------------------------|
| Loading | | | | |
| Backfill pressure, <i>BS 9295 Equation 27</i> | kN/m ² | P _e | 23.76 | Large Excavator |
| Road traffic loading, <i>BS 9295 Section 5.3</i> | kN/m ² | P _s | 77.59 | |
| Total vertical pressure, <i>BS 9295 Equation 28</i> | kN/m ² | P | 101.35 | |
| Leonhardt's coefficient, <i>BS 9295 Equation 29</i> | | C _L | 1.00 | |
| Overall modulus of soil reaction, <i>BS 9295 Equation 30</i> | MN/m ² | E' | 5.00 | |
| Buckling | | | | |
| Critical buckling pressure, <i>BS 9295 Equation 31</i> | kN/m ² | P _{cr} | 316.63 | OK (FOS>2) OK (FOS>1) |
| Unconstrained buckling pressure, <i>BS 9295 Equation 34</i> | kN/m ² | P _{cra} | 131.79 | |
| Stiffness of pipe | kN/m ² | | 5.49 | |
| Deflection lag factor | | D _L | 1.50 | |
| Factor of safety (buckling - with soil support), <i>BS 9295 Equation 32, pg 52</i> | | FOS | 3.09 | |
| Factor of safety (buckling - without soil support), <i>BS 9295 Equation 33</i> | | FOS | 5.32 | |
| Ovalisation & Bending Stress | | | | |
| Ovalisation, <i>BS 9295 Equation 35</i> | | Δ/D | 0.02155 | OK (deflection<3%) |
| Ratio of wall thickness to diameter | | t/D | 0.01 | |
| Ovalisation | % | Y | 2.15 | |
| | | m | 0.017 | |
| Hoop stress (Barlow) | kN/m ² | | 58182 | OK (FOS>2) |
| Factor of safety (against bursting) | | FOS | 4.04 | |



CALCULATION PACK

DOCUMENT No

PT/AU/Calcs_3m

PROJECT NO.

PROJECT TITLE

N/A

Augean / ENRMF site

SUBJECT

SHEET No

Steel Pipeline Calculations @ 3m cover, wall thickness 7.1mm

1 of 6

| ISSUE | TOTAL SHEET (S) | AUTHOR | DATE | CHECKED BY | DATE | APPROVED BY | DATE | COMMENTS |
|-------|-----------------|--------|----------|------------|----------|-------------|------|-------------|
| 1 | 6 | SJRD | 24/05/22 | SJRD | 27/05/22 | | | First Draft |
| 2 | | | | | | | | |
| 3 | | | | | | | | |
| 4 | | | | | | | | |

SUPERSEDES DOC No

DATE

DESIGN BA: 0.01

Source of Info

1. ENRMF DCO Application Anglian Water Pipelines. Table 1 Scoping Table for Scenarios of Risk Assessment
- 2.
- 3.

Standards and References

4. BS 9295:2020.
- 5.
- 6.
- 7.

Remit

Design Scenario:
Burial depth = 3m

STEEL PRESSURE PIPELINE

VARIABLE INPUTS

Pipe Properties

| | Units | Symbol | Value | Notes (assumed values etc) |
|--|-------------------|--------------|---------------|---|
| Is this calculation for twin steel pipes laid in a single trench? | | | Yes | Select |
| Steel Grade | | | L235 | Select pipe grade Assumed - worst case |
| Internal diameter (Nominal) | m | DN | 0.8 | Select pipe diameter |
| External diameter | m | Bc | 0.8142 | |
| Wall thickness (standard for the diameter selected) | m | t | 0.0071 | From look up table |
| Wall thickness (choose) | m | t | 0.0071 | Type in value |
| Poisson's ratio (steel) | | v_{steel} | 0.3 | |
| Type of pipe lining | | | Cement mortar | Select Assumed - worst case |
| Cement mortar lining thickness | m | t_L | 0.01 | |
| Poisson's ratio (mortar) | | v_{mortar} | 0.3 | |
| Weight of pipe + cement mortar | | kg/m | 219 | |
| Poisson's ratio (epoxy) | | v_{epoxy} | N/A | |
| Weight of pipe + epoxy | | kg/m | N/A | |
| Modulus of Elasticity (steel) | MN/m ² | E | 207000 | Standard value |
| Second moment of area of pipe wall | m ⁴ /m | I | 2.98259E-08 | |
| Pipe stiffness (no CM lining) | N/m ² | S | 11743 | |
| Density of mild steel | Kg/m ³ | | 7850 | Assumed |
| Yield Strength | MN/m ² | F_y | 235 | |
| Installation variables | | | | |
| Depth of cover | m | H | 3 | ENRMF DCO application Table 1 |
| Height of water above pipeline | m | H_w | 0 | No groundwater found in any borehole |
| Trench width | m | B_d | 7 | Assumed original trench width |
| Soil density | kN/m ³ | γ | 19.8 | Typical value (BS EN 1295-1) |
| Native soil modulus | MN/m ² | E^3 | 5 | Input soil modulus from BS 9295 Table 13 (stiff clay) |
| Modulus of surround | MN/m ² | E^2 | 5 | BS 9295 Table 14 (Class B1 85% compacted gravel to pipe haunches) |
| Thickness of bedding | m | | 0.15 | Assumed - standard value |
| Deflection lag factor | | D_L | 1.5 | BS 9295 Table 14 (85% compacted graded gravel) |
| Max pressure | bar | P_i | 8 | ENRMF DCO application Table 1 |
| Min pressure - vacuum ONLY. If vacuum = 0, enter 0.01 | bar | P_u | 0.01 | No vacuum |
| If twin pipes, spacing between pipes (OD to OD) | m | s | 4.816 | Leave blank if single pipe |

Pipe Data

Source: FT Pipelines
<https://ftpipelinesystems.co.uk/wp-content/uploads/2012/11/data-sheel-large-bore-welded-joints-nov2012.pdf>

| Internal diameter | Outside diameter | steel wall thickness* | Cement mortar lining thickness | Weight of pipe + CM lining | Weight of pipe + CM lining | Weight of pipe + epoxy lining | Weight of pipe + epoxy lining | Pressure rating** |
|-------------------|------------------|-----------------------|--------------------------------|----------------------------|----------------------------|-------------------------------|-------------------------------|-------------------|
| m | m | m | m | kg/m | kN/m | kg/m | kN/m | Bar |
| 0.08 | 0.0889 | 0.0036 | 0.003 | 11.4 | 0.11 | 8 | 0.08 | 123 |
| 0.1 | 0.1145 | 0.0036 | 0.003 | 14.6 | 0.14 | 10.2 | 0.10 | 95 |
| 0.15 | 0.1683 | 0.004 | 0.003 | 23.3 | 0.23 | 16.3 | 0.16 | 73 |
| 0.2 | 0.2191 | 0.0045 | 0.004 | 34.9 | 0.34 | 24.4 | 0.24 | 64 |
| 0.25 | 0.273 | 0.005 | 0.004 | 46.9 | 0.46 | 32.8 | 0.32 | 57 |
| 0.3 | 0.3239 | 0.0056 | 0.004 | 60.9 | 0.60 | 42.6 | 0.42 | 54 |
| 0.35 | 0.3556 | 0.0056 | 0.0071 | 69.4 | 0.68 | 48.6 | 0.48 | 50 |
| 0.4 | 0.4064 | 0.0063 | 0.005 | 86.4 | 0.85 | 60.5 | 0.59 | 49 |
| 0.45 | 0.457 | 0.0063 | 0.006 | 77 | 0.76 | 55 | 0.54 | 33 |
| 0.5 | 0.508 | 0.0056 | 0.006 | 92 | 0.90 | 67 | 0.66 | 27 |
| 0.6 | 0.61 | 0.0063 | 0.008 | 130 | 1.28 | 82 | 0.80 | 26 |
| 0.7 | 0.711 | 0.0071 | 0.008 | 164 | 1.61 | 106 | 1.04 | 26 |
| 0.8 | 0.813 | 0.0071 | 0.01 | 219 | 2.15 | 136 | 1.33 | 25 |
| 0.9 | 0.914 | 0.008 | 0.01 | 266 | 2.61 | 171 | 1.68 | 25 |
| 1 | 1.016 | 0.0088 | 0.012 | 333 | 3.27 | 213 | 2.09 | 24 |
| 1.1 | 1.118 | 0.01 | 0.014 | 417 | 4.09 | 256 | 2.51 | 25 |
| 1.2 | 1.219 | 0.01 | 0.014 | 485 | 4.76 | 315 | 3.09 | 24 |

* Where more than one wall thickness is given for a size, the lower value has been taken here
 ** Where more than one pressure rating is given for a size, the lower value has been taken here

Pipe lining

| Lining | Poisson |
|---------------|---------|
| Cement mortar | 0.3 |
| Epoxy | 0.36 |

Vehicular loading data

@1.2m deep @3m deep

| Main Roads | | |
|-------------------------|--------|-------|
| Fields & Gardens | | |
| A40 Dump Truck | 108.31 | 35.9 |
| Hitachi Large Excavator | 77.59 | 18.93 |
| | | |

General soil properties BS 9295 Section 6.6

| | | |
|-------------|------|-------------------|
| K_{μ} | 0.19 | kN/m ³ |
| K_{μ}^l | 0.13 | |
| γ | 19.6 | |

CALCULATIONS IN ACCORDANCE WITH BS 9295 (2020)

Fields & Gardens

| | UNIT | SYMBOL | VALUE |
|---|-------------------|----------------|--------------|
| Loading | | | |
| Backfill pressure, BS 9295 Equation 27 | kN/m ² | P _e | 59.40 |
| Road traffic loading, BS 9295 Section 5.3 | kN/m ² | P _s | 5.47 |
| Total vertical pressure, BS 9295 Equation 28 | kN/m ² | P | 64.87 |
| Leonhardt's coefficient, BS 9295 Equation 29 | | C _L | 1.00 |
| Overall modulus of soil reaction, BS 9295 Equation 30 | MN/m ² | E' | 5.00 |

Fields & Gardens

| | | | |
|--|-------------------|------------------|---------------------|
| Buckling | | | |
| Critical buckling pressure, BS 9295 Equation 31 | kN/m ² | P _{cr} | 406.90 |
| Unconstrained buckling pressure, BS 9295 Equation 34 | kN/m ² | P _{cra} | 0.01 |
| Stiffness of pipe | kN/m ² | | 11.74 |
| Deflection lag factor | | D _L | 1.50 |
| Factor of safety (buckling - with soil support), BS 9295 Equation 32, pg 52 | | FOS | 6.18 |
| Factor of safety (buckling - without soil support), BS 9295 Equation 33 | | FOS | no calc reqd |

OK (FOS>2)

OK (FOS>1)

| | | | |
|--|-------------------|------------|--------------|
| Ovalisation & Bending Stress | | | |
| Ovalisation, BS 9295 Equation 35 | | Δ/D | 0.01968 |
| Ratio of wall thickness to diameter | | t/D | 0.01 |
| Ovalisation | % | Y | 1.97 |
| | | m | 0.016 |
| Hoop stress (Barlow) | kN/m ² | | 45070 |
| Factor of safety (against bursting) | | FOS | 5.21 |

OK (deflection<3%)

OK (FOS>2)

CALCULATIONS IN ACCORDANCE WITH BS 9295 (2020)

A40 Dump Truck

| | UNIT | SYMBOL | VALUE |
|---|-------------------|----------------|-------|
| Loading | | | |
| Backfill pressure, BS 9295 Equation 27 | kN/m ² | P _e | 59.40 |
| Road traffic loading, BS 9295 Section 5.3 | kN/m ² | P _s | 35.90 |
| Total vertical pressure, BS 9295 Equation 28 | kN/m ² | P | 95.30 |
| Leonhardt's coefficient, BS 9295 Equation 29 | | C _L | 1.00 |
| Overall modulus of soil reaction, BS 9295 Equation 30 | MN/m ² | E' | 5.00 |

A40 Dump Truck

| | | | |
|--|-------------------|------------------|---------------------|
| Buckling | | | |
| Critical buckling pressure, BS 9295 Equation 31 | kN/m ² | P _{cr} | 406.90 |
| Unconstrained buckling pressure, BS 9295 Equation 34 | kN/m ² | P _{cra} | 0.01 |
| Stiffness of pipe | kN/m ² | | 11.74 |
| Deflection lag factor | | D _L | 1.50 |
| Factor of safety (buckling - with soil support), BS 9295 Equation 32, pg 52 | | FOS | 4.23 |
| Factor of safety (buckling - without soil support), BS 9295 Equation 33 | | FOS | no calc reqd |

OK (FOS>2)

OK (FOS>1)

| | | | |
|--|-------------------|------------|--------------|
| Ovalisation & Bending Stress | | | |
| Ovalisation, BS 9295 Equation 35 | | Δ/D | 0.02601 |
| Ratio of wall thickness to diameter | | t/D | 0.01 |
| Ovalisation | % | Y | 2.60 |
| | | m | 0.021 |
| Hoop stress (Barlow) | kN/m ² | | 45070 |
| Factor of safety (against bursting) | | FOS | 5.21 |

OK (deflection<3%)

OK (FOS>2)

CALCULATIONS IN ACCORDANCE WITH BS 9295 (2020)

Large Excavator

| | UNIT | SYMBOL | VALUE |
|---|-------------------|----------------|--------------|
| Loading | | | |
| Backfill pressure, BS 9295 Equation 27 | kN/m ² | P _e | 59.40 |
| Road traffic loading, BS 9295 Section 5.3 | kN/m ² | P _s | 18.93 |
| Total vertical pressure, BS 9295 Equation 28 | kN/m ² | P | 78.33 |
| Leonhardt's coefficient, BS 9295 Equation 29 | | C _L | 1.00 |
| Overall modulus of soil reaction, BS 9295 Equation 30 | MN/m ² | E' | 5.00 |

Large Excavator

| | | | |
|--|-------------------|------------------|---------------------|
| Buckling | | | |
| Critical buckling pressure, BS 9295 Equation 31 | kN/m ² | P _{cr} | 406.90 |
| Unconstrained buckling pressure, BS 9295 Equation 34 | kN/m ² | P _{cra} | 0.01 |
| Stiffness of pipe | kN/m ² | | 11.74 |
| Deflection lag factor | | D _L | 1.50 |
| Factor of safety (buckling - with soil support), BS 9295 Equation 32, pg 52 | | FOS | 5.13 |
| Factor of safety (buckling - without soil support), BS 9295 Equation 33 | | FOS | no calc reqd |

OK (FOS>2)

OK (FOS>1)

| | | | |
|--|-------------------|------------|--------------|
| Ovalisation & Bending Stress | | | |
| Ovalisation, BS 9295 Equation 35 | | Δ/D | 0.02248 |
| Ratio of wall thickness to diameter | | t/D | 0.01 |
| Ovalisation | % | Y | 2.25 |
| | | m | 0.018 |
| Hoop stress (Barlow) | kN/m ² | | 45070 |
| Factor of safety (against bursting) | | FOS | 5.21 |

OK (deflection<3%)

OK (FOS>2)



CALCULATION PACK

DOCUMENT No

PT/AU/Calcs_3m

PROJECT NO.

PROJECT TITLE

N/A

Augean / ENRMF site

SUBJECT

SHEET No

Steel Pipeline Calculations @ 3m cover, wall thickness 5.5mm

1 of 6

| ISSUE | TOTAL SHEET (S) | AUTHOR | DATE | CHECKED BY | DATE | APPROVED BY | DATE | COMMENTS |
|-------|-----------------|--------|----------|------------|----------|-------------|------|-------------|
| 1 | 6 | SJRD | 24/05/22 | SJRD | 27/05/22 | | | First Draft |
| 2 | | | | | | | | |
| 3 | | | | | | | | |
| 4 | | | | | | | | |

SUPERSEDES DOC No

DATE

DESIGN BA: 0.01

Source of Info

1. ENRMF DCO Application Anglian Water Pipelines. Table 1 Scoping Table for Scenarios of Risk Assessment
- 2.
- 3.

Standards and References

4. BS 9295:2020.
- 5.
- 6.
- 7.

Remit

Design Scenario:

Burial depth = 3m

STEEL PRESSURE PIPELINE

VARIABLE INPUTS

Pipe Properties

| | Units | Symbol | Value | Notes (assumed values etc) |
|--|-------------------|-----------------------|---------------|---|
| Is this calculation for twin steel pipes laid in a single trench? | | | Yes | Select |
| Steel Grade | | | L235 | Select pipe grade Assumed - worst case |
| Internal diameter (Nominal) | m | DN | 0.8 | Select pipe diameter |
| External diameter | m | Bc | 0.811 | |
| Wall thickness (standard for the diameter selected) | m | t | 0.0071 | From look up table |
| Wall thickness (choose) | m | t | 0.0055 | Type in value |
| Poisson's ratio (steel) | | ν_{steel} | 0.3 | |
| Type of pipe lining | | | Cement mortar | Select Assumed - worst case |
| Cement mortar lining thickness | m | t_L | 0.01 | |
| Poisson's ratio (mortar) | | ν_{mortar} | 0.3 | |
| Weight of pipe + cement mortar | | kg/m | 219 | |
| Poisson's ratio (epoxy) | | ν_{epoxy} | N/A | |
| Weight of pipe + epoxy | | kg/m | N/A | |
| Modulus of Elasticity (steel) | MN/m ² | E | 207000 | Standard value |
| Second moment of area of pipe wall | m ⁴ /m | I | 1.38646E-08 | |
| Pipe stiffness (no CM lining) | N/m ² | S | 5491 | |
| Density of mild steel | Kg/m ³ | | 7850 | Assumed |
| Yield Strength | MN/m ² | F_y | 235 | |
| Installation variables | | | | |
| Depth of cover | m | H | 3 | ENRMF DCO application Table 1 |
| Height of water above pipeline | m | H_w | 0 | No groundwater found in any borehole |
| Trench width | m | B_d | 7 | Assumed original trench width |
| Soil density | kN/m ³ | γ | 19.8 | Typical value (BS EN 1295-1) |
| Native soil modulus | MN/m ² | E^3 | 5 | Input soil modulus from BS 9295 Table 13 (stiff clay) |
| Modulus of surround | MN/m ² | E^2 | 5 | BS 9295 Table 14 (Class B1 85% compacted gravel to pipe haunches) |
| Thickness of bedding | m | | 0.15 | Assumed - standard value |
| Deflection lag factor | | D_L | 1.5 | BS 9295 Table 14 (85% compacted graded gravel) |
| Max pressure | bar | P_i | 8 | ENRMF DCO application Table 1 |
| Min pressure - vacuum ONLY. If vacuum = 0, enter 0.01 | bar | P_u | 0.01 | No vacuum |
| If twin pipes, spacing between pipes (OD to OD) | m | s | 4.816 | Leave blank if single pipe |

Pipe Data

Source: FT Pipelines
<https://ftpipelinesystems.co.uk/wp-content/uploads/2012/11/data-sheel-large-bore-welded-joints-nov2012.pdf>

| Internal diameter | Outside diameter | steel wall thickness* | Cement mortar lining thickness | Weight of pipe + CM lining | Weight of pipe + CM lining | Weight of pipe + epoxy lining | Weight of pipe + epoxy lining | Pressure rating** |
|-------------------|------------------|-----------------------|--------------------------------|----------------------------|----------------------------|-------------------------------|-------------------------------|-------------------|
| m | m | m | m | kg/m | kN/m | kg/m | kN/m | Bar |
| 0.08 | 0.0889 | 0.0036 | 0.003 | 11.4 | 0.11 | 8 | 0.08 | 123 |
| 0.1 | 0.1145 | 0.0036 | 0.003 | 14.6 | 0.14 | 10.2 | 0.10 | 95 |
| 0.15 | 0.1683 | 0.004 | 0.003 | 23.3 | 0.23 | 16.3 | 0.16 | 73 |
| 0.2 | 0.2191 | 0.0045 | 0.004 | 34.9 | 0.34 | 24.4 | 0.24 | 64 |
| 0.25 | 0.273 | 0.005 | 0.004 | 46.9 | 0.46 | 32.8 | 0.32 | 57 |
| 0.3 | 0.3239 | 0.0056 | 0.004 | 60.9 | 0.60 | 42.6 | 0.42 | 54 |
| 0.35 | 0.3556 | 0.0056 | 0.005 | 69.4 | 0.68 | 48.6 | 0.48 | 50 |
| 0.4 | 0.4064 | 0.0063 | 0.005 | 86.4 | 0.85 | 60.5 | 0.59 | 49 |
| 0.45 | 0.457 | 0.0063 | 0.006 | 77 | 0.76 | 55 | 0.54 | 33 |
| 0.5 | 0.508 | 0.0056 | 0.006 | 92 | 0.90 | 67 | 0.66 | 27 |
| 0.6 | 0.61 | 0.0063 | 0.008 | 130 | 1.28 | 82 | 0.80 | 26 |
| 0.7 | 0.711 | 0.0071 | 0.008 | 164 | 1.61 | 106 | 1.04 | 26 |
| 0.8 | 0.813 | 0.0071 | 0.01 | 219 | 2.15 | 136 | 1.33 | 25 |
| 0.9 | 0.914 | 0.008 | 0.01 | 266 | 2.61 | 171 | 1.68 | 25 |
| 1 | 1.016 | 0.0088 | 0.012 | 333 | 3.27 | 213 | 2.09 | 24 |
| 1.1 | 1.118 | 0.01 | 0.014 | 417 | 4.09 | 256 | 2.51 | 25 |
| 1.2 | 1.219 | 0.01 | 0.014 | 485 | 4.76 | 315 | 3.09 | 24 |

* Where more than one wall thickness is given for a size, the lower value has been taken here
 ** Where more than one pressure rating is given for a size, the lower value has been taken here

Pipe lining

| Lining | Poisson |
|---------------|---------|
| Cement mortar | 0.3 |
| Epoxy | 0.36 |

Vehicular loading data

@1.2m deep @3m deep

| Main Roads | | |
|-------------------------|--------|-------|
| Fields & Gardens | | |
| A40 Dump Truck | 108.31 | 35.9 |
| Hitachi Large Excavator | 77.59 | 18.93 |
| | | |

General soil properties BS 9295 Section 6.6

| | | |
|-------------|------|-------------------|
| K_{μ} | 0.19 | kN/m ³ |
| K_{μ}^l | 0.13 | |
| γ | 19.6 | |

CALCULATIONS IN ACCORDANCE WITH BS 9295 (2020)

Fields & Gardens

| | UNIT | SYMBOL | VALUE |
|--|-------------------|----------------|--------------|
| Loading | | | |
| Backfill pressure, <i>BS 9295 Equation 27</i> | kN/m ² | P _e | 59.40 |
| Road traffic loading, <i>BS 9295 Section 5.3</i> | kN/m ² | P _s | 5.47 |
| Total vertical pressure, <i>BS 9295 Equation 28</i> | kN/m ² | P | 64.87 |
| Leonhardt's coefficient, <i>BS 9295 Equation 29</i> | | C _L | 1.00 |
| Overall modulus of soil reaction, <i>BS 9295 Equation 30</i> | MN/m ² | E' | 5.00 |

Fields & Gardens

| | | | |
|---|-------------------|------------------|---------------------|
| Buckling | | | |
| Critical buckling pressure, <i>BS 9295 Equation 31</i> | kN/m ² | P _{cr} | 316.63 |
| Unconstrained buckling pressure, <i>BS 9295 Equation 34</i> | kN/m ² | P _{cra} | 131.79 |
| Stiffness of pipe | kN/m ² | | 5.49 |
| Deflection lag factor | | D _L | 1.50 |
| Factor of safety (buckling - with soil support), <i>BS 9295 Equation 32, pg 52</i> | | FOS | 4.81 |
| Factor of safety (buckling - without soil support), <i>BS 9295 Equation 33</i> | | FOS | no calc reqd |

OK (FOS>2)

OK (FOS>1)

| | | | |
|--|-------------------|------------|--------------|
| Ovalisation & Bending Stress | | | |
| Ovalisation, <i>BS 9295 Equation 35</i> | | Δ/D | 0.02250 |
| Ratio of wall thickness to diameter | | t/D | 0.01 |
| Ovalisation | % | Y | 2.25 |
| | | m | 0.018 |
| Hoop stress (Barlow) | kN/m ² | | 58182 |
| Factor of safety (against bursting) | | FOS | 4.04 |

OK (deflection<3%)

OK (FOS>2)

CALCULATIONS IN ACCORDANCE WITH BS 9295 (2020)

A40 Dump Truck

| | UNIT | SYMBOL | VALUE |
|---|-------------------|----------------|-------|
| Loading | | | |
| Backfill pressure, BS 9295 Equation 27 | kN/m ² | P _e | 59.40 |
| Road traffic loading, BS 9295 Section 5.3 | kN/m ² | P _s | 35.90 |
| Total vertical pressure, BS 9295 Equation 28 | kN/m ² | P | 95.30 |
| Leonhardt's coefficient, BS 9295 Equation 29 | | C _L | 1.00 |
| Overall modulus of soil reaction, BS 9295 Equation 30 | MN/m ² | E' | 5.00 |

A40 Dump Truck

| | | | |
|---|-------------------|------------------|--------------|
| Buckling | | | |
| Critical buckling pressure, BS 9295 Equation 31 | kN/m ² | P _{cr} | 316.63 |
| Unconstrained buckling pressure, BS 9295 Equation 34 | kN/m ² | P _{cra} | 131.79 |
| Stiffness of pipe | kN/m ² | | 5.49 |
| Deflection lag factor | | D _L | 1.50 |
| Factor of safety (buckling - with soil support), BS 9295 Equation 32, pg 52 | | FOS | 3.29 |
| Factor of safety (buckling - without soil support), BS 9295 Equation 33 | | FOS | no calc reqd |

OK (FOS>2)

OK (FOS>1)

| | | | |
|---|-------------------|-----|---------|
| Ovalisation & Bending Stress | | | |
| Ovalisation, BS 9295 Equation 35 | | Δ/D | 0.02973 |
| Ratio of wall thickness to diameter | | t/D | 0.01 |
| Ovalisation | % | Y | 2.97 |
| | | m | 0.024 |
| Hoop stress (Barlow) | kN/m ² | | 58182 |
| Factor of safety (against bursting) | | FOS | 4.04 |

OK (deflection<3%)

OK (FOS>2)

CALCULATIONS IN ACCORDANCE WITH BS 9295 (2020)

Large Excavator

| | UNIT | SYMBOL | VALUE |
|---|-------------------|----------------|--------------|
| Loading | | | |
| Backfill pressure, BS 9295 Equation 27 | kN/m ² | P _e | 59.40 |
| Road traffic loading, BS 9295 Section 5.3 | kN/m ² | P _s | 18.93 |
| Total vertical pressure, BS 9295 Equation 28 | kN/m ² | P | 78.33 |
| Leonhardt's coefficient, BS 9295 Equation 29 | | C _L | 1.00 |
| Overall modulus of soil reaction, BS 9295 Equation 30 | MN/m ² | E' | 5.00 |

Large Excavator

| | | | |
|--|-------------------|------------------|---------------------|
| Buckling | | | |
| Critical buckling pressure, BS 9295 Equation 31 | kN/m ² | P _{cr} | 316.63 |
| Unconstrained buckling pressure, BS 9295 Equation 34 | kN/m ² | P _{cra} | 131.79 |
| Stiffness of pipe | kN/m ² | | 5.49 |
| Deflection lag factor | | D _L | 1.50 |
| Factor of safety (buckling - with soil support), BS 9295 Equation 32, pg 52 | | FOS | 3.99 |
| Factor of safety (buckling - without soil support), BS 9295 Equation 33 | | FOS | no calc reqd |

OK (FOS>2)

OK (FOS>1)

| | | | |
|--|-------------------|------------|--------------|
| Ovalisation & Bending Stress | | | |
| Ovalisation, BS 9295 Equation 35 | | Δ/D | 0.02570 |
| Ratio of wall thickness to diameter | | t/D | 0.01 |
| Ovalisation | % | Y | 2.57 |
| | | m | 0.021 |
| Hoop stress (Barlow) | kN/m ² | | 58182 |
| Factor of safety (against bursting) | | FOS | 4.04 |

OK (deflection<3%)

OK (FOS>2)