



National Infrastructure Planning  
Temple Quay House  
2 The Square  
Bristol, BS1 6PN

Customer: 0303 444 5000  
Services:

email: [ENRMExtension@planninginspectorate.gov.uk](mailto:ENRMExtension@planninginspectorate.gov.uk)

---

The Applicant by email

Your Ref:

Our Ref: WS010005

Date: 25 July 2022

---

Dear Ms Heasman

## **Planning Act 2008 and The Infrastructure Planning (Examination Procedure) Rules 2010 – Rule 17**

### **Application by Augean South Limited for an Order Granting Development Consent for the East Northants Resource Management Facility Western Extension**

#### **Request for Further Information**

#### ***Proposed Change and Western Power Distribution (WPD)***

I write following the Applicant's request for a proposed change to the Application and its Deadline 7 submissions. Together, those submissions establish a 20m stand-off distance for the Anglian Water (AW) pipelines which cross the western extension land. The Proposed Development also includes the diversion of an overhead electricity cable to follow broadly the same route as the water pipelines (Work 5). However, it is not clear from the Applicant's recent submissions what distance the electricity cable would be from the pipelines. The matter is referred to in the Deadline 7 versions of the DEC Appendix B and the draft Statement of Common Ground (with WPD), as well as the later emails in the bundle of correspondence with AW. The submissions suggest that the matter would be controlled through the Protective Provisions for WPD. Again however, the Provisions as currently drafted do not specify a stand-off distance or other parameter.

I should be grateful if the Applicant would clarify its proposal for the separation distance between the electricity cable and the water pipelines and how this would be controlled through the DCO. It would also help the Examination to have the views of WPD and AW on this matter.

Please respond by email by **Monday 1 August 2022**. Please contact the Case Team if you have any questions about this letter.

Yours sincerely

*Simon Warder*

**Examining Authority**

This communication does not constitute legal advice.  
Please view our [Privacy Notice](#) before sending information to the Planning Inspectorate.

<https://infrastructure.planninginspectorate.gov.uk>

